



State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON  
Lieutenant Governor

Department of  
Environmental Quality

Kimberly D. Shelley  
Executive Director

DIVISION OF WATER QUALITY  
John Mackey, P.E.  
Director

December 26, 2023

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE TO MODIFY A UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO MODIFY A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER THE AUTHORITY OF THE UTAH WATER QUALITY ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

PERMITTEE NAME: Central Davis Sewer District  
FACILITY NAME: Central Davis Sewer District Wastewater Treatment Facility  
MAILING ADDRESS: 2200 South Sunset Drive, Kaysville, Utah 84037  
TELEPHONE NUMBER: (801) 451-2190  
FACILITY LOCATION: 2200 South Sunset Drive, Kaysville, Utah 84037  
UPDES PERMIT NO.: UT0020974  
PERMITTED OUTFALLS: 001  
OUTFALL LOCATION: Latitude 40°59'54", Longitude 111°57'01"  
RECEIVING WATER: Great Salt Lake Farmington Bay

**BACKGROUND**

The Central Davis Sewer District (CDSD) wastewater treatment facility was originally placed in service in 1961. The plant was constructed with one trickling filter, two rectangular clarifiers and an anaerobic digester. The plant was upgraded in the 1970's with an additional secondary trickling filter, two circular clarifiers and additional digestion. In the 1980's a major upgrade was made which included a new headworks, the addition of an oxidation ditch and two final clarifiers, new chlorination equipment, contact basin and additional solids handling facilities including gravity belt thickeners and presses. In the 1990's CDSD expanded to meet the maximum population of the service area. This expansion included a second oxidation ditch, two clarifiers, additional chlorine equipment, a second contact basin and additional solids handling equipment.

The current UPDES permit was issued on May 1, 2020, expiring at midnight on April 30, 2023. The permit has been modified to further explain the lower percent removal effluent limitations for biological oxygen demand percent removal and total suspended solids percent removal, as specified in *Utah Administrative Code R317-1-3.2*.

**PUBLIC COMMENTS**

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12.

Public comments are invited any time prior to the deadline of the close of business on **January 26, 2024**. Written public comments can be submitted to: Jennifer Berjikian, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [wqcomments@utah.gov](mailto:wqcomments@utah.gov).

After considering public comments, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under “Public Participation” at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/) & <https://www.utah.gov/pmn/index.html>. If internet access is not available, a copy may be obtained by calling Jennifer Berjikian at (385) 341-0272.