



PUBLIC HEARING

LOCATION: 80 S Main Street, Spanish Fork, Utah, 84660

DATE: October 1, 2024

TIME: 6 pm

TOPIC: 13.16.100 Illicit Discharges Detection And Elimination

This Section shall apply to all water generated on developed or undeveloped land and then entering the MS4. No person shall introduce or cause to be introduced into the MS4 any discharge that is not composed entirely of stormwater.

A. Exceptions. The commencement, conduct, or continuance of any non-stormwater discharge to the MS4 is prohibited unless it

is an uncontaminated discharge from the following sources:

1. Water line flushing or other potable water source;
2. Landscape irrigation or lawn watering with drinking water or City pressure irrigation water;
3. Diverted stream flows;
4. Rising ground water;
5. Groundwater infiltration to storm drains;
6. Uncontaminated pumped groundwater;
7. Water from foundation or footing drains;
8. Water from crawl space pumps;
9. Air conditioning condensation;
10. Springs;
11. Natural riparian habitat or wetland flows;
12. Swimming pools (if de-chlorinated - typically less than one PPM chlorine);
13. Firefighting activities;
14. Any other uncontaminated water source;
15. Discharges specified in writing by the City Engineer as being necessary to protect public health and safety; or
16. Dye testing is an allowable discharge if authorized by the City Engineer.
17. Uncontaminated groundwater infiltration
18. Individual residential car washing
19. Dechlorinated water reservoir discharges
20. Residual street wash water

The prohibition shall not apply to any non-stormwater discharge permitted under an UPDES permit, waiver, or waste discharge order issued to the discharger and administered under the authority of the State of Utah Division of Water Quality, provided that the discharger is in full compliance with all requirements of the permit, waiver, or order and other applicable laws and regulations, and provided that written approval has been granted for any discharge to the MS4.