



## State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON  
Lieutenant Governor

## Department of Environmental Quality

Tim Davis  
Executive Director

DIVISION OF WATER QUALITY  
John K. Mackey, P.E.  
Director

**May 7, 2025**

### DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE TO RENEW A UPDES PERMIT

#### **PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET.

#### **PERMIT INFORMATION**

PERMITTEE NAME:	Lake Point Improvement District
FACILITY NAME:	Lake Point Improvement District Lagoons
MAILING ADDRESS:	7856 North Mountain View Road, Lake Point, Utah 84074
TELEPHONE NUMBER:	(435) 255-2099
FACILITY LOCATION:	7851 North Highway 36
UPDES PERMIT NO.:	UT0020231
PERMITTED OUTFALLS:	001
OUTFALL LOCATION:	Latitude 40°40'27.50" and longitude 112°17'6.03"
RECEIVING WATER:	Unnamed ditch

#### **BACKGROUND**

Lake Point Improvement District serves the community of Lake Point with a population of 3,000. The Facility is a facultative lagoon system with a 9-acre primary cell and a 7.4-acre secondary cell. A 5-acre third cell was added in 1987 for polishing the effluent. Disinfection is accomplished with chlorination by using chlorine tablets with dosage adjustments based on flow. The design capacity is 0.392 million gallons a day (MGD); over the last five years, the annual average flow rate was 0.307 MGD. Since 1972, the Facility's effluent flows into an unnamed ditch and then enters what appears to be an old industrial canal. As the water flows through the ditch and canal, some of the water infiltrates into the soil. At the end of the canal, the water exits the dike and flows onto a flat playa-like area where the rest of the water dissipates into the soil. See the Permit and Fact Sheet for more information.

#### **PUBLIC COMMENTS**

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12.

Page 2  
Public Notice

Public comments are invited any time prior to the deadline of the close of business on **May 7<sup>th</sup>, 2025**. Written public comments can be submitted to: Lindsay Cowles, UPDES Individual Permits Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [lcowles@utah.gov](mailto:lcowles@utah.gov).

After considering public comments, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under "Public Participation" at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/). If internet access is not available, a copy may be obtained by calling Lindsay Cowles at (385) 414-0311.

DWQ-2025-003648