

Official Draft Public Notice Version **January 16<sup>th</sup>, 2026**

The findings, determinations, and assertions contained in this document are not final and subject to change following the public comment period.

**FACT SHEET**  
**SPRINGDALE WASTEWATER LAGOONS**  
**PERMIT MODIFICATION: DISCHARGE**  
**UPDES PERMIT NUMBER: UT0025224**  
**MINOR MUNICIPAL**

**FACILITY CONTACTS**

Operator Name: Town of Springdale  
Person Name: Barbara Bruno  
Position: Mayor

Person Name: Rick Wixom  
Position: City Manager

Person Name: Robert Totten  
Position: Public Works Superintendent  
Phone Number: (435) 243-3686

Facility Name: Springdale Wastewater Lagoons  
Mailing and Facility Address: Springdale City Offices  
PO Box 187  
118 Lion Blvd  
Springdale, Utah 84767

Telephone: (435) 772-6907  
Actual Address: 3300 North 1200 West

**DESCRIPTION OF PERMIT MODIFICATION**

This modification is in response to a letter from the Town of Springdale (DWQ-2025-010179), received on December 12, 2025, requesting a modification of the Compliance Schedule found in Utah Pollutant Discharge Elimination System (UPDES) Permit No. UT0025224 for Lagoon upgrades and total suspended solids (TSS) interim Permit limitations. Due to the Permittee's continued efforts to come into compliance, the Division of Water Quality approves this request. The modified Compliance Schedule and interim Permit limits are provided below and are also reflected in Part I.C.3.a. of UPDES Permit No. UT0025224. Any violation of the Compliance Schedule is a violation of the UPDES Permit.

**Compliance Schedule Milestones:**

<b>Lagoon Upgrade</b>	
<b>Date</b>	<b>Milestone</b>
May 1, 2026	Provide DWQ with an update on treatment solution and bench testing for the reduction of TSS.
December 1, 2026	Final Treatment Solution Complete.
January 1, 2027	Final Effluent Limitations in Effect.

**Compliance Schedule TSS:**

<b>TSS</b>			
<b>Date</b>	<b>TSS Max. Monthly Average</b>	<b>TSS Max. Weekly Average</b>	<b>TSS Min. % Removal</b>
Permit Issue – December 31, 2026	70 mg/L	70 mg/L	No limitation
January 1, 2027	45 mg/L	65 mg/L	85%

**PERMIT DURATION**

It is recommended that this Permit modification be effective through the current Permit expiration date, April 30, 2029.

Drafted by  
Lindsay Cowles, Environmental Scientist

**PUBLIC NOTICE**

Began: xxxxx

Ended: xxxxx

Comments will be received at: 195 North 1950 West  
PO Box 144870  
Salt Lake City, UT 84114-4870

During the public comment period provided under R317-8-6.5, any interested person may submit written comments on the draft Permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in R317-8-6.12.

**ADDENDUM TO FSSOB**

During finalization of the Permit certain dates, spelling edits and minor language corrections were completed. Due to the nature of these changes they were not considered Major and the permit is not required to be re Public Noticed.

**Responsiveness Summary**

No comments were received during the public comment period.