

# LAKE POINT IMPROVEMENT DISTRICT

WASTEWATER LAGOON NO. 1  
AERATION EXPANSION

DESIGN STUDY REPORT

DRAFT April 2026



**WARD ENGINEERING GROUP**  
Planning • Engineering • Surveying





7856 N MOUNTAIN VIEW RD  
LAKE POINT UT 84074  
PHONE: 801-520-0053

# LAKE POINT IMPROVEMENT DISTRICT

DESIGN STUDY REPORT

WASTEWATER LAGOON NO. 1 –  
AERATION EXPANSION

DRAFT APRIL 2026



**DESIGN STUDY REPORT  
WASTEWATER LAGOON NO. 1 – AERATION EXPANSION  
LAKE POINT IMPROVEMENT DISTRICT**

**CONTENTS**

|                                                       |    |
|-------------------------------------------------------|----|
| Introduction .....                                    | 1  |
| Background .....                                      | 1  |
| Service Area.....                                     | 1  |
| Objectives .....                                      | 1  |
| Existing Conditions .....                             | 2  |
| Past Studies and Applicable Documents.....            | 2  |
| Regional Trends in Growth and Population.....         | 2  |
| Projected Local Growth and Population.....            | 3  |
| Existing Wastewater Treatment System .....            | 5  |
| Facultative Lagoon – Area, Depth, and Site Plan ..... | 7  |
| Existing Biological Treatment Capacity .....          | 8  |
| Existing Hydraulic Capacity .....                     | 10 |
| Proposed Conditions .....                             | 10 |
| Basis of Aeration Expansion .....                     | 10 |
| Design Period .....                                   | 10 |
| Proposed Levels of Service.....                       | 11 |
| Potential for Phasing .....                           | 14 |
| Manufacture and Supplier's Technical Data .....       | 14 |

**APPENDICES**

|                                                        |                                                                                                 |
|--------------------------------------------------------|-------------------------------------------------------------------------------------------------|
| Appendix A .....                                       | Service Area                                                                                    |
| • Figure 3: Service Area                               |                                                                                                 |
| • Figure 4: Regional Service Areas                     |                                                                                                 |
| Appendix B .....                                       | Product Information                                                                             |
| • Newterra Budgetary Proposal Submittal 5-6-2026       |                                                                                                 |
| Appendix C .....                                       | Newterra Supporting Calculations and Conformance to the<br>Stipulated Minimum Levels of Service |
| • Calculations and Manufacture's Worksheets            |                                                                                                 |
| Appendix D .....                                       | 2004 Design Study Report (DSR)                                                                  |
| • Report Prepared by Ward Engineering Group for Cell 1 |                                                                                                 |
| Appendix E .....                                       | Historical Flow and Sampling Data                                                               |
| • Raw Data Sheets                                      |                                                                                                 |

# DESIGN STUDY REPORT WASTEWATER LAGOON NO. 1 - AERATION EXPANSION LAKE POINT IMPROVEMENT DISTRICT

## INTRODUCTION

### BACKGROUND

Lake Point Improvement District (LPID) was formed in 1972, with construction of its initial facultative sewer lagoons by Exxon Mobile, serving the commercial area at Exit 99 off Interstate 80. Today, LPID has expanded its sewer treatment system, adding hydraulic capacity, aeration, pumping capacity, and disinfection, on approximately 26 acres of property owned by LPID.

LPID provides both sewer collection and treatment of domestic wastewater to a mix of customers, including more than 650 residential accounts, and 16 commercial, institutional, and light industrial accounts, contained within its service area comprising 3,967 acres.

### SERVICE AREA

LPID is primarily located within the corporate boundary of Lake Point City, situated at the north end of Tooele County, south of Interstate 80, lying both west and east of SR-36. Two exhibits depicting the location and extents of LPID's service area are shown in Figures 3 and 3 of Appendix A.

## OBJECTIVES

In 2004, a Design Study Report (DSR) was prepared by Ward Engineering Group, addressing options to expand the biological treatment capacity of the district's existing three facultative lagoons. Refer to Appendix D. LPID acted on the recommendation to install a number of aspirating aerators within its existing primary Treatment Lagoon (Cell No. 1). Six aerators were subsequently installed and are currently in operation. At the time the 2004 DSR was prepared, considerations were made for future expansion, and calculations were made for the eventual installation of up to 24 "like" aeration units.

Since 2004, LPID has experienced both residential, commercial, and light industrial growth. Likewise, the district anticipates ongoing and future growth. As a result, LPID seeks to increase its biological treatment capacity by acting on the 2004 recommendations, to add additional aerator units to its Cell No. 1, as originally planned. The objectives of this 2026 DSR are:

- 1) to provide an update to the growth projections, and calculate revised design flows,
- 2) collect and report wastewater constituent loading necessary to confirm and revise the sizing and number of aerator units required for the design period,
- 3) coordinate with the product manufacture of the selected aerator units, and obtain performance criteria, and treatment capacities, and incorporate such information as part of the DSR, and
- 4) provide sufficient information to the Division of Water Quality in order to proceed with the design, permitting, and installation of said aerators.





## EXISTING CONDITIONS

### PAST STUDIES AND APPLICABLE DOCUMENTS

The following documents were prepared for LPID, and were instrumental in the evaluation and preparation of this DSR. A brief summation of each is provided, detailing relevance to this report.

*2004 Lagoon Aerators – Cell No. 1 Design Study Report:* This report was described in the objectives sections, and is the basis for the biological treatment expansion proposed in this DSR.

*Adopted 2018 Sewer Master Plan:* This report provided updated growth modeling for both sewer collection and treatment services within the current boundary of LPID. This report provided further finding with respect to LPID's unit of flow (i.e., GPD/ERU), including measured inflow and infiltration (I/I); which together, serves as the basis for this DSR. This report is not included in this DSR.

*Adopted 2020 Impact Fee Facilities Plan (IFFP):* This report adds upon the 2018 Sewer Master Plan by establishing capital improvement projects recommended in the master plan, which have been funded by impact fee revenue. The aeration expansion project proposed by the DSR is programmed in the 2020 IFFP, and it is the intent of the district to fund the project entirely with reserved impact fees. Currently, the district is required to spend its impact fee reserves this year. As such, this expansion project schedule is time sensitive. The IFFP is not included in this DSR.


*Adopted 2020 Sewer Impact Fee Analysis:* This report was independently prepared in conjunction with the afore described IFFP, and established the recommendation for the maximum allowed impact fee, for which the district has collected impact fee revenue to fund the aeration project at hand. This report is not included in this DSR.

### REGIONAL TRENDS IN GROWTH AND POPULATION

| TOOELE COUNTY                |            |            |
|------------------------------|------------|------------|
| Year                         | Population | Growth (%) |
| 2003                         | 46700      |            |
| 2004                         | 47900      | 2.6%       |
| 2005                         | 49300      | 2.9%       |
| 2006                         | 51500      | 4.5%       |
| 2007                         | 53800      | 4.5%       |
| 2008                         | 55900      | 3.9%       |
| 2009                         | 57200      | 2.3%       |
| 2010                         | 58,218     | 1.8%       |
| 2011                         | 59,190     | 1.7%       |
| 2012                         | 59,792     | 1.0%       |
| 2013                         | 60,633     | 1.4%       |
| 2014                         | 61,442     | 1.3%       |
| 2015                         | 62,639     | 1.9%       |
| 2016                         | 64,612     | 3.1%       |
| 2017                         | 67,486     | 4.4%       |
| 2018                         | 69,989     | 3.7%       |
| 2019                         | 72,259     | 3.2%       |
| 2020                         | 74,500     | 3.1%       |
| 2021                         | 76,600     | 2.8%       |
| 2022                         | 80,000     | 4.4%       |
| 2023                         | 82,100     | 2.6%       |
| 2024                         | 84,488     | 2.9%       |
| 20-Year Average Growth       |            | 2.9%       |
| Last 10-Year Average Growth  |            | 3.2%       |
| First 10-Year Average Growth |            | 2.5%       |

Data was collected from the U.S. Census Bureau for Tooele County, 2003 through 2024. A summary table of the historic growth within Tooele County at large shows that the past 20-year period yielded a 2.9% growth rate. The last 10 years shows a slightly greater rate of 3.2%. These historic trends can be compared to the growth projections with LPID, which is situated within North Tooele County.



Regional Historic Growth Trend



## PROJECTED LOCAL GROWTH AND POPULATION

| LPID Service Area    |       |            |                  |                                         |                           |
|----------------------|-------|------------|------------------|-----------------------------------------|---------------------------|
| Year                 | ERUs  | Growth (%) | Total Flow (MGD) | Baseline I/I Flow As of Year 2017 (MGD) | Total Flow Less I/I (MGD) |
| 2017                 | 567   | -          | 0.26             | 0.034                                   | 0.222                     |
| 2018                 | 604   | 6.6%       | 0.27             | 0.034                                   | 0.235                     |
| 2019                 | 644   | 6.6%       | 0.28             | 0.034                                   | 0.248                     |
| 2020                 | 687   | 6.6%       | 0.30             | 0.034                                   | 0.263                     |
| 2021                 | 732   | 6.6%       | 0.31             | 0.034                                   | 0.279                     |
| 2022                 | 780   | 6.6%       | 0.33             | 0.034                                   | 0.296                     |
| 2023                 | 832   | 6.6%       | 0.35             | 0.034                                   | 0.313                     |
| 2024                 | 887   | 6.6%       | 0.37             | 0.034                                   | 0.332                     |
| 2025                 | 945   | 6.6%       | 0.39             | 0.034                                   | 0.353                     |
| 2026                 | 993   | 5.0%       | 0.40             | 0.034                                   | 0.369                     |
| 2027                 | 1,039 | 4.7%       | 0.42             | 0.034                                   | 0.385                     |
| 2028                 | 1,085 | 4.4%       | 0.43             | 0.034                                   | 0.401                     |
| 2029                 | 1,130 | 4.1%       | 0.45             | 0.034                                   | 0.416                     |
| 2030                 | 1,173 | 3.8%       | 0.47             | 0.034                                   | 0.431                     |
| 2031                 | 1,214 | 3.5%       | 0.48             | 0.034                                   | 0.445                     |
| 2032                 | 1,252 | 3.2%       | 0.49             | 0.034                                   | 0.459                     |
| 2033                 | 1,289 | 2.9%       | 0.51             | 0.034                                   | 0.471                     |
| 2034                 | 1,321 | 2.5%       | 0.52             | 0.034                                   | 0.483                     |
| 2035                 | 1,354 | 2.5%       | 0.53             | 0.034                                   | 0.494                     |
| 2036                 | 1,388 | 2.5%       | 0.54             | 0.034                                   | 0.506                     |
| 2037                 | 1,423 | 2.5%       | 0.55             | 0.034                                   | 0.518                     |
| 2038                 | 1,458 | 2.5%       | 0.56             | 0.034                                   | 0.530                     |
| 2039                 | 1,495 | 2.5%       | 0.58             | 0.034                                   | 0.543                     |
| 2040                 | 1,532 | 2.5%       | 0.59             | 0.034                                   | 0.556                     |
| 2041                 | 1,570 | 2.5%       | 0.60             | 0.034                                   | 0.569                     |
| 2042                 | 1,609 | 2.5%       | 0.62             | 0.034                                   | 0.582                     |
| 2043                 | 1,650 | 2.5%       | 0.63             | 0.034                                   | 0.596                     |
| 2044                 | 1,691 | 2.5%       | 0.64             | 0.034                                   | 0.611                     |
| 2045                 | 1,733 | 2.5%       | 0.66             | 0.034                                   | 0.625                     |
| 2046                 | 1,777 | 2.5%       | 0.67             | 0.034                                   | 0.640                     |
| 2047                 | 1,812 | 2.0%       | 0.69             | 0.034                                   | 0.653                     |
| 2048                 | 1,848 | 2.0%       | 0.70             | 0.034                                   | 0.665                     |
| 2049                 | 1,885 | 2.0%       | 0.71             | 0.034                                   | 0.678                     |
| 2050                 | 1,923 | 2.0%       | 0.72             | 0.034                                   | 0.691                     |
| 2051                 | 1,961 | 2.0%       | 0.74             | 0.034                                   | 0.704                     |
| 2052                 | 2,001 | 2.0%       | 0.75             | 0.034                                   | 0.718                     |
| 2053                 | 2,041 | 2.0%       | 0.77             | 0.034                                   | 0.732                     |
| 2054                 | 2,081 | 2.0%       | 0.78             | 0.034                                   | 0.746                     |
| 2055                 | 2,123 | 2.0%       | 0.79             | 0.034                                   | 0.760                     |
| 2056                 | 2,166 | 2.0%       | 0.81             | 0.034                                   | 0.775                     |
| 2057                 | 2,209 | 2.0%       | 0.82             | 0.034                                   | 0.790                     |
| 2058                 | 2,253 | 2.0%       | 0.84             | 0.034                                   | 0.805                     |
| 20-Year Average      |       | 3.0%       |                  |                                         |                           |
| Next 10-Year Average |       | 3.4%       |                  |                                         |                           |







From 2018 to 2025 it is calculated that LPID has grown at an average rate of approximately 6.6 percent, a little more than twice the average Tooele County rate. Over the next ten-year period, it is anticipated that the district's growth rate will diminish over time falling more in line with the County's overall growth trend, at 2.5% by 2034.


A tabulation and graphical representation of LPID's projected growth are depicted in the preceding table and charts, and are expressed in terms of both flow rate and equivalent residential units (ERUs). From the 2018 Sewer Master Plan, an estimation of baseline I/I was made, in order to more accurately project growth in terms of influent flow per ERU. Additional information is provided in regards to I/I in a subsequent section of this report. A summary of project growth is provided below.


#### Summary of Growth Projections

| Year | Total Influent Flow (MGD) | Basine I/I (MGD) | ERUs  |
|------|---------------------------|------------------|-------|
| 2026 | 0.40                      | 0.034            | 993   |
| 2036 | 0.54                      | 0.034            | 1,388 |
| 2046 | 0.67                      | 0.034            | 1,777 |
| 2051 | 0.74                      | 0.034            | 1,961 |

#### EXISTING WASTEWATER TREATMENT SYSTEM

*Domestic Wastewater Generation:* The following two charts graphically depict the average daily flow and the maximum daily flow based on the measured influent flow rates collected by the District Manager, from 2014 through 2025.






As mathematically derived from the trendline of the historical average influent flow chart, the average influent flow at the end of 2025 was 0.39 million gallons per day. This was used as the benchmark for the growth projections provided on page 3.

As also mathematically derived from the upper trendline of the historical maximum influent flow chart, the peak flow at the end of 2025 was shown to be 0.83 MGD. Therefore, the maximum peak factor would be 2.1. Refer to Appendix E for reference to a complete set of flow data.

*Unit of Demand:* It is typical for a sewer district to define a unit of demand as an Equivalent Residential Unit, or ERU. LPID conforms to this conventional approach. The unit flow criteria used for master planning in the DSR is therefore, 346 gallons per day average demand per ERU (2018 Sewer Master Plan, pg. 18), with 3.23 capita per ERU. This excludes I/I as previously indicated. All commercial, institutional, and industrial land uses are converted to ERUs for uniformity and simplification in calculating and reporting user demands and levels of service.

*Inflow & Infiltration (I/I):* is an important consideration for LPID. During a five-month period at the latter half of 2017, an I/I study was conducted (2018 Sewer Master Plan, pg. 8). It was determined that 60 gallons per day per ERU was attributed to I/I, or 34,000 gallons per day. Furthermore, most of the I/I was observed to originate from the older portion of the sewer collection system, referred to as the Core Area. This was established through additional flow analysis described in the master plan, page 6. As a result, I/I is considered to be a perpetual flow that must be conveyed through the system until such time that the district takes action to reduce the known I/I through pipe lining and manhole rehabilitation. For growth modeling purposes, I/I within the existing Core Area is treated as a constant, which is part of the total measured influent flow. However, it is separated apart from the total flow in order to more accurately calculate future ERU projections.

# FACULTATIVE LAGOON – AREA, DEPTH, AND SITE PLAN





As illustrated in Figure 1, LPID's treatment system comprises three lagoon cells, for a total estimated surface area of 19 acres, at an average depth of six feet. The district operates the cells in series, with cell 1 as the only aerated portion of the treatment system, having six existing 7.5 horsepower aspirating surface aerator units.

### EXISTING BIOLOGICAL TREATMENT CAPACITY

From the 2004 DSR (Appendix D), the manufacture of the district's existing Aeromix aerators, provided performance criteria for the calculation of oxygen requirements, and associated power requirements to provide capacity to treat the BOD loading of the district. Based on the manufacture's performance criteria, together with a standard BOD loading rate of 250 mg/l, calculations have been made to determine the status of the existing biological capacity based on the existing six aerator units now in operation in cell 1.

#### **Existing Biological Treatment Capacity Calculations**

**From 2004 DSR - Manufacture's (Aeromix) unit performance criteria, page 1 and 2**

##### Design Criteria

---

|                   |      |      |
|-------------------|------|------|
| USER ENTER FLOW = | 0.22 | MGD  |
| BOD demand =      | 250  | mg/l |
| TKN Demand =      | 0    | mg/l |
| TSS =             | 0    | mg/l |

##### Calculations for Oxygen Requirements

---

Apply 2 lbs of oxygen per lb of BOD and 4.6 lbs of oxygen per lbs TKN.  
2 mg/l residual oxygen is required at all times.

|                         |       |              |
|-------------------------|-------|--------------|
| BOD Demand =            | 458.7 | lbs / day    |
| BOD Oxygen Required =   | 917.4 | lbs O2 / day |
| TKN Oxygen Required =   | 0     | lbs O2 / day |
| Total Oxygen Required = | 917.4 | lbs O2 / day |

|         |        |                                                            |
|---------|--------|------------------------------------------------------------|
| No. =   | 1755.7 | lbs / day of Standard Total Oxygen Requirement             |
| N =     | 917.4  | lbs / day of Total Oxygen Requirement                      |
| Beta =  | 0.95   | Salinity, surface tension factor per manufacture           |
| Cwalt = | 7.9    | Saturation at given altitude & temperature per manufacture |
| Cl =    | 2      | mg/l Residual oxygen required by DWQ                       |
| Alpha = | 0.85   | Oxygen transfer correction factor per manufacture          |
| T =     | 20     | deg C Operating temperature (68 deg F) per manufacture     |

##### Calculations for Power

---

At standard conditions, units transfer up to 2.5 lbs/HP. However, use an oxygen transfer rate of 1.65 O2 / HP per hour, with 24-hour operation

|                  |      |                    |
|------------------|------|--------------------|
| Required Power = | 44.3 | HP                 |
| Number of Units  | 5.9  | at 7.5 HP per unit |



The following calculations are provided to determine the requirements for aeration for the existing treatment plant, based on the measured existing average influent flow of 0.39 MGD, and 933 ERUs.

### Existing Biological Treatment Requirement Calculations

From 2004 DSR - Manufacture's (Aeromix) unit performance criteria, page 1 and 2

#### Design Criteria

|                   |      |      |
|-------------------|------|------|
| USER ENTER FLOW = | 0.39 | MGD  |
| BOD demand =      | 250  | mg/l |
| TKN Demand =      | 0    | mg/l |
| TSS =             | 0    | mg/l |

#### Calculations for Oxygen Requirements

Apply 2 lbs of oxygen per lb of BOD and 4.6 lbs of oxygen per lbs TKN.  
2 mg/l residual oxygen is required at all times.

|                         |        |                          |
|-------------------------|--------|--------------------------|
| BOD Demand =            | 813.2  | lbs / day                |
| BOD Oxygen Required =   | 1626.3 | lbs O <sub>2</sub> / day |
| TKN Oxygen Required =   | 0      | lbs O <sub>2</sub> / day |
| Total Oxygen Required = | 1626.3 | lbs O <sub>2</sub> / day |

|                     |        |                                                            |
|---------------------|--------|------------------------------------------------------------|
| No. =               | 3112.4 | lbs / day of Standard Total Oxygen Requirement             |
| N =                 | 1626.3 | lbs / day of Total Oxygen Requirement                      |
| Beta =              | 0.95   | Salinity, surface tension factor per manufacture           |
| C <sub>walt</sub> = | 7.9    | Saturation at given altitude & temperature per manufacture |
| Cl =                | 2      | mg/l Residual oxygen required by DWQ                       |
| Alpha =             | 0.85   | Oxygen transfer correction factor per manufacture          |
| T =                 | 20     | deg C Operating temperature (68 deg F) per manufacture     |

#### Calculations for Power

At standard conditions, units transfer up to 2.5 lbs/HP. However, use an oxygen transfer rate of 1.65 O<sub>2</sub> / HP per hour, with 24-hour operation

|                  |      |                    |
|------------------|------|--------------------|
| Required Power = | 78.6 | HP                 |
| Number of Units  | 10.5 | at 7.5 HP per unit |

Based on the preceding two sets of calculations and stated BOD loading, the existing system has a capacity to treat 0.22 million gallons per day as summarized in the following table. It is noted that the treatment capacity should be brought up to the existing demands of 0.39 MGD, requiring a total of 11 aerator units.

#### Summary of Existing Biological Treatment Capacity

| Year Ending | Existing Number of Aerator Units | Capacity (MGD) | Capacity (ERUs) | Needed Number of Aerator Units | Existing Flow (MGD) | Existing Users (ERUs) |
|-------------|----------------------------------|----------------|-----------------|--------------------------------|---------------------|-----------------------|
| 2025        | 6                                | 0.22           | 635             | 11                             | 0.39                | 993                   |



## EXISTING HYDRAULIC CAPACITY

The volume of the existing three treatment cells has been estimated based on the surface area take-offs shown on Figure 1, applying an average depth of six feet, with a 3:1 slope at the banks. The resulting total volume of the treatment plant is 186,396 cubic yards (34,011,618 gallons). As required by UAC R317-3-10.F.2, the required hydraulic retention time (HRT) is 30 days.

The following table summarizes the existing HRT.

### Summary of HRT

| Year Ending | Total Volume (MG) | Influent Average Flow (MGD) | HRT (Days) |
|-------------|-------------------|-----------------------------|------------|
| 2025        | 34.01             | 0.39                        | 87.2       |

## PROPOSED CONDITIONS

### BASIS OF AERATION EXPANSION

*Consideration of Aeration Alternatives:* The district evaluated multiple alternatives for its aeration system in 2004, as part of the DSR previously sited; including diffused air, high-speed surface aerators, and aspirating aerators. LPID selected the recommended aspirating-type aerators, consisting of single 7.5 HP units as explained in more detail in the DSR provided for reference in Appendix D.

*Product Selection:* At the time of the original installation of the 7.5 HP units, provisions were recommended, and made effective, to expand the biological treatment capacity by installing additional 7.5 HP units at the recommended locations to achieve proper zone coverage and depth, according to the manufacture's oxygen profiles. This would allow for the district to continue utilizing the existing aerators, in conjunction with the integration of the recommended "like" units. For these reasons, LPID has selected similar 7.5 aspirating aerator units manufactured by Newterra, for its aeration expansion project.

*Project Previously Programmed:* As indicated, this proposed aeration expansion project was programmed for construction in the district's 2018 Impact Fee Facilities Plan (IFFP), and the district has collected sufficient revenue to fund this specific project. Furthermore, the district is under obligation to expend said impact fees within a statutory time period, which expires on December 31, 2026. Therefore, the district is working within an expeditious time frame to complete this project. It is also noted that this DSR is written specifically for the aeration expansion project. Other unit processes are not intended to be a part of the analysis provided in this DSR.

### DESIGN PERIOD

The design period contemplated with this DSR is a minimum of twenty (20) years. The minimum number of aeration units needed for expansion are on this basis.





## PROPOSED LEVELS OF SERVICE

*Unit of Demand:* As established in the analysis of the existing conditions, 346 gallons per day average demand per ERU, with 3.23 capita per ERU is used to establish the unit demand for the proposed aeration expansion project. I/I, as previously indicated is factored in to the total flow projections as a baseline, perpetual flow. For purposes of projecting influent flow, no distinction of land use types are included in this scope of analysis. Notwithstanding, all land use-wastewater generation is considered “domestic” wastewater.


*Regulatory Aeration Requirements (UAC R317-4 & R317-3-10):* The following parameters are made effective in the calculations for the expansion of aeration capacity.

- BOD Loading is 200 mg/l.
- Design based on 2.0 pounds of oxygen input per pound of BOD<sub>5</sub>.
- Aeration equipment must be capable of maintaining 2 mg/l in the lagoon at all times.
- Circle of Influence: that area in which return velocity is greater than 0.15 feet per second as indicated by the manufacture’s certified data.
- Suitable protection from weather shall be provided for equipment and electrical controls.

### *Historical Influent BOD:*

The District Manager has collected historic annual average and maximum day influent BOD concentrations from 2014 through 2025.

| Year | Average Influent BOD (mg/l) | Maximum Influent BOD (mg/l) |
|------|-----------------------------|-----------------------------|
| 2014 | 139                         | 197                         |
| 2015 | 143                         | 195                         |
| 2016 | 162                         | 243                         |
| 2017 | 185                         | 290                         |
| 2018 | 203                         | 331                         |
| 2019 | 158                         | 463                         |
| 2020 | 184                         | 287                         |
| 2021 | 182                         | 231                         |
| 2022 | 155                         | 227                         |
| 2023 | 180                         | 314                         |
| 2024 | 178                         | 378                         |
| 2025 | 177                         | 309                         |



As shown, the historic average annual influent concentrations year over year have not exceeded 200 mg/l. Therefore, the design BOD loading meets the requirement of UAC R317-4, and is the level of service for which the aeration expansion project will be designed. It is noted that the previous 2004 DSR used 250 mg/l. However, based on historic data, the treatment plant clearly operates at average concentrations at or below 200 mg/l, while yearly peak day concentrations do exceed that. Appendix E provides a more expanded set of data for reference. It is noted that I/I is inclusive of the measured BOD concentrations. In the future, additional measurements may be warranted as the district mitigates or removes the stated baseline I/I from the influent flow, which may result in slightly higher BOD concentrations.



Biological Treatment Capacity (BOD): Based on the 20-year design period, the following calculations are provided as an estimate for the minimum number of 7.5 HP aerator units that will be required, with an option to expand to the full extent of the system's capability, which is 24 aerator units within cell 1, as planned for in the 2004 DSR.

#### Summary of Proposed Biological Treatment Capacity

| Year Ending | Proposed Minimum Number of Aerator Units | Capacity (MGD) | Capacity (ERUs) | Optional Number of Aerator Units | Future Flow (MGD) | Future Users (ERUs) |
|-------------|------------------------------------------|----------------|-----------------|----------------------------------|-------------------|---------------------|
| 2046        | 15                                       | 0.67           | 1,777           | 24                               | 1.11              | 3,032               |

Note: results based on inclusion of I/I and BOD loading = 200 mg/l.

Figure 2 from the 2004 DSR is provided to show the ultimate location and configuration of the master planned, 24 aerator units in cell 1. It is for conceptual purposes only, and does not necessarily represent the final locations that may be designed, and may not reflect the most current cell data.

#### Proposed Biological Treatment Requirement Calculations

From 2004 DSR - Manufacture's (Aeromix) unit performance criteria, page 1 and 2

##### Design Criteria

|                   |      |      |
|-------------------|------|------|
| USER ENTER FLOW = | 0.67 | MGD  |
| BOD demand =      | 200  | mg/l |
| TKN Demand =      | 0    | mg/l |
| TSS =             | 0    | mg/l |

##### Calculations for Oxygen Requirements

Apply 2 lbs of oxygen per lb of BOD and 4.6 lbs of oxygen per lbs TKN.

2 mg/l residual oxygen is required at all times.

|                         |         |                          |
|-------------------------|---------|--------------------------|
| BOD Demand =            | 1117.6  | lbs / day                |
| BOD Oxygen Required =   | 2235.12 | lbs O <sub>2</sub> / day |
| TKN Oxygen Required =   | 0       | lbs O <sub>2</sub> / day |
| Total Oxygen Required = | 2235.12 | lbs O <sub>2</sub> / day |


|                     |         |                                                            |
|---------------------|---------|------------------------------------------------------------|
| No. =               | 4277.5  | lbs / day of Standard Total Oxygen Requirement             |
| N =                 | 2235.12 | lbs / day of Total Oxygen Requirement                      |
| Beta =              | 0.95    | Salinity, surface tension factor per manufacture           |
| C <sub>walt</sub> = | 7.9     | Saturation at given altitude & temperature per manufacture |
| Cl =                | 2       | mg/l Residual oxygen required by DWQ                       |
| Alpha =             | 0.85    | Oxygen transfer correction factor per manufacture          |
| T =                 | 20      | deg C Operating temperature (68 deg F) per manufacture     |

##### Calculations for Power

At standard conditions, units transfer up to 2.5 lbs/HP. However, use an oxygen transfer rate of 1.65 O<sub>2</sub> / HP per hour, with 24-hour operation

|                  |       |                    |
|------------------|-------|--------------------|
| Required Power = | 108.0 | HP                 |
| Number of Units  | 14.4  | at 7.5 HP per unit |







*Hydraulic Capacity (HRT):* By applying the physical parameters previously described under existing conditions, the HRT of the system at the end of the 20-year design period, 2046, is summarized in the table below.

#### Summary of HRT

| Year Ending | Total Volume (MG) | Influent Average Flow (MGD) | HRT (Days) |
|-------------|-------------------|-----------------------------|------------|
| 2046        | 34.01             | 0.67                        | 50.8       |

*Other Levels of Service:* The treatment plant is, and will be, designed to accept domestic wastewater from residential, commercial, industrial, or similar sources that result primarily from human sanitary uses; and excludes industrial processes, or wastewater in large peak volumes, any stormwater whatsoever, and any excessive ground water resulting from new collection system infiltration (except as previously defined as “baseline” I/I), and illegal storm drain or ground water sump discharge. All customers are required to install pretreatment facilities (prior to any connection to LPID’s sewer collection system), if a potential exists during the plan review and permitting process, or if measured or observed in the field; for the generation of wastewaters containing pollutants such as: high organic concentrations, toxic substances, metals, or pH extremes), or any other organic or inorganic constituent that is deemed by LPID to adversely or disproportionally impact LPID’s discharge limits established by the Utah Department of Environmental Quality, Division of Water Quality (DWQ).

Other levels of service may apply to other unit processes of LPID’s treatment system. However, such other levels of service are beyond the scope of service pertaining to this specific project.

#### POTENTIAL FOR PHASING

As proposed in the summary table of proposed biological treatment capacity, the minimum proposed number of total aerator units for the 20-year design period is 15, including the existing 6 units in operation today. The current system is programmed for the ultimate installation and operation of 24 total units, including the existing 6 units in operation.

As determined by the Board of Trustees, according to impact fee revenue stored for aeration expansion, LPID may determine that it will install a minimum of 9 additional units (15 total), or up to 18 additional units (24 total). A final determination may be made upon receiving bids for the aeration expansion project.

#### MANUFACTURE AND SUPPLIER’S TECHNICAL DATA


*Aeration Industries International (Newterra):* LPID has engaged Newterra with the intent to specify its aspirating 7.5 HP surface mounted TORNADO aerator and mixer units, which are similar in operation and performance to the existing Aeromix TORNADO units now in operation. Refer to Appendix B for Newterra’s product information.

*Calculations and Technical Worksheets:* Supporting calculations and conformance to the stipulated minimum levels of service, for the proposed 7.5 HP TORDADO units are provided by Newterra in Appendix C.



## APPENDIX A: SERVICE AREA

- Figure 3: Service Area
- Figure 4: Regional Service Area



TO TOOELE CITY  
(SEE FIGURE 2)

HYPOCHLORITE DISINFECTION SYSTEM

DISCHARGE

PUMP STATION #4

CELL 3

CELL 2

CELL 1


LAKE POINT IMPROVEMENT  
DISTRICT SERVICE AREA

SR-36


REGIONAL PUMP STATION

PUMP STATION #1

TO I-80







LEGEND

- SATNSBURY PARK IMPROVEMENT DISTRICT SERVICE AREA
- OQUIRRH POINT IMPROVEMENT DISTRICT SERVICE AREA
- LAKE POINT IMPROVEMENT DISTRICT SEWER AREA

ERDA CITY

SR-138

1200 WEST

EXISTING SEWER TREATMENT

STANSBURY PARK  
IMPROVEMENT DISTRICT  
SERVICE AREA

ERDA ESTATES

TEALBY DEV.

IHC  
(HOSPITAL)

OQUIRRH POINT  
IMPROVEMENT  
DISTRICT  
SERVICE AREA

EAST CHURCH ROAD

SR-36

BRYAN ROAD

MAJESTIC &  
SUNSET ACRES

ERDA CITY MUNICIPAL BOUNDARY

UNINCORPORATED  
TOOELE COUNTY

LAKE POINT IMPROVEMENT DISTRICT  
SERVICE AREA

## APPENDIX B: PRODUCT INFORMATION

- Newterra Budgetary Proposal Submittal 5-6-2026





# Lake Point Improvement District, UT- TORNADO Aerators Surface Mounted Aerators and Mixers Budgetary Proposal QU-2610574.R0

**Submitted To:** Wards Engineering Group

**Attention To:** Colin Reynolds, 801-487-8040 ext.220, creynolds@wardeg.com

**Submitted By:** Newterra Corporation, Inc.  
1555 Coraopolis Heights Rd. Suite 4100  
Coraopolis, PA 15108

**Represented By:** WATERFORD SYSTEMS, Mike Sorensen, 801-463-9900,  
mike.waterford@gmail.com

**Presented By:** Dina Palumbo, 763-746-9271;ext=271, dpalumbo@newterra.com



Submitted 2026-05-06



# Contents

|          |                                           |           |
|----------|-------------------------------------------|-----------|
| <b>1</b> | <b>Introduction &amp; Overview .....</b>  | <b>3</b>  |
|          | About Newterra .....                      | 3         |
|          | Locations .....                           | 4         |
| <b>2</b> | <b>Commercial Section .....</b>           | <b>5</b>  |
|          | Price Breakdown .....                     | 5         |
|          | Freight Pricing .....                     | 5         |
|          | Commercial Notes .....                    | 5         |
|          | Schedule .....                            | 6         |
| <b>3</b> | <b>Technical Section .....</b>            | <b>7</b>  |
|          | Scope of Supply .....                     | 7         |
|          | Scope of Supply by Others .....           | 8         |
| <b>4</b> | <b>Newterra Lifecycle Solutions .....</b> | <b>9</b>  |
| <b>5</b> | <b>Appendices .....</b>                   | <b>10</b> |

# 1 Introduction & Overview

## About Newterra

Newterra's approach is simple: we are a single point contractor combining process design, engineering, fabrication, and long-term life cycle support services to all our customers. We are a leading provider of modular, prefabricated water treatment technologies with a core focus of treating water for three primary purposes:

-  **To drink**
-  **To safely return to the environment or be reused**
-  **For industries to use to produce goods and services**

Operating as Newterra since 1992, and headquartered in Coraopolis, PA, USA, Newterra is an industry leader in modular treatment solutions. Servicing a variety of customers in diverse end-markets including municipalities, land developers, military, commercial & institutional and a variety of light and heavy industries. Providing treatment solutions from 100 gallons per day up to several million gallons per day is within our wheelhouse and driven by the type of treatment solution targeted. Our cross functional team brings outstanding expertise in engineering, treatment applications, manufacturing, and service, leveraging a broad portfolio of technologies. We have dependable (largely modular) designs for ease of installation and operation. We employ a flexible business model to address your needs from capital equipment to rental units (water as a service) and full lifecycle support. Newterra provides real solutions to the world's most demanding industrial end-users, including Mining, Oil & Gas and food and beverage, as well as potable and wastewater solutions for Private and Commercial Developments, and Municipalities.

With over 200+ employees worldwide, delivering 100's of systems annually Newterra is more than just an equipment and solutions provider. Newterra forms a long-term partnership with all our customers, providing long-term Life Cycle support and site services. We understand operating a water or wastewater treatment system can be challenging. Oftentimes, the purchaser of the system, and even the operator of the system, cannot maintain the same level of expertise as the original system designer. Newterra is dedicated to the ongoing success of all its clients, and so we offer our engineering and technical capabilities as an ongoing service.

What differentiates Newterra from our competition is:

- 1) **Client Relationships** – Our fundamental belief is that knowing our clients and understanding their needs, desires and challenges is the only way to foster and maintain long-lasting relationships where both parties reap the benefits.
- 2) **Flexibility** – Newterra understands that not all clients or projects are the same and therefore offer the ability to design the level of systems that is appropriate for your specific project needs.
- 3) **Stature** – Newterra is a right sized company to provide a hands-on approach to every project. One of Newterra's greatest strengths is the ability to make decisions quickly and effectively. Our clients appreciate the speed of service and our level of attentiveness, especially in moments of crisis or emergency.
- 4) **Streamlined In-House Services and Capabilities** – Being an integrated mid-sized equipment and service provider allows Newterra the flexibility to offer a full spectrum of in-house capabilities to best serve and create value for our clients.



## Locations

Newterra is headquartered in Coraopolis, PA, with engineering, fabrication, and field service offices strategically located throughout North America to better service our growing client base.



### **Newterra Corporate Headquarters**

1555 Coraopolis Heights Rd. Suite 4100  
Coraopolis, PA 15108  
USA



### **Systems Manufacturing**

1291 California Ave.  
Brockville, ON K6V 5Y6  
Canada



### **Pressure Vessel Manufacturing**

250 Bolton Sullivan Dr.  
Heber Springs, AR 72543  
USA



### **Surface Aerators & Mixer Manufacturing**

1215 Chaska Creek Blvd., Suite 400  
Chaska, MN 55318  
USA



### **Systems Manufacturing**

1220 Kendall Road  
San Luis Obispo, CA 93401  
USA



## 2 Commercial Section

### Price Breakdown

#### 18 TORNADO Aerators

| Item                                                     | Unit Price   | Qty. | Total Price   |
|----------------------------------------------------------|--------------|------|---------------|
| Kit Tornado 7.5/60 For NEMA Motor 1-3/8" Shaft           | \$ 12,348.00 | 18   | \$ 222,264.00 |
| Motor Techtop7.5/3/208-230/460/50-60 C-face 1800RPM IP55 | Included     | 18   | Included      |
| Kit 2 Float System For Tornado 2-10HP Stainless Steel    | Included     | 18   | Included      |
| Total                                                    |              |      | \$ 222,264.00 |

#### 12 TORNADO Aerators

| Item                                                     | Unit Price   | Qty. | Total Price   |
|----------------------------------------------------------|--------------|------|---------------|
| Kit Tornado 7.5/60 For NEMA Motor 1-3/8" Shaft           | \$ 12,348.00 | 12   | \$ 148,176.00 |
| Motor Techtop7.5/3/208-230/460/50-60 C-face 1800RPM IP55 | Included     | 12   | Included      |
| Kit 2 Float System For Tornado 2-10HP Stainless Steel    | Included     | 12   | Included      |
| Total                                                    |              |      | \$ 148,176.00 |

### Freight Pricing (both options)

| Item                                                                                                                                                                                                                                                                                                                                | Price       |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|
| Estimated Equipment Freight to Site <ul style="list-style-type: none"> <li>System will be shipped DAP (Incoterms 2020)</li> <li>Freight costs will be prepaid and added to invoice</li> <li>Customer is responsible for offloading at site</li> <li>Customer is responsible for final placement of equipment at the site</li> </ul> | \$ 4,375.00 |

### Commercial Notes

- All prices are quoted in US Dollars (USD)
- This quote is for budgetary purposes only and does not constitute a binding offer of sale. Contact your Newterra representative for a firm priced proposal before placing a purchase order.
- Unless otherwise specified, any sales or value added taxes or duties are not included.
- This is an equipment supply price and does not include onsite technical services.
- This proposal has been prepared with considerations for globally sourcing materials and independent of provisions specific to BABAA.

## Schedule

The information provided below is a projected estimate only and should not be assumed to represent a binding schedule.

- Submittal of drawings for approval (if required): Estimated to be 1-2 weeks after Order Acceptance<sup>1</sup>
- Customer review and approval of drawings (if required): In a timely fashion, not longer than 2 weeks
- Notice of readiness to ship: Estimated to be 8-10 weeks<sup>2</sup> after Receipt of Submittal Approval or Order Acceptance (if submittals are not required)

*Notes:*


- 1) *Order Acceptance will occur once all required fully executed order documents have been received (signed purchase order, mutually agreed upon terms and conditions) and acknowledged in writing by Newterra.*
- 2) *Readiness to Ship date will be contingent on payment milestones being met (payment received and confirmed by Newterra in writing). Delays on any payments will postpone the ship date.*



## 3 Technical Section

### TORNADO® Surface Aspirating Aerator/Mixer

The TORNADO® Aerator provides high oxygen transfer and intensive mixing capabilities. The TORNADO® aerator's turbulent directional mixing and jet propulsion discharge assures that oxygen is quickly blended with the wastewater for unmatched oxygen transfer. The intense action of the jet propulsion shears wastewater solids to increase treatment performance and provide better contact for the oxygen and wastewater bacteria.



### Scope of Supply

Newterra's scope of supply for this project consists of the following items:

#### Option 1:

- Eighteen (18) 7.5HP TORNADO® Surface Aspirating Aerator/Mixers, consisting of:
  - One (1) 230/460V, 60Hz, 3PH, 1800RPM NEMA Motor
  - One (1) 304SS 2-Pontoon Float System
  - One (1) 1-Year Non-Prorated Warranty

*Note: Aerators shall arrive fully assembled for immediate mounting*

#### Option 2:

- Twelve (12) 7.5HP TORNADO® Surface Aspirating Aerator/Mixers, consisting of:
  - One (1) 230/460V, 60Hz, 3PH, 1800RPM NEMA Motor
  - One (1) 304SS 2-Pontoon Float System
  - One (1) 1-Year Non-Prorated Warranty

*Note: Aerators shall arrive fully assembled for immediate mounting*



## Scope of Supply by Others

All items below are EXCLUDED from this proposal and are the responsibility of the CUSTOMER. These are to be completed by others or specifically agreed to in writing by Newterra and included in the pricing section of the final version of the proposal.

- Our records show that Newterra was not involved in the sizing or selection of the aeration/mixing equipment on this project. We supplied what was defined by the end user and the end user takes responsibility for the adequacy of the aerators for the application.
- All aspects of final assembly and installation of the equipment at the project site, including field mounting of the equipment, electrical wiring and power connections, start-up and commissioning, filling of the tanks, and checking and testing of the components and systems. Float systems are delivered unassembled and field assembly is required. Assembly and installation are to be supplied by others.
- Control accessories such as electrical disconnects, motor starters or run timers are not included and are to be supplied by others.
- Electrical accessories such as electrical cable, electrical cable hangers, motor cable grips or strain reliefs are not included and are to be supplied by others.
- Soft starts and VFDs are highly recommended for any unit over 10 horsepower. Soft starts and VFDs are not included in proposal and are to be supplied by others.
- Mooring accessories such as mooring cable, mooring clips and thimbles, and mooring posts are not included and are to be supplied by others.
- The CUSTOMER will be responsible for supplying the design and equipment for the mooring posts for soil site conditions. Newterra can provide typical installations along with aerator forces being applied to the mooring posts.
- The CUSTOMER assumes responsibility for any alterations to the proposal, in design, materials, manufacture, or otherwise, as such alterations may affect the contract price, the delivery schedule, and the performance of components and the entire plant.
- Additional aerator accessories may be needed (not included in price) in the event the water level will fluctuate more than three (3) feet, these include but are not limited to: swing arms, low level legs, anti-erosion shields and anti-vortex shields. This equipment is available upon request.

## 4 Newterra Lifecycle Solutions

### Robust Support and Complete Lifecycle Solutions: Call us at 1-800-420-4056

Newterra Lifecycle offerings are here to assist with maintaining your water treatment equipment every step of the way by offering OEM Spare Parts & Consumables customized to suit your needs, alongside a team of support staff dedicated to providing top level services for the life of your system. Not Just Technologies. Lifecycle Solutions.



#### NEWTERRA PARTS AND CONSUMABLES SUPPORT

Our Newterra Parts Team ensures seamless replacement and maintenance parts support, with a detailed list of OEM critical spares, maintenance, and consumable parts provided in your Operations & Maintenance Manual. We're dedicated to meeting your parts requirements to ensure long-lasting equipment solutions. Whether your system needs regular maintenance or requires consumable parts for optimal performance, we have you covered. Our Customer Experience Team is here to assist you in identifying the right components based on your specific challenges. Let us connect you with one of our specialists to find the perfect solution tailored to your needs.



#### TECHNICAL SERVICE SUPPORT

Our dedicated OEM Trained Service Team is here to help support you and your equipment needs. We offer a range of water treatment services including: 1) Operations Consultations, 2) Equipment Audits, 3) On-site Training, 4) 24/7 Digital Monitoring Services, 5) Equipment Maintenance/Repair, 6) Real-time Technical Support and 7) System Upgrades. Our Technical Services Teams are here to ensure your water treatment equipment is operating optimally, maximum uptime is achieved, and costly repairs are avoided. Reach out for expert guidance and a customized solution to your specific technical service needs today.



#### NEWTERRA DIGITAL SERVICE

Newterra Digital Services offers the integration of 24/7 web-based remote monitoring to help you increase system runtime and track performance. It provides real-time data and notifications to you and our technical support team on how your system is running or if there are any issues. The technology also provides the ability to quickly analyze the root cause and assist in determining a proper solution. Newterra Digital Services web-based remote monitoring can consist of two levels of access; read-only and system control. With control, you can have the ability to restart components from remote locations saving you time and money. The advanced digital services support will help you get the most out of your water treatment equipment and stay ahead of potential problems.



#### MEDIA & MEDIA SERVICES

Proper media selection is crucial for efficiency, sustainability, and cost-effectiveness. Newterra leads this sector, providing a range of media solutions from bulk supplies to specialized drums, including Granular Activated Carbon (GAC) and Resin media. When your media has lost its ability to reduce contaminants, our trained professionals, backed by Newterra's experience in the design and implementation of liquid and vapor phase treatment systems, provide complete on-site services. Our trained technicians will arrive on-site and safely clean and remove vapor phase and liquid phase media or even the vessels themselves. We embrace the entire lifecycle of your system.



#### RENTALS SOLUTIONS

For just about any water problem, Newterra has you covered. If you're looking for medium or short-term water or wastewater treatment solutions, Newterra has a large, in-stock inventory of solutions that are available to rent. From supplemental aeration to remediation systems, pressure vessels, and complete wastewater treatment systems, our temporary ownership and rental solutions can save precious capital while solving a critical need. Newterra offers flexible terms and conditions to suit any customer.

## 5 Appendices





## TORNADO Surface Aspirating Aerator



*Powerful and reliable, self-aspirating surface TORNADO aerators are used to upgrade lagoon systems and expand the treatment capacity of mechanical wastewater treatment plants*

### Achieve Improved Aeration and Mixing With TORNADO Surface Aspirating Aerators

The TORNADO® Aerator by Newterra is an innovative aeration system designed for wastewater treatment applications. It features a unique, high-efficiency impeller design that creates a powerful tornado-like flow pattern, enhancing oxygen transfer and mixing in water treatment processes.

This aerator is known for its ability to effectively oxygenate and mix wastewater, promoting biological treatment processes and improving overall treatment efficiency. It is often used in aeration basins, lagoons, and other wastewater treatment systems to optimize

oxygenation and mixing while minimizing energy consumption. TORNADO provides in a wide range of applications.


The TORNADO aerator's turbulent directional mixing and jet propulsion discharge assures that oxygen is quickly blended with the wastewater for unmatched oxygen transfer. The intense action of the jet propulsion shears wastewater solids to increase treatment performance and provide better contact for the oxygen and wastewater bacteria.







in the water surface and the solid steel propeller. The draft tube is stationary. The air turbulence and air bubbles,



### Stainless Steel Components

Durable stainless steel floats are unmatched in the industry and ensure the aerator remains buoyant for its full life, even in the harshest of environments. Proprietary engineering ensures that the aerator runs properly throughout its service life, without time consuming maintenance.

### Reduced Energy Costs

Every TORNADO aerator is equipped with premium efficiency motor to operate more economically over time. Larger motors are designed to work with soft start or Variable Frequency Drive (VFD) controllers to eliminate power surge penalties and reduce energy costs.

### Key Technical Features

- Available horsepower range: 2-100 hp (1.5 kW-75 kW)
- Operational speed: 1800 rpm at 60 Hz (1500 rpm at 50 Hz)
- Premium efficiency (TEFC) motors
- 304 stainless steel (standard) or 316 stainless steel (optional) construction
- Grease-lubricated bearings and a solid shaft ensure a vibration-free design

### Markets and Industries

- Municipal Wastewater Treatment
- Aquaculture
- Wineries & Breweries
- Chemical Processing
- Pulp & Paper Mills
- Textile • Oil & Gas
- Mining
- Dairies
- Food & Beverage Processing

| TORNADO Specifications |      |                 |                |                 |                 |                     |
|------------------------|------|-----------------|----------------|-----------------|-----------------|---------------------|
| hp                     | kW   | 60 Hz Motor rpm | Motor FLA 460V | 50 Hz Motor rpm | Motor FLA 380 V | Ship Weight lb (kg) |
| 2                      | 1.5  | 1730            | 3.1            | 1425            | 3.7             | 118 (54)            |
| 3                      | 2    | 1745            | 4.0            | 1450            | 4.8             | 161 (73)            |
| 5                      | 4    | 1750            | 6.5            | 1445            | 7.9             | 169 (76)            |
| 7.5                    | 5.5  | 1750            | 9.4            | 1445            | 11.6            | 225 (102)           |
| 10                     | 7.5  | 1750            | 12.4           | 1445            | 15              | 248 (113)           |
| 15                     | 11   | 1760            | 18.6           | 1450            | 22.6            | 407 (185)           |
| 20                     | 15   | 1760            | 23.5           | 1450            | 31.4            | 492 (223)           |
| 25                     | 18.5 | 1770            | 29.6           | 1460            | 35.2            | 539 (244)           |
| 30                     | 22   | 1770            | 35.5           | 1460            | 42              | 541 (245)           |
| 40                     | 30   | 1770            | 47.1           | 1460            | 55              | 730 (331)           |
| 50                     | 37   | 1770            | 59.2           | 1460            | 68              | 914 (415)           |
| 60                     | 45   | 1775            | 69.4           | 1465            | 83              | 1146 (520)          |
| 75                     | 56   | 1775            | 86.2           | 1465            | 103.5           | 1219 (553)          |
| 100                    | 74.5 | 1780            | 114            | 1480            | 135             | 1353 (1353)         |





# TORNADO® Surface Aspirating Aerator




## Available Accessories

- Anti-erosion shields to prevent erosion in shallow (clay or earthen) basins
- Anti-vortex shield if vortexing occurs or if an aerator is operated below the standard 45 degree angle of operation
- Low-level legs to prevent damage to basin or equipment when water levels drop below three feet
- Walls and bridge mounts for mounting flexibility
- Swing arms to accommodate up to 15 feet of fluctuations in water elevation
- Maintenance decks built on pontoon platforms for easy servicing access
- Automatic grease lubrication equipment to reduce maintenance
- Blower add-on kit accessory to convert to blower-assisted operation
- **Rental units also available**

## Enhanced Oxygenation for Advanced Wastewater Treatment

The Blower-Assisted TORNADO Aerator is used for wastewater treatment applications that require a higher level of oxygenation. A blower is added to the self-aspirating aerator to force additional air down the inlet hole. The blower uses a small motor, typically from 2 to 10 HP (1.5kW to 7.5 kW), that inputs more oxygen as compared to a standard TORNADO aerator. The TORNADO Blower-assist aerator mounts at an angle on floats or can be wall-mounted. The motor and air intake is above the surface and the propeller is submerged beneath the water.




## What's Your Unique Water Question?

With thousands of installed units around the world, Newterra is your expert provider for wastewater treatment solutions. We offer all major wastewater aeration technologies and the expertise to help you select and apply the equipment best suited for your application. Our technical experts are ready to assist you with the proper sizing, layout, and operation of your aeration system.

For just about any water problem, Newterra has you covered. Our temporary ownership and rental solutions can save precious capital while solving a critical need. Newterra offers flexible terms and conditions to suit any customer.

Contact us today at **+1 800.420.4056** or visit us online at **[newterra.com](http://newterra.com)**





# NOTES:

- 1) FLOATS SHIPPED UNASSEMBLED, ASSEMBLY BY OTHERS.
- 2) MOORING PLATES CABLE & CABLE CLIPS NOT INCLUDED, AVAILABLE IN A KIT
- 3) NORMAL USEAGE IS FROM 45° TO 60°. AT ANGLES APPROCHING 30° A VORTEX SHIELD WILL BE NEEDED.
- 4) USE LOW LEVEL LEGS IF USED IN LESS THAN 3.5FT OF WATER.
- 5) Inch [mm]

## PARTS LIST

| ITE | QT | PART NO | DESCRIPTION                                    | MASS [LBS]     |
|-----|----|---------|------------------------------------------------|----------------|
| 1   | 1  | 37030   | 7.5HP/5.6KW MOTOR                              | 45.866 lbmass  |
| 2   | 1  | 72152K  | Kit: 2 Float System                            | 157.359 lbmass |
| 3   | 1  | 84907K  | Kit Tornado 7.5/60 For NEMA Motor 1-3/8" Shaft | 66.319 lbmass  |

|         |
|---------|
| DRAWN   |
| DATE    |
| CHECKED |
| SIZE    |
| A       |

|                                                                                                                     |  |                                                                                                                          |  |
|---------------------------------------------------------------------------------------------------------------------|--|--------------------------------------------------------------------------------------------------------------------------|--|
|                                                                                                                     |  | MANUFACTURING NOTES (WHERE APPLICABLE):<br>-BREAK CORNERS AND SHARP EDGES<br>-REMOVE BURRS<br>-CLEAN AND PASSIVATE WELDS |  |
| MATERIAL                                                                                                            |  | TITLE<br>Kit 2 Float System With 7.5Hp<br>TORNADO                                                                        |  |
| DEFAULT TOLERANCES<br>FRACTIONAL DECIMAL ANGULAR<br>+/- 1/64 X.X +/- 0.1 +/- 1°<br>X.XX +/- 0.03<br>X.XXX +/- 0.005 |  | DRAWING/PART NUMBER                                                                                                      |  |
| THIRD ANGLE PROJECTION<br>SCALE: VIEW LEVEL                                                                         |  | SHEET<br>1 of 1                                                                                                          |  |

## APPENDIX C: NEWTERRA SUPPORTING CALCULATIONS AND CONFORMANCE TO THE STIPULATED MINIMUM LEVELS OF SERVICE

- Calculations and Manufacture's Worksheets





## APPENDIX D: 2004 DESIGN STUDY REPORT (DSR)

- Report Prepared by Ward Engineering Group for Cell 1

# LAKE POINT IMPROVEMENT DISTRICT LAGOON AERATORS – CELL NO. 1 DESIGN STUDY REPORT

---



**Ward Engineering Group**

1370 South West Temple  
Salt Lake City, Utah 84115  
(801)487-8040  
APRIL 2004



## **CONTENTS**

|                                     | Page no. |
|-------------------------------------|----------|
| Executive Summary                   | 1        |
| 1. Introduction                     | 3        |
| 1.1. Background                     | 3        |
| 1.2. Purpose of This Report         | 3        |
| 2. Existing Conditions              | 3        |
| 2.1. Planning Area                  | 3        |
| 2.2. Planning Period                | 3        |
| 2.3. Existing Facultative Lagoons   | 4        |
| 2.4. Wastewater Constituents        | 5        |
| 3. Population and Flow Projections  | 5        |
| 3.1. Population Projections         | 5        |
| 3.2. Flow Projections               | 6        |
| 4. Regulatory Requirements          | 6        |
| 4.1. General                        | 6        |
| 4.2. Lagoon Requirements            | 7        |
| 4.3. Aeration Requirements          | 7        |
| 5. Lagoon Aeration Design Standards | 7        |
| 5.1. General                        | 7        |
| 5.2. Cold Weather Conditions        | 8        |
| 5.3. Odor Control Standards         | 8        |
| 5.4. Oxygen Requirement Standards   | 8        |
| 5.5. Mixing Requirement Standards   | 9        |
| 6. Lagoon Aeration Alternatives     | 9        |
| 6.1. General                        | 9        |
| 6.2. Diffused Air                   | 9        |
| 6.3. High Speed Surface Aerators    | 9        |
| 6.4. Aspirating Aerators            | 10       |
| 7. Recommended Alternative          | 10       |
| 7.1. Recommended Aerator            | 10       |
| 7.2. Horsepower Requirements        | 10       |
| 7.2. Construction Recommendations   | 12       |
| 8. Estimated Cost of Construction   | 12       |
| 9. Conclusion                       | 12       |

***Tables***

|                                                        |    |
|--------------------------------------------------------|----|
| Table 2.3A – Lagoon Hydraulic Characteristics          | 4  |
| Table 2.3B – Summary of Paid Active and Inactive ERU's | 4  |
| Table 2.3C – Remaining Lagoon Capacity                 | 5  |
| Table 2.4 – Historic Influent Sampling Data            | 5  |
| Table 3.1 – Population Projections                     | 6  |
| Table 3.2 – Flow Projections                           | 6  |
| Table 5.1 – Complete Mix Lagoon Design Parameters      | 7  |
| Table 5.2 – Lagoon Average Cold Weather Temperature    | 8  |
| Table 7.2A – Mixing Horsepower Requirements            | 11 |
| Table 7.2B – Aeration Phasing                          | 11 |

***Figures***

|                                                      |
|------------------------------------------------------|
| Figure 1 – Existing Lagoons                          |
| Figure 2 – Initial Lagoon Aerator Layout Schematic   |
| Figure 3 – Build Out Lagoon Aerator Layout Schematic |

***Appendices***

|                                              |
|----------------------------------------------|
| Appendix A – Abbreviations                   |
| Appendix B – Engineer's Cost Estimate        |
| Appendix C – Population and Flow Projections |
| Appendix D – Calculations                    |
| Appendix E – Manufacturer's Data             |



## **EXECUTIVE SUMMARY**

### **Background**

In June 2001, the Lake Point Improvement District (LPID) was presented with a *Preliminary Engineering Report for Wastewater Treatment* prepared by Ward Engineering Group (WEG). In that report WEG addressed the potential future growth of LPID and the surrounding area, and presented various options for a municipal wastewater treatment plant. Also in the report WEG recommended an interim solution of the installation of mechanical aerators in the existing lagoon system prior to the construction of a mechanical wastewater treatment plant. The installation of mechanical aerators would eliminate odors problems and increase the existing capacity of the lagoons, thus extending the life of the existing lagoon system.

### **Purpose of This Report**

In May 2003, LPID contracted WEG to develop a Design Study Report (DSR) to evaluate various aerator options and to recommend the type of aerator that would best meet LPID's needs.

### **Existing Conditions**

Lake Point is currently treating approximately 0.174 million gallons per day (MGD) of wastewater from 498 paid active equivalent residential units (ERUs). In addition to the 498 paid active connections there are 274 paid inactive ERUs that the District has received impact fees from. This brings the total number of ERUs that the lagoons should have capacity to treat to 772.

Wastewater from the District is treated in a system of three facultative lagoons with a hydraulic capacity of 0.293 MGD and a BOD capacity of 315 pound per day. Effluent from the treatment lagoons is discharged on an as-needed basis to an unnamed drainage ditch that flows into the Great Salt Lake.

Based upon the total number of paid active ERUs the BOD capacities of the lagoons is being exceeded by 15%.

### **Regulatory Requirements**

The Utah Department of Environmental Quality (DEQ), Division of Water Quality (DWQ) regulates wastewater treatment facilities. The rules governing requirements for wastewater treatment facilities can be found in *Utah Administrative Code (UAC) Rule R317-3*.

All wastewater treatment facilities proposing improvements must submit construction drawings and specifications to DWQ and receive a construction permit and approval prior to beginning construction of the proposed improvements.

## **Population and Flow Projections**

Population and flow projections for the LPID service area for the next twenty years have been taken into account for this study. The population and flow projections of future developments have not been taken into account. This is due to the uncertain time frame of these future developments.

Based upon an average of 3.5 people per ERU and 350 gallons per day (gpd) per ERU flow projections for the planning period were calculated. By the end of the planning period it is estimated that LPID may need to treat approximately 0.599 million gallons per day of wastewater.

## **Treatment Alternatives**

Several treatment alternatives for LPID were explored to determine the most viable and economic alternative for supplying oxygen to wastewater. The alternatives considered are Diffusion Aeration, High Speed Surface and Aspirating Aeration.

## **Recommendation**

Considering effectiveness and cost, the recommended aeration alternative is Aspirating Aerators. Based upon the depth of the lagoons and the current BOD loading it recommended that eight - 7.5 horsepower (hp) Tornado aspirating aerators as manufactured by Aeromix be installed at this time. The eight aerators are to be operated continuously to ensure adequate dissolved oxygen level is maintained. If the aerators are not operated continuously additional aerators will be required to maintain the dissolved oxygen level for treatment.

Prior to beginning construction of the project the design of the plans and technical specifications must be reviewed by the DWQ and a construction permit issued.

## **Estimated Cost of Construction**

The Preliminary Estimated Cost of Construction for installation of eight aerators and infrastructure for 24 aerators is approximately \$141,934. This includes a 20% contingency, engineering design, and construction management services.

## INTRODUCTION

### 1.1. Background

In June 2001 the Lake Point Improvement District (LPID) was presented with a *Preliminary Engineering Report for Wastewater Treatment* prepared by Ward Engineering Group (WEG). In that report WEG addressed the potential future growth of LPID and the surrounding area, and presented various options for a mechanical wastewater treatment plant. Also in the report WEG recommended an interim solution of the installation of mechanical aerators in the existing lagoon system prior to the construction of a mechanical wastewater treatment plant. The installation of mechanical aerators would both eliminate odors problems and increase the existing capacity of the lagoons, thus extending the life of the existing lagoon system.

### 1.2. Purpose of This Report

In May 2003 LPID contracted WEG to develop a Design Study Report (DSR) to evaluate the various aerator options and to make a recommendation as to the type of aerator that would best suit LPID's needs.

This DSR has three main goals:

- Determine the current and future design parameters used in the design of the chosen aerator alternative.
- Evaluate the various aeration alternatives and recommend a chosen alternative.
- Provide preliminary engineering data for the chosen alternative.

## 2. EXISTING CONDITIONS

### 2.1. Planning Area

The planning area only included the LPID service area. Due to the uncertain time frame of development, the population and flow projections for future developments have not been taken into account. However, it should be noted that when development begins, the existing lagoon system with aerators could reach capacity in a relatively short period of time.

### 2.2. Planning Period

Population and flow projections for the LPID service area for the next twenty years are taken into account. As with the Planning Area, the population and flow projections for future developments have not been taken into account. This is due to the uncertain time frame of these developments.



### 2.3. Existing Facultative Lagoon System

LPID currently operates a facultative lagoon system, which consists of three aerobic/facultative lagoons operating in series, as shown in *Figure 1*.

*Table 2.3A* contains the hydraulic characteristics of the existing lagoon system.

**Table 2.3A – Lagoon Hydraulic Characteristics**

| Cell  | Function  | Area (Acre) | Depth (feet) | Capacity<br>(Million Gallons) |
|-------|-----------|-------------|--------------|-------------------------------|
| 1     | Primary   | 9.0         | 4.5          | 12.4                          |
| 2     | Secondary | 7.4         | 6.0          | 13.6                          |
| 3     | Tertiary  | 5.0         | 6.0          | 9.2                           |
| TOTAL |           | 21.4        |              | 35.2                          |

The capacity of each cell is based upon 94% of the total volume of the cell. This is to account for the side slopes of each of the lagoons.

For complete mix calculations the full depth of primary cell is to be used. This equates to a total volume of 16.5 Million Gallons (MG) (2,205,730 cubic feet).

For odor control calculations the effective depth of Cell No.1 of 4.5-feet (12.4 MG or 1,657,640 cubic feet) will be used. This is to account for the depth of the sludge blanket. The sludge blanket is not to be disturbed by the aerators.

The existing lagoon system has an overall hydraulic capacity of 0.293 million gallons per day (MGD) or approximately 837 ERUs based upon 350 gallons per day (gpd) per ERU and a hydraulic retention time of 120 days. This hydraulic capacity does not include inflow and infiltration (I/I).

Additionally the lagoons have the capacity to treat 315 pounds of BOD based upon a maximum BOD loading rate of 35 pounds per day (ppd) per Acre (*UAC R317-3-10.3.A.1.*) and the 9-acre area of the primary cell. This equates to 431 ERUs based upon 0.73 ppd of BOD per ERU.

Currently LPID serves 498 Equivalent Residential Units (ERUs), with an additional 274 ERUs that are inactive. *Table 2.3B* contains a summary of the paid active and inactive ERUs.

**Table 2.3B – Summary Of Paid Active And Inactive ERUs**

| Connection  | Paid Active | Paid Inactive | Total |
|-------------|-------------|---------------|-------|
| Commercial  | 286         | 0             | 286   |
| Residential | 212         | 274           | 486   |
| TOTAL       | 498         | 274           | 772   |

Table 2.3C contains a summary of the paid active and total paid ERUs as compared to lagoon capacities.

**Table 2.3C – Remaining Lagoon Capacity**

| Parameter                    | Active ERUs | Total ERUs |
|------------------------------|-------------|------------|
| Hydraulic Loading (MGD)      | 0.174       | 0.270      |
| BOD Loading (ppd)            | 363         | 563        |
| Hydraulic Capacity Remaining | 41%         | 8%         |
| BOD Capacity Remaining       | -15%        | -79%       |

Based upon these figures the lagoons are at their BOD loading capacity and measures should be taken as soon as possible to increase the treatment capacity of the lagoons.

## 2.4. Wastewater Constituents

Historic sampling data collected by the LPID for January 2000 through March 2003 is contained in *Appendix C* along with graphical representations of the sampling data. *Table 2.4* contains the average BOD and Total Suspended Solids (TSS).

**Table 2.4 – Historic Influent Sampling Data**

| Average BOD (Mg/l) | Average TSS (Mg/l) |
|--------------------|--------------------|
| 161                | 197                |

The historic sampling data indicate that the average BOD and TSS concentrations are not increasing even though there are wide variations in the data.

For this study the District standard of an average BOD concentration of 250 mg/L will be used in all calculations.

## 3. POPULATION AND FLOW PROJECTIONS

### 3.1. Population Projections

Population projections for the LPID service area from the *Preliminary Engineering Report for Wastewater Treatment* have been revised and used in this study. The projections have been extended to 2023. Due to the uncertain time frame of development, the population and flow projections for future developments have not been taken into account. Therefore, only the paid active ERUs have been used as a base line for projects. The population projections from the *Preliminary Engineering Report for Wastewater Treatment* were determined based upon a flat residential and commercial growth rate of 6% per year and are related in terms of ERUs.

An ERU is defined as being the equivalent flow of one residential unit or home. Based upon District standards, this is assumed to be approximately 350 gallons per day or 3.5 persons per ERU and 100 gallons per day per capita, as prescribed in *Utah Administrative Code (UAC) R317-3*.

Table 3.1 contains a summary of the calculated number of residential and commercial ERUs for the LPID service area.

**Table 3.1 – Population Projections**

| Year | Residential ERUs | Commercial ERUs | Total |
|------|------------------|-----------------|-------|
| 2008 | 284              | 383             | 667   |
| 2013 | 380              | 467             | 847   |
| 2023 | 680              | 731             | 1411  |

Appendix C contains more detailed information for population and flow projections.

### **3.2. Flow Projections**

Flow projections for the planning period have been calculated based upon an average flow of 350-gallons per day per ERU as shown in Table 3.2. Due to the well-maintained sewer collection system, the system experiences little Inflow and Infiltration (I/I), therefore I/I flows have not been taken into account in these flow projections.

**Table 3.2 – Flow Projections**

| Year | Residential Flow (MGD) | Commercial Flow (MGD) | Total |
|------|------------------------|-----------------------|-------|
| 2008 | 0.145                  | 0.134                 | 0.279 |
| 2013 | 0.179                  | 0.164                 | 0.342 |
| 2023 | 0.284                  | 0.256                 | 0.540 |

Appendix C contains more detailed information for population and flow projections.

## **4. REGULATORY REQUIREMENTS**

### **4.1. General**

The Utah Department of Environmental Quality (DEQ), Division of Water Quality (DWQ) regulates wastewater treatment facilities. The rules governing requirements for wastewater treatment facilities can be found in *Utah Administrative Code (UAC) Rule R317-3*.

All wastewater treatment facilities proposing improvements must submit construction drawings and specifications to DWQ and receive a construction permit and approval prior to beginning construction of the proposed improvements.

These requirements must be followed for the design of complete mix aerated lagoons.



## 4.2. Lagoon Requirements

The following is a summary of lagoon requirements as described in *UAC Rule R317-3-10*.

- The minimum detention time for discharging lagoons with chlorination is 120 days. The detention time is calculated using the entire lagoon volume less 18-inches of sludge build-up in the primary cell.
- The minimum detention time for aerated lagoons is 30 days.
- The maximum BOD loading for facultative lagoons is 15 to 35 pounds per acre per day.

## 4.3. Aeration Requirements

The following excerpts from *UAC Rule R317-3-10* describe the regulatory requirements for complete mix aerated lagoons.

- "...[the design parameters for the aerated lagoon] should be based on two pounds of oxygen input per pound of BOD applied..."
- "Aeration equipment shall be capable of maintaining a minimum dissolved oxygen level of 2 milligrams per liter in the lagoon at all times such that their circles of influence meet. The circle or zone of influence is the area in which return velocity is greater than 0.15 feet per second as indicated by the manufacturer's certified data."
- "Freezing. Suitable protection from weather shall be provided for aerators and electrical controls."

# 5. LAGOON AERATION DESIGN STANDARDS

## 5.1. General

The following design standards are based upon state regulations and accepted engineering standards and existing lagoon parameters.

**Table 5.1 – Complete Mix Lagoon Design Parameters**

| Description                          | Existing | Future  |
|--------------------------------------|----------|---------|
| Cell No. 1 Area (Ac)                 | 9.0      | 9.0     |
| Cell No. 1 Depth (ft)                | 6.0      | 6.0     |
| Cell No. 1 Volume (mg)               | 16.5     | 16.5    |
| ERUs                                 | 772      | 2,425   |
| Flow (MGD)                           | 0.270    | 0.849   |
| BOD (mg/l)                           | 250      | 250     |
| BOD (lb/d)*                          | 563      | 1,770   |
| Average Water Temperature (°F)       | 52.9     | 52.9    |
| Maximum Water Surface Elevation (ft) | 4,242.5  | 4,242.5 |

\* Based upon 250 mg/L x 8.34 x Flow (MGD)

The following assumptions were made when determining the design parameters:

- Neither the geometry nor the size of Cell No. 1 will change.
- The more conservative recommended state standards for BOD of 250 mg/l or 0.73 ppd per ERU are to be used (*UAC R-317-3-4.3.C*).
- A BOD loading rate of 35 ppd per acre to the primary cell is to be used (*UAC R-317-3-10.3.A.1*).
- For complete mix lagoons, an effective depth of 6 feet is used.

## 5.2. Cold Weather Conditions

During the months in which lagoon temperatures are typically below 40 degrees, typically November through March, biological activity is extremely low. Because of the decrease temperatures and biologic activity during this time period the effectiveness of the aerators will drop. During this time it may be difficult to meet the discharge requirements and may be necessary to retain wastewater until warmer weather and increased biological activity.

**Table 5.2 – Lagoon Average Cold Weather Temperature**

| Month       | Average Temperature (°F) |
|-------------|--------------------------|
| December-01 | 33.1                     |
| January-01  | 33.3                     |
| February-01 | 33.5                     |
| March-01    | 40.3                     |
| December-02 | 40.2                     |
| January-02  | 40.2                     |
| February-02 | 40.8                     |
| March-02    | 49.8                     |

## 5.3. Odor Control Standards

There is not a quantitative standard used in the sizing of aerators for the control of odor. General engineering standards suggest that 20% of total horsepower required for complete mix is adequate for neutralization of odors.

## 5.4. Oxygen Requirement Standards

Oxygen requirements for aerated lagoons are based upon on “two pounds of oxygen input per pound of BOD applied” and “a minimum dissolved oxygen level of 2 milligrams per liter in the lagoon at all times” as specified in *UAC Rule R317-3-10.3-G*.

## **5.5. Mixing Requirement Standards**

Mixing requirements for complete mix are based upon the general engineering standard of 0.08 horsepower (hp) of mixing per 1,000 cubic feet of lagoon volume.

## **6. LAGOON AERATION ALTERNATIVES**

### **6.1. General**

The main purpose of aeration is to supply oxygen to the wastewater to enhance the aerobic digestion of BOD as well as for the control of odor.

There are two basic methods of aerating wastewater 1) to introduce air into the wastewater with submerged diffusers and 2) to agitate the wastewater mechanically to promote the transfer of air from the atmosphere to the wastewater.

This report will evaluate three different types of aeration:

- Diffused Air
- High Speed Surface Aerators
- Aspirating Aerators

Each of these will be covered separately in the following sections.

### **6.2. Diffused Air**

A diffused air system consists of diffusers submerged in the wastewater, header pipes, air mains, blowers, and appurtenances through which the air passes.

With a diffused air system, blowers force air through a series of air pipes to a series of diffusers that are submerged. The air bubbles up through the water causing mixing as well as oxygen transfer.

A diffused air system provides a high oxygen transfer rate. However due to the high initial cost and maintenance issues this option will not be evaluated further.

### **6.3. High-Speed Surface Aerators**

High-speed surface aerators typically mounted on floats so that they can move vertically with changes in the water surface elevation. The aerators are then anchored to the lagoon banks using mooring cables.

High-speed surface aerators serve dual purposes of oxygenation and mixing. They oxygenate the water by pulling water up from the bottom of the lagoon and throwing it into the air where contact with the oxygen in the air is transferred to the water. Secondly



they provide mixing. By pulling water up from the bottom of the lagoon they also provide mixing.

High-speed surface aerators create a high aerosol environment that can lead to odor problems. Additionally they have a limited zone of mixing influence. The limited mixing potential can lead to freezing problems in winter months.

#### **6.4. Aspirating Aerators**

Aspirating aerators provide both mixing and aeration and are typically mounted on floats so that they can move vertically with changes in the water surface elevation. The aerators are then anchored to the lagoon banks using mooring cables.

As with high-speed surface aerators, aspirating aerators provide both oxygenation and mixing of wastewater. Moreover, aspirating aerators inject air into water by use of a submerged impeller connected to a solid shaft inside a hollow tube. As the impeller rotates air is pulled through the hollow shaft by the creation of a vacuum that is caused by the rotation of the impeller. The rotation of the impeller also causes mixing.

By injecting air, aspirating aerators have more efficient O<sub>2</sub> transfer, have no aerosol (less odors) and cost less than diffusers. Because of this design, they are not affected by freeze and are easier to maintain.

### **7. RECOMMENDED ALTERNATIVE**

#### **7.1. Recommended Aerator**

Based upon the alternative types of aeration considered, the recommended alternative is an aspirating aerator. The aspirating type aerator will supply adequate mixing and oxygen transfer to increase the existing lagoon capacity and possibly reduce the odor associated with the lagoons.

There are two main manufacturers of aspirating aerators, Aeromix which produces the Tornado and Aeration Industries International, Inc., which produces the Aire-O2. Both the Tornado and the Aire-O2 are similar in design and function. The main difference is that the Tornado cost about \$200 less and is of better construction. The manufacturer has designed the Tornado for ease of maintenance with the majority of the components being readily available at most retail hardware stores.

Therefore it is recommended that the 7.5 hp Tornado aerator manufactured by Aeromix be used. The remaining sections of this report will be based upon the Tornado. Refer to *Appendix E* for drawings relating to the Tornado.

## 7.2. Horsepower Requirements

Based upon the regulatory requirements and horsepower design parameters discussed in Sections 4 and 5 of this report, the horsepower requirements for mixing are summarized in *Table 7.2A*.

**Table 7.2A – Mixing Horsepower Requirements**

| Parameter    | Required Horsepower* |
|--------------|----------------------|
| Complete Mix | 176                  |
| Partial Mix  | 88                   |
| Odor Control | 26                   |

\* - Based upon continuous operation.

A total of 24-7.5 hp aerators will be required in Cell No. 1. At the present time, it is not necessary for LPID to install all of the aerators that will be required at build out. Therefore a phasing plan has been developed based upon the calculated BOD loading rate. *Table 7.2B* contains a summary of aeration phasing.

**Table 7.2B – Aeration Phasing**

| #ERU  | Flow (MGD) | BOD (ppd)** | Horsepower* | 7.5 hp Aerators |
|-------|------------|-------------|-------------|-----------------|
| 772   | 0.270      | 563         | 56          | 8               |
| 1,000 | 0.350      | 730         | 72          | 10              |
| 1,250 | 0.438      | 912         | 91          | 12              |
| 1,500 | 0.525      | 1,095       | 109         | 15              |
| 1,750 | 0.6123     | 1,277       | 126         | 17              |
| 2,000 | 0.700      | 1,460       | 144         | 20              |
| 2,250 | 0.788      | 1,642       | 163         | 22              |
| 2,425 | 0.849      | 1,770       | 176         | 24              |

\* - Based upon continuous operation.

\*\* - Based upon  $250 \text{ mg/L} \times 8.34 \times \text{Flow (MGD)}$

As the number of ERUs increases thus increasing the flow and BOD loading additional aerator can be installed.

It is feasible to install aerators into all three lagoons. With aerators in all three lagoons the hydraulic retention time can be reduced to 30 days (*UAC R317-3-10.3.F.2.a(1)*). This equates to a hydraulic capacity of 1.31 MGD or 3,743 ERUs. Cell No. 2 would require 20-7.5 hp aerators and Cell No. 3 would require 13-7.5 hp aerators operating continuously to provide complete mix. However at this point a mechanical wastewater treatment plant may be more economically viable.

### **7.3. Construction Recommendation**

Based upon the current total number of active and inactive ERUs it is recommended that eight – 7.5 hp aerators be installed at this time and ran continuously. *Figure 1* contained in illustrates the proposed layout of the initial eight aerators.

At the time the initial eight aerators are installed, infrastructure for the maximum number of aerators to be installed in Cell No. 1 should also be installed. The infrastructure includes running PVC duct for future electrical wiring, mooring posts with cables, and a control panel with adequate capacity for the 24 aerators. By installing the mooring posts with cables the operator can then have the flexibility to change the layout of the aerators as operation of the lagoons dictate, only the electrical wiring will need to be altered. Additionally when future aerators are required they can be easily installed without having to first install the mooring posts with cables, only the electrical wiring and controls will need to be installed. Prior to installation and shipping of the aerators from the manufacturer, the manufacturer should check the aerators to ensure that the oxygen transfer rate prescribed can be obtained.

It is also recommended that a dissolved-oxygen (DO) monitoring meter be included. The DO meter could be either a portable unit or a fixed meter stationed at the outfall between lagoons 1 and 2. A portable DO meter would be more applicable and allow for greater flexibility in monitoring DO levels through out the cell.

At the point when the flow and BOD loading reach a point of 0.849 MGD or 1,770 ppd, respectively, additional aerators will need to be installed into Cell No. 2 to maintain treatment capacity. It is recommended that prior to installation of aerators in Cell No. 2 that the District re-evaluates the option of a mechanical wastewater treatment facility.

## **8. Estimated Cost of Construction**

The Preliminary Estimated Cost of Construction for installation of eight aerators and infrastructure for 24 aerators is approximately \$141,934. This includes a 20% contingency, engineering design, and construction management services. See *Appendix B* for Engineer's Estimate of Probable Cost.

## **9. Conclusion**

At this time the lagoons are at their BOD loading capacity and measures must be taken to ensure adequate treatment of wastewater. Therefore it is recommended that aerators be installed in Cell No.1.

Of the aerator options reviewed, it is recommended that an aspirating type aerator be used. An aspirating aerator will allow a greater degree of flexibility in operating and provide both mixing and aeration. Of the two aspirating aerators available, the Tornado manufactured by Areomix is recommended.




To meet the present paid ERUs demand eight – 7.5 horsepower aerators will be required to meet all of the regulatory and treatment requirements. Preliminary cost estimate indicates that the \$141,934 including engineering.

Prior to beginning construction of the project the design of the plans and technical specifications must be reviewed by the DWQ and a construction permit issued.

## FIGURES


|                          | CELL NO. 1 | CELL NO. 2 | CELL NO. 3 |
|--------------------------|------------|------------|------------|
| AREA                     | 9.0 AC     | 7.4 AC     | 5.0 AC     |
| MAX. WATER SURFACE ELEV. | 4236.50    | 4235.50    | 4234.50    |
| MAX. WATER DEPTH         | 6.00       | 6.00       | 6.00       |



Drawn by: \_\_\_\_\_ Client: LPID  
 Design by: \_\_\_\_\_  
 Checked by: \_\_\_\_\_ Drawing: Existing Lagoons  
 Date: JUL 03 Job NO. LPID 23

## Lagoon Aerators - Cell No. 1


Figure 1



Sheet:



|                          | CELL NO. 1 | CELL NO. 2 | CELL NO. 3 |
|--------------------------|------------|------------|------------|
| AREA                     | 9.0 AC     | 7.4 AC     | 5.0 AC     |
| MAX. WATER SURFACE ELEV. | 4236.50    | 4235.50    | 4234.50    |
| MAX. WATER DEPTH         | 6.00       | 6.00       | 6.00       |



8 - 7.5 hp AERATORS


Drawn by: \_\_\_\_\_ Client: LPID  
 Design by: \_\_\_\_\_  
 Checked by: \_\_\_\_\_ Drawing: Existing Lagoons  
 Date: JUL 03 Job NO. LPID 23

Lagoon Aerators - Cell No. 1  
 Figure 2

 Ward Engineering Group

Sheet:

|                          | CELL NO. 1 | CELL NO. 2 | CELL NO. 3 |
|--------------------------|------------|------------|------------|
| AREA                     | 9.0 AC     | 7.4 AC     | 5.0 AC     |
| MAX. WATER SURFACE ELEV. | 4236.50    | 4235.50    | 4234.50    |
| MAX. WATER DEPTH         | 6.00       | 6.00       | 6.00       |



- ☒ PHASE 1 7.5 hp AERATOR
- PROPOSED 7.5 hp AERATOR
- ZONE OF INFLUENCE

← DIRECTION OF FLOW

24 - 7.5 hp AERATORS

Drawn by: \_\_\_\_\_ Client: LPID  
 Design by: \_\_\_\_\_  
 Checked by: \_\_\_\_\_ Drawing: Existing Lagoons  
 Date: JUL 03 Job NO. LPID 23

Lagoon Aerators - Cell No. 1  
 Figure 3

Ward Engineering Group

Sheet:

**APPENDIX A**  
**ABBREVIATIONS AND DEFINITIONS**



## **Abbreviations**

BOD: Biochemical Oxygen Demand

DO: Dissolved Oxygen

ERU(s): Equivalent Residential Unit

gpcd: gallons per capita per day

gpd: gallons per day

hp: horsepower

LPID: Lake Point Improvement District

mgd: million gallons per day

NPDES: National Pollutant Discharge Elimination Standards

O&M: Operations and Maintenance

ppd: pounds per day

TSS: Total Suspended Solids

UAC: Utah Administrative Code

UPDES: Utah Pollutant Discharge Elimination Standards

WWTP: Wastewater Treatment Plant

## **Definitions**

Equivalent Residential Unit (ERU): equivalent to 350 gpd and 0.73 ppd BOD (mean values)

**APPENDIX B**  
**ENGINEER'S COST ESTIMATE**

## Engineer's Estimate of Probable Cost of Construction

### Lagoon Aerators - Cell No. 1 - Phase 1

| No.       | Item                         | Quantity | Unit | Unit Cost   | Cost          |
|-----------|------------------------------|----------|------|-------------|---------------|
| 1         | 7.5 hp Aerator               | 8        | EA   | \$ 7,000.00 | \$ 56,000.00  |
| 2         | 4" PVC Conduit               | 3500     | LF   | \$ 2.00     | \$ 7,000.00   |
| 3         | 5' Dia. 4" PVC Conduit Sweep | 12       | EA   | \$ 50.00    | \$ 600.00     |
| 4         | Junction Box                 | 1        | EA   | \$ 500.00   | \$ 500.00     |
| 5         | Electrical Cable             | 5900     | LF   | \$ 1.62     | \$ 9,558.00   |
| 6         | Mooring Posts                | 13       | EA   | \$ 200.00   | \$ 2,600.00   |
| 7         | 1/4" Mooring Cable           | 2400     | LF   | \$ 1.75     | \$ 4,200.00   |
| 8         | Controls                     | 8        | EA   | \$ 2,089.00 | \$ 16,712.00  |
| 9         | Control Panel                | 1        | LS   | \$ 5,000.00 | \$ 5,000.00   |
| 10        | Portable DO Meter            | 1        | LS   | \$ 1,000.00 | \$ 1,000.00   |
| 11        | Mobilization                 | 1        | LS   | \$ 2,000.00 | \$ 2,000.00   |
| Sub-Total |                              |          |      |             | \$ 105,170.00 |

|                         |              |
|-------------------------|--------------|
| Contingency (20%)       | \$ 21,034.00 |
| Engineering             | \$ 10,320.00 |
| Construction Management | \$ 5,410.00  |

**TOTAL** **\$ 141,934.00**

This cost estimate is an estimate only. These figures are supplied as a guide only.  
Ward Engineering Group is not responsible for fluctuation in cost of material, labor or components, or unforeseen contingencies.

**APPENDIX C**  
**POPULATION AND FLOW PROJECTIONS**



Lake Point Improvement District  
Lagoon Aerators - Cell No. 1  
LPID 23  
Population and Flow Projections


| Year | Residential |            | Commercial |            | Total |            |
|------|-------------|------------|------------|------------|-------|------------|
|      | ERU         | Flow (mgd) | ERU        | Flow (mgd) | ERU   | Flow (mgd) |
| 2003 | 212         | 0.120      | 331        | 0.112      | 543   | 0.232      |
| 2004 | 225         | 0.125      | 331        | 0.116      | 556   | 0.241      |
| 2005 | 238         | 0.129      | 343        | 0.120      | 581   | 0.250      |
| 2006 | 252         | 0.134      | 356        | 0.125      | 608   | 0.259      |
| 2007 | 268         | 0.140      | 369        | 0.129      | 637   | 0.269      |
| 2008 | 284         | 0.145      | 383        | 0.134      | 667   | 0.279      |
| 2009 | 301         | 0.151      | 398        | 0.139      | 699   | 0.291      |
| 2010 | 319         | 0.158      | 414        | 0.145      | 733   | 0.302      |
| 2011 | 338         | 0.164      | 431        | 0.151      | 769   | 0.315      |
| 2012 | 358         | 0.171      | 449        | 0.157      | 807   | 0.328      |
| 2013 | 380         | 0.179      | 467        | 0.164      | 847   | 0.342      |
| 2014 | 402         | 0.187      | 487        | 0.171      | 890   | 0.357      |
| 2015 | 427         | 0.195      | 509        | 0.178      | 935   | 0.373      |
| 2016 | 452         | 0.204      | 531        | 0.186      | 983   | 0.390      |
| 2017 | 479         | 0.214      | 555        | 0.194      | 1034  | 0.408      |
| 2018 | 508         | 0.224      | 580        | 0.203      | 1088  | 0.427      |
| 2019 | 539         | 0.234      | 607        | 0.212      | 1145  | 0.447      |
| 2020 | 571         | 0.246      | 635        | 0.222      | 1206  | 0.468      |
| 2021 | 605         | 0.258      | 665        | 0.233      | 1270  | 0.491      |
| 2022 | 641         | 0.270      | 697        | 0.244      | 1338  | 0.514      |
| 2023 | 680         | 0.284      | 731        | 0.256      | 1411  | 0.540      |

\*These tabulations were taken from the Preliminary Engineering Report for Wastewater Treatment prepared by Ward Engineering in July 2001.


Lake Point Improvement District  
Lagoon Aerators - Cell No. 1  
LPID 23  
Wastewater Consituents

| Month          | Average Flow (MGD) | Mg/l       |            | Lb/Day     |            |
|----------------|--------------------|------------|------------|------------|------------|
|                |                    | BOD        | TSS        | BOD        | TSS        |
| Jan-99         | 0.147              | 70         | 130        | 86         | 159        |
| Feb-99         | 0.164              | 160        | 222        | 219        | 304        |
| Mar-99         | 0.124              | 140        | 256        | 145        | 265        |
| Apr-99         | 0.138              | 120        | 176        | 138        | 203        |
| May-99         | 0.13               | 150        | 344        | 163        | 373        |
| Jun-99         | 0.096              | 220        | 272        | 176        | 218        |
| Jul-99         | 0.104              | 250        | 278        | 217        | 241        |
| Aug-99         | 0.102              | 380        | 374        | 323        | 318        |
| Sep-99         | 0.108              | 230        | 330        | 207        | 297        |
| Oct-99         | 0.085              | 290        | 276        | 206        | 196        |
| Nov-99         | 0.089              | 290        | 276        | 215        | 205        |
| Dec-99         | 0.1                | 190        | 396        | 159        | 330        |
| Jan-00         | 0.114              | 100        | 214        | 95         | 204        |
| Feb-00         | 0.147              | 200        | 180        | 245        | 221        |
| Mar-00         | 0.146              | 122        | 197        | 149        | 240        |
| Apr-00         | 0.134              | 124        | 150        | 139        | 168        |
| May-00         | 0.132              | 135        | 128        | 149        | 141        |
| Jun-00         | 0.105              | 171        | 145        | 150        | 127        |
| Jul-00         | 0.121              | 142        | 151        | 143        | 152        |
| Aug-00         | 0.108              | 120        | 184        | 108        | 166        |
| Sep-00         | 0.113              | 252        | 295        | 238        | 278        |
| Oct-00         | 0.106              | 90         | 164        | 80         | 145        |
| Nov-00         | 0.086              | 210        | 140        | 151        | 100        |
| Dec-00         | 0.106              | 99         | 93         | 88         | 82         |
| Jan-01         | 0.114              | 186        | 179        | 177        | 170        |
| Feb-01         | 0.114              | 264        | 208        | 251        | 198        |
| Mar-01         | 0.127              | 218        | 127        | 231        | 135        |
| Apr-01         | 0.119              | 89         | 82         | 88         | 81         |
| May-01         | 0.125              | 178        | 246        | 186        | 257        |
| Jun-01         | 0.126              | 109        | 176        | 115        | 185        |
| Jul-01         | 0.145              | 107        | 107        | 129        | 129        |
| Aug-01         | 0.16               | 74         | 119        | 99         | 159        |
| Sep-01         | 0.152              | 117        | 221        | 148        | 280        |
| Oct-01         | 0.127              | 199        | 163        | 211        | 173        |
| Nov-01         | 0.128              | 190        | 174        | 203        | 186        |
| Dec-01         | 0.14               | 69         | 27         | 81         | 32         |
| Jan-02         | 0.131              | 128        | 180        | 140        | 197        |
| Feb-02         | 0.15               | 95         | 130        | 119        | 163        |
| Mar-02         | 0.195              | 144        | 338        | 234        | 550        |
| Apr-02         | 0.182              | 145        | 351        | 220        | 533        |
| May-02         | 0.17               | 136        | 113        | 193        | 160        |
| Jun-02         | 0.196              | 133        | 188        | 218        | 307        |
| Jul-02         | 0.184              | 94         | 76         | 144        | 117        |
| Aug-02         | 0.18               | 129        | 147        | 194        | 221        |
| Sep-02         | 0.16               | 152        | 162        | 203        | 216        |
| Oct-02         | 0.132              | 127        | 116        | 140        | 128        |
| Nov-02         | 0.167              | 170        | 209        | 237        | 291        |
| Dec-02         | 0.164              | 142        | 99         | 194        | 135        |
| Jan-03         | 0.162              | 167        | 179        | 226        | 242        |
| Feb-03         | 0.162              | 170        | 189        | 230        | 256        |
| Mar-03         | 0.161              | 235        | 362        | 316        | 486        |
| <b>AVERAGE</b> |                    | <b>161</b> | <b>197</b> | <b>225</b> | <b>274</b> |

### Sampling Data




### Sampling Data





Average Monthly Flow



## **APPENDIX D**

### **CALCULATIONS**



**AEROMIX Systems, Inc.**  
2611 North Second Street  
Minneapolis, MN 55411 USA  
Within USA: 1-800-879-3677 Phone: 612-521-8519 Fax 612-521-1455  
E-mail: aeromix@aeromix.com

**Lagoon Sizing Calculation using TORNADO Aerators**  
**Prepared for: LPID Lagoon**  
**April 14, 2004**

**Design Criteria**

To convert mg/l into lbs. / day, use the following formula: mg/l \*8.34\*Daily flow (MGD)

|                         |                              |                |
|-------------------------|------------------------------|----------------|
| Flow :                  | 0.27 million gallons per day |                |
| BOD demand:             | 250 mg/l converts to:        | 562 lbs. / day |
| TKN :                   | 0 lbs. / day                 |                |
| Total Suspended Solids: | 0 mg/l converts to:          | 0 lbs. / day   |

The basin volume is found using the following equation:

$$V = D/3(As + Ab + \text{square root}(As * Ab))$$

Where:

V = Cell volume in cubic feet      D = water depth  
As = surface area      Ab = bottom area

Detention time is found by dividing volume by daily flow.

|                        | Cell 1               | Cell 2               | Cell 3               |
|------------------------|----------------------|----------------------|----------------------|
| <b>Width:</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Length</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Depth:</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Volume:</b>         | 2,205,730 cubic feet | 1,818,055 cubic feet | 1,229,861 cubic feet |
| <b>Capacity</b>        | 16,498,860 Gallons   | 13,599,051 Gallons   | 9,199,360 Gallons    |
| <b>Detention time:</b> | 61.11 Days           | 50.37 Days           | 34.07 Days           |

**Calculations of Oxygen Requirements**

This application is sized using 2 lbs. of oxygen per lbs. of BOD, and 4.6 lbs. of oxygen per lbs. of TKN (under working conditions). A residual oxygen level of 2 mg/l will be maintained in the basin at all times.

**BOD Oxygen requirement calculation.**

562 lbs. of BOD/day x 2 lbs. of O<sub>2</sub> / lbs. BOD = 1124 lbs. O<sub>2</sub>/day.

**TKN Oxygen requirement calculation:**

0 lbs. of TKN / day x 4.6 lbs. of O<sub>2</sub> / lbs. TKN = 0 lbs. O<sub>2</sub>/day

**Total Oxygen required per day is the total of the BOD and TKN demands.**

1124 lbs. / day BOD + 0 lbs. / day TKN = 1124 lbs. of oxygen per day (under field conditions).

# AEROMIX Systems, Inc. TORNADO Sizing Calculations for:

LPID Lagoon

LPID 23

Design Study Report

Lagoon Aerators Cell No. 1

Oxygen transfer rates for aerators are reported under standard conditions. In order to make proper comparisons under field conditions, Total Oxygen Requirement (TOR) should be converted to Standard Condition Total Oxygen Requirement (STOR). Conversion from field conditions can be accomplished with the following equation:

$$No = \frac{N}{\frac{Beta * C_{walt} - Cl}{9.17} * Alpha * 1.024^{(T-20)}}$$

Where:

No = STOR lbs. / day  
N = TOR = 1,124 lbs. per day  
Beta = Salinity, surface tension factors = 0.95  
C<sub>walt</sub> = Saturation at given altitude & temp = 7.90  
Cl = Residual oxygen = 2.00 mg/l  
Alpha = Oxygen transfer correction factor = 0.85  
T = Operating temperature (68 degrees F) 20 degrees C

$$= \frac{1124}{\frac{(0.95 * 7.9) - 2}{9.17} * 0.85 * 1.024^0}$$

= 2,203 lbs. of O<sub>2</sub>/day

At standard conditions, the TORNADO aerator transfers up to 2.5 lbs. / HP . For this system, an Oxygen Transfer rate of 1.65 lbs. O<sub>2</sub> / HP per hour is used, and 24 hours of daily operation is assumed.

$$\text{Oxygen power} = 2202 \text{ lbs. / day} / 1.65 \text{ lbs. / Hp per hour} * 24 \text{ hours per day} = 56 \text{ HP}$$

## Calculation of Mixing Requirements

Treatment efficiency is directly related to mixing. To completely mix and keep all biological solids in suspension, for a lagoon application, typically required the application of 0.08 HP per 1000 cubic feet of wastewater. Lower power to volume ratios produce different results as shown below.

| Cell | Complete Mix HP | Partial Mix HP | Odor Control HP |
|------|-----------------|----------------|-----------------|
| 1    | 176             | 88             | 35              |
| 2    | 145             | 72             | 29              |
| 3    | 98              | 49             | 19              |

## TOTAL POWER RECOMMENDATION:

The total power recommended is generally the greater of the mixing and oxygen requirements, AEROMIX recommends:

|        |   |   |                     |
|--------|---|---|---------------------|
| Cell 1 | - | - | HP TORNADO Aerators |
| Cell 2 | - | - | HP TORNADO Aerators |
| Cell 3 | - | - | HP TORNADO Aerators |





**AEROMIX Systems, Inc.**  
2611 North Second Street  
Minneapolis, MN 55411 USA  
Within USA: 1-800-879-3677 Phone: 612-521-8519 Fax 612-521-1455  
E-mail: aeromix@aeromix.com

**Lagoon Sizing Calculation using TORNADO Aerators**  
**Prepared for: LPID Lagoon**  
April 14, 2004

**Design Criteria**

To convert mg/l into lbs. / day, use the following formula: mg/l \* 8.34 \* Daily flow (MGD)

|                         |                              |                |
|-------------------------|------------------------------|----------------|
| Flow :                  | 0.35 million gallons per day |                |
| BOD demand:             | 250 mg/l converts to:        | 729 lbs. / day |
| TKN :                   | 0 lbs. / day                 |                |
| Total Suspended Solids: | 0 mg/l converts to:          | 0 lbs. / day   |

The basin volume is found using the following equation:

$$V = D/3(As + Ab + \text{square root}(As * Ab))$$

Where:

V = Cell volume in cubic feet      D = water depth  
As = surface area      Ab = bottom area

Detention time is found by dividing volume by daily flow.

|                        | Cell 1               | Cell 2               | Cell 3               |
|------------------------|----------------------|----------------------|----------------------|
| <b>Width:</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Length</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Depth:</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Volume:</b>         | 2,205,730 cubic feet | 1,818,055 cubic feet | 1,229,861 cubic feet |
| <b>Capacity</b>        | 16,498,860 Gallons   | 13,599,051 Gallons   | 9,199,360 Gallons    |
| <b>Detention time:</b> | 47.14 Days           | 38.85 Days           | 26.28 Days           |

**Calculations of Oxygen Requirements**

This application is sized using 2 lbs. of oxygen per lbs. of BOD, and 4.6 lbs. of oxygen per lbs. of TKN (under working conditions). A residual oxygen level of 2 mg/l will be maintained in the basin at all times.

**BOD Oxygen requirement calculation.**

729 lbs. of BOD/day x 2 lbs. of O<sub>2</sub> / lbs. BOD = 1458 lbs. O<sub>2</sub>/day.

**TKN Oxygen requirement calculation:**

0 lbs. of TKN / day x 4.6 lbs. of O<sub>2</sub> / lbs. TKN = 0 lbs. O<sub>2</sub>/day

**Total Oxygen required per day is the total of the BOD and TKN demands.**

1458 lbs. / day BOD + 0 lbs. / day TKN = 1458 lbs. of oxygen per day (under field conditions).

**AEROMIX Systems, Inc. TORNADO Sizing Calculations for:**  
**LPID Lagoon**

LPID 23

*Design Study Report*

*Lagoon Aerators Cell No. 1*

Oxygen transfer rates for aerators are reported under standard conditions. In order to make proper comparisons under field conditions, Total Oxygen Requirement (TOR) should be converted to Standard Condition Total Oxygen Requirement (STOR). Conversion from field conditions can be accomplished with the following equation:

$$No = \frac{N}{\frac{Beta * C_{walt} - Cl}{9.17} * Alpha * 1.024^{(T-20)}}$$

Where:

|                                                           |                    |
|-----------------------------------------------------------|--------------------|
| No = STOR lbs. / day                                      |                    |
| N = TOR =                                                 | 1,458 lbs. per day |
| Beta = Salinity, surface tension factors =                | 0.95               |
| C <sub>walt</sub> = Saturation at given altitude & temp = | 7.90               |
| Cl = Residual oxygen =                                    | 2.00 mg/l          |
| Alpha = Oxygen transfer correction factor =               | 0.85               |
| T = Operating temperature (68 degrees F)                  | 20 degrees C       |

$$= \frac{1458}{\frac{(0.95 * 7.9) - 2}{9.17 \text{ mg/l}} * 0.85 * 1.024^0}$$

= 2,857 lbs. of O<sub>2</sub>/day

At standard conditions, the TORNADO aerator transfers up to 2.5 lbs. / HP . For this system, an Oxygen Transfer rate of 1.65 lbs. O<sub>2</sub> / HP per hour is used, and 24 hours of daily operation is assumed.

**Oxygen power = 2857 lbs. / day / 1.65 lbs. / Hp per hour \* 24 hours per day = 72 HP**

**Calculation of Mixing Requirements**

Treatment efficiency is directly related to mixing. To completely mix and keep all biological solids in suspension, for a lagoon application, typically required the application of 0.08 HP per 1000 cubic feet of wastewater. Lower power to volume ratios produce different results as shown below.

| Cell | Complete Mix HP | Partial Mix HP | Odor Control HP |
|------|-----------------|----------------|-----------------|
| 1    | 176             | 88             | 35              |
| 2    | 145             | 72             | 29              |
| 3    | 98              | 49             | 19              |

**TOTAL POWER RECOMMENDATION:**

The total power recommended is generally the greater of the mixing and oxygen requirements, AEROMIX recommends:

|        |   |   |                     |
|--------|---|---|---------------------|
| Cell 1 | — | — | HP TORNADO Aerators |
| Cell 2 | — | — | HP TORNADO Aerators |
| Cell 3 | — | — | HP TORNADO Aerators |



**AEROMIX Systems, Inc.**  
2611 North Second Street  
Minneapolis, MN 55411 USA  
Within USA: 1-800-879-3677 Phone: 612-521-8519 Fax 612-521-1455  
E-mail: aeromix@aeromix.com

**Lagoon Sizing Calculation using TORNADO Aerators**  
**Prepared for: LPID Lagoon**  
April 14, 2004

**Design Criteria**

To convert mg/l into lbs. / day, use the following formula:  $\text{mg/l} \times 8.34 \times \text{Daily flow (MGD)}$

|                         |                              |                |
|-------------------------|------------------------------|----------------|
| Flow :                  | 0.44 million gallons per day |                |
| BOD demand:             | 250 mg/l converts to:        | 917 lbs. / day |
| TKN :                   | 0 lbs. / day                 |                |
| Total Suspended Solids: | 0 mg/l converts to:          | 0 lbs. / day   |

The basin volume is found using the following equation:

$$V = D/3(As + Ab + \text{square root}(As * Ab))$$

Where:

V = Cell volume in cubic feet

D = water depth

As = surface area

Ab = bottom area

Detention time is found by dividing volume by daily flow.

|                        | Cell 1               | Cell 2               | Cell 3               |
|------------------------|----------------------|----------------------|----------------------|
| <b>Width:</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Length</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Depth:</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Volume:</b>         | 2,205,730 cubic feet | 1,818,055 cubic feet | 1,229,861 cubic feet |
| <b>Capacity</b>        | 16,498,860 Gallons   | 13,599,051 Gallons   | 9,199,360 Gallons    |
| <b>Detention time:</b> | 37.50 Days           | 30.91 Days           | 20.91 Days           |

**Calculations of Oxygen Requirements**

This application is sized using 2 lbs. of oxygen per lbs. of BOD, and 4.6 lbs. of oxygen per lbs. of TKN (under working conditions). A residual oxygen level of 2 mg/l will be maintained in the basin at all times.

**BOD Oxygen requirement calculation.**

917 lbs. of BOD/day x 2 lbs. of O<sub>2</sub> / lbs. BOD = 1834 lbs. O<sub>2</sub>/day.

**TKN Oxygen requirement calculation:**

0 lbs. of TKN / day x 4.6 lbs. of O<sub>2</sub> / lbs. TKN = 0 lbs. O<sub>2</sub>/day

**Total Oxygen required per day is the total of the BOD and TKN demands.**

1834 lbs. / day BOD + 0 lbs. / day TKN = 1834 lbs. of oxygen per day (under field conditions).

# AEROMIX Systems, Inc. TORNADO Sizing Calculations for:

LPID Lagoon

LPID 23

## Design Study Report

### Lagoon Aerators Cell No. 1

Oxygen transfer rates for aerators are reported under standard conditions. In order to make proper comparisons under field conditions, Total Oxygen Requirement (TOR) should be converted to Standard Condition Total Oxygen Requirement (STOR). Conversion from field conditions can be accomplished with the following equation:

$$No = \frac{N}{\frac{Beta * C_{walt} - Cl}{9.17} * Alpha * 1.024^{(T-20)}}$$

Where:

No = STOR lbs. / day  
N = TOR = 1,834 lbs. per day  
Beta = Salinity, surface tension factors = 0.95  
C<sub>walt</sub> = Saturation at given altitude & temp = 7.90  
Cl = Residual oxygen = 2.00 mg/l  
Alpha = Oxygen transfer correction factor = 0.85  
T = Operating temperature (68 degrees F) 20 degrees C

$$= \frac{1834}{\frac{(0.95 * 7.9) - 2}{9.17} * 0.85 * 1.024^0}$$

= 3,594 lbs. of O<sub>2</sub>/day

At standard conditions, the TORNADO aerator transfers up to 2.5 lbs. / HP . For this system, an Oxygen Transfer rate of 1.65 lbs. O<sub>2</sub> / HP per hour is used, and 24 hours of daily operation is assumed.

$$\text{Oxygen power} = 3594 \text{ lbs. / day} / 1.65 \text{ lbs. / Hp per hour} * 24 \text{ hours per day} = 91 \text{ HP}$$

## Calculation of Mixing Requirements

Treatment efficiency is directly related to mixing. To completely mix and keep all biological solids in suspension, for a lagoon application, typically required the application of 0.08 HP per 1000 cubic feet of wastewater. Lower power to volume ratios produce different results as shown below.

| Cell | Complete Mix HP | Partial Mix HP | Odor Control HP |
|------|-----------------|----------------|-----------------|
| 1    | 176             | 88             | 35              |
| 2    | 145             | 72             | 29              |
| 3    | 98              | 49             | 19              |

## TOTAL POWER RECOMMENDATION:

The total power recommended is generally the greater of the mixing and oxygen requirements, AEROMIX recommends:

|        |   |   |                     |
|--------|---|---|---------------------|
| Cell 1 | = | = | HP TORNADO Aerators |
| Cell 2 | = | = | HP TORNADO Aerators |
| Cell 3 | = | = | HP TORNADO Aerators |





**AEROMIX Systems, Inc.**  
2611 North Second Street  
Minneapolis, MN 55411 USA  
Within USA: 1-800-879-3677 Phone: 612-521-8519 Fax 612-521-1455  
E-mail: aeromix@aeromix.com

**Lagoon Sizing Calculation using TORNADO Aerators**  
**Prepared for: LPID Lagoon**  
April 14, 2004

**Design Criteria**

To convert mg/l into lbs. / day, use the following formula: mg/l \*8.34\*Daily flow (MGD)

|                         |                              |                 |
|-------------------------|------------------------------|-----------------|
| Flow :                  | 0.53 million gallons per day |                 |
| BOD demand:             | 250 mg/l converts to:        | 1105 lbs. / day |
| TKN :                   | 0 lbs. / day                 |                 |
| Total Suspended Solids: | 0 mg/l converts to:          | 0 lbs. / day    |

The basin volume is found using the following equation:

$$V = D/3(As + Ab + \text{square root}(As * Ab))$$

Where:

V = Cell volume in cubic feet      D = water depth  
As = surface area      Ab = bottom area

Detention time is found by dividing volume by daily flow.

|                        | Cell 1               | Cell 2               | Cell 3               |
|------------------------|----------------------|----------------------|----------------------|
| <b>Width:</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Length</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Depth:</b>          | 0.0 feet             | - feet               | - feet               |
| <b>Volume:</b>         | 2,205,730 cubic feet | 1,818,055 cubic feet | 1,229,861 cubic feet |
| <b>Capacity</b>        | 16,498,860 Gallons   | 13,599,051 Gallons   | 9,199,360 Gallons    |
| <b>Detention time:</b> | 31.13 Days           | 25.66 Days           | 17.36 Days           |

**Calculations of Oxygen Requirements**

This application is sized using 2 lbs. of oxygen per lbs. of BOD, and 4.6 lbs. of oxygen per lbs. of TKN (under working conditions). A residual oxygen level of 2 mg/l will be maintained in the basin at all times.

**BOD Oxygen requirement calculation.**

1105 lbs. of BOD/day x 2 lbs. of O2 / lbs. BOD = 2210 lbs. O2/day.

**TKN Oxygen requirement calculation:**

0 lbs. of TKN / day x 4.6 lbs. of O2 / lbs. TKN = 0 lbs. O2/day

**Total Oxygen required per day is the total of the BOD and TKN demands.**

2210 lbs. / day BOD + 0 lbs. / day TKN = 2210 lbs. of oxygen per day (under field conditions).

**AEROMIX Systems, Inc. TORNADO Sizing Calculations for:**  
**LPID Lagoon**

LPID 23

Design Study Report

Lagoon Aerators Cell No. 1

Oxygen transfer rates for aerators are reported under standard conditions. In order to make proper comparisons under field conditions, Total Oxygen Requirement (TOR) should be converted to Standard Condition Total Oxygen Requirement (STOR). Conversion from field conditions can be accomplished with the following equation:

$$No = \frac{N}{\frac{Beta * C_{walt} - Cl}{9.17} * Alpha * 1.024^{(T-20)}}$$

Where:

No = STOR lbs. / day  
 N = TOR = 2,210 lbs. per day  
 Beta = Salinity, surface tension factors = 0.95  
 C<sub>walt</sub> = Saturation at given altitude & temp = 7.90  
 Cl = Residual oxygen = 2.00 mg/l  
 Alpha = Oxygen transfer correction factor = 0.85  
 T = Operating temperature (68 degrees F) 20 degrees C

$$= \frac{2210}{\frac{(0.95 * 7.9) - 2}{9.17 \text{ mg/l}} * 0.85 * 1.024^0}$$

= 4,331 lbs. of O<sub>2</sub>/day

At standard conditions, the TORNADO aerator transfers up to 2.5 lbs. / HP . For this system, an Oxygen Transfer rate of 1.65 lbs. O<sub>2</sub> / HP per hour is used, and 24 hours of daily operation is assumed.

**Oxygen power = 4330 lbs. / day / 1.65 lbs. / Hp per hour \* 24 hours per day = 109 HP**

**Calculation of Mixing Requirements**

Treatment efficiency is directly related to mixing. To completely mix and keep all biological solids in suspension, for a lagoon application, typically required the application of 0.08 HP per 1000 cubic feet of wastewater. Lower power to volume ratios produce different results as shown below.

| Cell | Complete Mix HP | Partial Mix HP | Odor Control HP |
|------|-----------------|----------------|-----------------|
| 1    | 176             | 88             | 35              |
| 2    | 145             | 72             | 29              |
| 3    | 98              | 49             | 19              |

**TOTAL POWER RECOMMENDATION:**

The total power recommended is generally the greater of the mixing and oxygen requirements, AEROMIX recommends:

|        |   |   |                     |
|--------|---|---|---------------------|
| Cell 1 | - | - | HP TORNADO Aerators |
| Cell 2 | - | - | HP TORNADO Aerators |
| Cell 3 | - | - | HP TORNADO Aerators |



**AEROMIX Systems, Inc.**  
2611 North Second Street  
Minneapolis, MN 55411 USA  
Within USA: 1-800-879-3677 Phone: 612-521-8519 Fax 612-521-1455  
E-mail: aeromix@aeromix.com

**Lagoon Sizing Calculation using TORNADO Aerators**  
**Prepared for: LPID Lagoon**  
April 14, 2004

**Design Criteria**

To convert mg/l into lbs. / day, use the following formula:  $\text{mg/l} \times 8.34 \times \text{Daily flow (MGD)}$

|                         |                              |                 |
|-------------------------|------------------------------|-----------------|
| Flow :                  | 1.31 million gallons per day |                 |
| BOD demand:             | 250 mg/l converts to:        | 2731 lbs. / day |
| TKN :                   | 0 lbs. / day                 |                 |
| Total Suspended Solids: | 0 mg/l converts to:          | 0 lbs. / day    |

The basin volume is found using the following equation:

$$V = D/3(As + Ab + \text{square root}(As * Ab))$$

Where:

V = Cell volume in cubic feet      D = water depth  
As = surface area      Ab = bottom area

Detention time is found by dividing volume by daily flow.

|                 | Cell 1               | Cell 2               | Cell 3               |
|-----------------|----------------------|----------------------|----------------------|
| Width:          | 0.0 feet             | - feet               | - feet               |
| Length          | 0.0 feet             | - feet               | - feet               |
| Depth:          | 0.0 feet             | - feet               | - feet               |
| Volume:         | 2,205,730 cubic feet | 1,818,055 cubic feet | 1,229,861 cubic feet |
| Capacity        | 16,498,860 Gallons   | 13,599,051 Gallons   | 9,199,360 Gallons    |
| Detention time: | 12.59 Days           | 10.38 Days           | 7.02 Days            |

**Calculations of Oxygen Requirements**

This application is sized using 2 lbs. of oxygen per lbs. of BOD, and 4.6 lbs. of oxygen per lbs. of TKN (under working conditions). A residual oxygen level of 2 mg/l will be maintained in the basin at all times.

**BOD Oxygen requirement calculation.**

2731 lbs. of BOD/day x 2 lbs. of O<sub>2</sub> / lbs. BOD = 5462 lbs. O<sub>2</sub>/day.

**TKN Oxygen requirement calculation:**

0 lbs. of TKN / day x 4.6 lbs. of O<sub>2</sub> / lbs. TKN = 0 lbs. O<sub>2</sub>/day

**Total Oxygen required per day is the total of the BOD and TKN demands.**

5462 lbs. / day BOD + 0 lbs. / day TKN = 5462 lbs. of oxygen per day (under field conditions).

**AEROMIX Systems, Inc. TORNADO Sizing Calculations for:**  
**LPID Lagoon**

LPID 23

Design Study Report

Lagoon Aerators Cell No. 1

Oxygen transfer rates for aerators are reported under standard conditions. In order to make proper comparisons under field conditions, Total Oxygen Requirement (TOR) should be converted to Standard Condition Total Oxygen Requirement (STOR). Conversion from field conditions can be accomplished with the following equation:

$$No = \frac{N}{\frac{Beta * C_{walt} - Cl}{9.17} * Alpha * 1.024^{(T-20)}}$$

Where:

No = STOR lbs. / day  
 N = TOR = 5,462 lbs. per day  
 Beta = Salinity, surface tension factors = 0.95  
 C<sub>walt</sub> = Saturation at given altitude & temp = 7.90  
 Cl = Residual oxygen = 2.00 mg/l  
 Alpha = Oxygen transfer correction factor = 0.85  
 T = Operating temperature (68 degrees F) 20 degrees C

$$= \frac{5462}{\frac{(0.95 * 7.9) - 2}{9.17 \text{ mg/l}} * 0.85 * 1.024^0}$$

= 10,704 lbs. of O<sub>2</sub>/day

At standard conditions, the TORNADO aerator transfers up to 2.5 lbs. / HP . For this system, an Oxygen Transfer rate of 1.65 lbs. O<sub>2</sub> / HP per hour is used, and 24 hours of daily operation is assumed.

**Oxygen power = 10703 lbs. / day / 1.65 lbs. / Hp per hour \* 24 hours per day = 270 HP**

**Calculation of Mixing Requirements**

Treatment efficiency is directly related to mixing. To completely mix and keep all biological solids in suspension, for a lagoon application, typically required the application of 0.08 HP per 1000 cubic feet of wastewater. Lower power to volume ratios produce different results as shown below.

| Cell | Complete Mix HP | Partial Mix HP | Odor Control HP |
|------|-----------------|----------------|-----------------|
| 1    | 176             | 88             | 35              |
| 2    | 145             | 72             | 29              |
| 3    | 98              | 49             | 19              |

**TOTAL POWER RECOMMENDATION:**

The total power recommended is generally the greater of the mixing and oxygen requirements, AEROMIX recommends:

|        |   |   |                     |
|--------|---|---|---------------------|
| Cell 1 | — | — | HP TORNADO Aerators |
| Cell 2 | — | — | HP TORNADO Aerators |
| Cell 3 | — | — | HP TORNADO Aerators |




**APPENDIX E**  
**MANUFACTURER'S DATA**

| REV. | DESCRIPTION        | DATE | CHK. |
|------|--------------------|------|------|
| B    | MINOR TEXT CHANGES | 2/03 | JCM  |

UNITS GIVEN IN FEET (METERS)

| SIZE     | A         | B       | C         | D        | R        | S         | T         | U         |
|----------|-----------|---------|-----------|----------|----------|-----------|-----------|-----------|
| 2-5HP    | 2 (0.6)   | 3 (0.9) | 5 (1.5)   | 7 (2.1)  | 6 (1.8)  | 20 (6.1)  | 50 (15)   | 80 (24)   |
| 7.5-10HP | 2 (0.6)   | 4 (1.2) | 6 (1.8)   | 8 (2.4)  | 7 (2.1)  | 23 (7)    | 55 (16.5) | 95 (28.5) |
| 20-25HP  | 2.5 (0.8) | 5 (1.5) | 7.5 (2.3) | 10 (3.1) | 10 (3.1) | 28 (8.5)  | 60 (18)   | 110 (33)  |
| 30-40HP  | 3 (0.9)   | 6 (1.8) | 9 (2.7)   | 12 (4.2) | 12 (4.2) | 32 (9.6)  | 70 (21)   | 130 (39)  |
| 50-100HP | 6 (1.8)   | 13 (4)  | 19 (5.8)  | 25 (7.6) | 15 (4.6) | 45 (13.5) | 110 (33)  | 200 (60)  |

-  10-30 FT/MIN (3-9 M/MIN)  
 30-60 FT/MIN (9-18 M/MIN)  
 60-100 FT/MIN (18-31 M/MIN)  
 100-120 FT/MIN (31-37 M/MIN)




| ITEM                                                                                                                                                                                                      | DWG.#            | PART# | DESCRIPTION                                                                                                                     | QTY                   |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|-------|---------------------------------------------------------------------------------------------------------------------------------|-----------------------|
| PARTS LIST                                                                                                                                                                                                |                  |       |                                                                                                                                 |                       |
| <br>2311 North Second Street<br>Minneapolis, Minnesota 55411 U.S.A.<br>612/821-8818 800/878-3677<br>FAX 612 821-1405 |                  |       | TITLE:<br>TORNADO MIXING<br>PROFILE (SIDE)                                                                                      |                       |
| DATE:<br>3-22-97                                                                                                                                                                                          | DRAWN BY:<br>WES |       | PATENTS:<br>AEROSOL PRODUCTS MAY BE COVERED BY ONE OR MORE PATENTS OR PATENTS<br>PENDING. THESE REMAIN THE PROPERTY OF AEROSOL. | DRAWING#:<br>AT5MIXPT |

| REV. | DESCRIPTION        | DATE | CHK. |
|------|--------------------|------|------|
| B    | MINDR TEXT CHANGES | 2/03 | JCM  |

UNITS GIVEN IN FEET (METERS)

| SIZE     | A        | B         | C         | D        | R         | S         | T         | U         |
|----------|----------|-----------|-----------|----------|-----------|-----------|-----------|-----------|
| 2-5HP    | 25 (7.5) | 10 (3)    | 20 (6)    | 5 (1.5)  | 25 (7.5)  | 20 (6.1)  | 50 (15)   | 80 (24)   |
| 7.5-10HP | 60 (18)  | 21 (6.3)  | 38 (11.4) | 6 (1.8)  | 48 (14.4) | 23 (7)    | 55 (16.5) | 95 (28.5) |
| 20-25HP  | 100 (30) | 38 (11.4) | 50 (15)   | 7 (2.1)  | 70 (21)   | 28 (8.5)  | 60 (18)   | 110 (33)  |
| 30-40HP  | 140 (42) | 60 (18)   | 70 (21)   | 8 (2.4)  | 92 (27.6) | 32 (9.6)  | 70 (21)   | 130 (39)  |
| 50-100HP | 180 (54) | 80 (24)   | 100 (30)  | 12 (3.6) | 140 (42)  | 45 (13.5) | 110 (33)  | 200 (60)  |

-  5-15 FT/MIN (1.5-4.5 M/MIN)  
 10-30 FT/MIN (3-9 M/MIN)  
 30-60 FT/MIN (9-18 M/MIN)  
 100-120 FT/MIN (31-37 M/MIN)



| ITEM       | DWG.# | PART# | DESCRIPTION | QTY |
|------------|-------|-------|-------------|-----|
| PARTS LIST |       |       |             |     |



2811 North Second Street  
 Minneapolis, MN 55412  
 612/521-1010  
 FAX 612 521-1458

TITLE:  
 TORNADO MIXING  
 PROFILE (TOP)

DATE: 4-21-98  
 DRAWN BY: WES  
 PATENTS: APPROVE PRODUCTS MAY BE COPIED BY ONE OR MORE INDIVIDUALS OR FIRMS FOR PERSONAL USE ONLY. THE RIGHTS OF INVENTOR ARE RESERVED.  
 DRAWING: ATSMIXTT

## APPENDIX E: HISTORICAL FLOW AND SAMPLING DATA

- Raw Data Sheets

# Lake Point Improvement District

|           |     | Flows (mgd) |       |          |       | Influent |     |         |     | Effluent |     |
|-----------|-----|-------------|-------|----------|-------|----------|-----|---------|-----|----------|-----|
|           |     | Influent    |       | Effluent |       | mg/l     |     | Lbs/day |     | mg/l     |     |
|           |     | Avg         | Max   | Avg      | Max   | BOD      | TSS | BOD     | TSS | BOD      | TSS |
| 2014      | Jan | 0.214       | 0.229 | 0.203    | 0.209 | 99       | 77  | 177     | 137 | 13       | 5   |
|           | Feb | 0.256       | 0.279 | 0.217    | 0.220 | 122      | 153 | 260     | 327 | 26       | 4   |
|           | Mar | 0.243       | 0.294 | 0.197    | 0.230 | 102      | 152 | 207     | 308 | 15       | 13  |
|           | Apr | 0.241       | 0.271 | 0.108    | 0.172 | 57       | 95  | 115     | 191 | 5        | 10  |
|           | May | 0.210       | 0.241 | 0.155    | 0.177 | 190      | 214 | 333     | 375 | 9        | 6   |
|           | Jun | 0.194       | 0.200 | 0.124    | 0.144 | 125      | 147 | 202     | 238 | 13       | 23  |
|           | Jul | 0.199       | 0.206 | 0.062    | 0.119 | 98       | 109 | 163     | 181 | 13       | 52  |
|           | Aug | 0.188       | 0.216 | 0.151    | 0.160 | 123      | 122 | 193     | 191 | 5        | 32  |
|           | Sep | 0.183       | 0.188 | 0.137    | 0.159 | 177      | 127 | 270     | 194 | 5        | 52  |
|           | Oct | 0.155       | 0.208 | 0.141    | 0.144 | 190      | 199 | 246     | 257 | 5        | 45  |
|           | Nov | 0.144       | 0.161 | 0.063    | 0.090 | 184      | 238 | 221     | 286 | 5        | 4   |
|           | Dec | 0.160       | 0.218 | 0.145    | 0.202 | 197      | 113 | 263     | 151 | 13       | 15  |
|           | Avg | 0.199       | 0.226 | 0.142    | 0.169 | 139      | 146 | 221     | 236 | 11       | 22  |
|           | Max | 0.256       | 0.294 | 0.217    | 0.230 | 197      | 238 | 333     | 375 | 26       | 52  |
|           | Min | 0.144       | 0.161 | 0.062    | 0.090 | 57       | 77  | 115     | 137 | 5        | 4   |
| % Loading |     | 50.7%       |       |          |       |          |     | 34%     | 36% |          |     |
| 2015      | Jan | 0.162       | 0.181 | 0.168    | 0.197 | 109      | 135 | 147     | 204 | 16       | 23  |
|           | Feb | 0.178       | 0.208 | 0.099    | 0.108 | 173      | 170 | 257     | 295 | 15       | 18  |
|           | Mar | 0.207       | 0.216 | 0.037    | 0.038 | 119      | 131 | 205     | 236 | 7        | 37  |
|           | Apr | 0.191       | 0.199 | 0.042    | 0.124 | 107      | 138 | 170     | 229 | 16       | 22  |
|           | May | 0.213       | 0.270 | 0.153    | 0.173 | 108      | 100 | 192     | 225 | 5        | 11  |
|           | Jun | 0.200       | 0.219 | 0.059    | 0.088 | 195      | 286 | 325     | 522 | 11       | 21  |
|           | Jul | 0.174       | 0.190 | 0.018    | 0.029 | 185      | 220 | 268     | 349 | 5        | 14  |
|           | Aug | 0.158       | 0.209 | 0.040    | 0.042 | 191      | 201 | 252     | 350 | 5        | 11  |
|           | Sep | 0.171       | 0.174 | 0.042    | 0.069 | 188      | 271 | 268     | 393 | 15       | 32  |
|           | Oct | 0.151       | 0.177 | 0.082    | 0.102 | 88       | 173 | 111     | 255 | 8        | 12  |
|           | Nov | 0.154       | 0.154 | 0.110    | 0.173 | 94       | 170 | 121     | 218 | 7        | 45  |
|           | Dec | 0.160       | 0.177 | 0.160    | 0.207 | 157      | 234 | 210     | 345 | 5        | 8   |
|           | Avg | 0.177       | 0.198 | 0.084    | 0.113 | 143      | 186 | 211     | 302 | 10       | 21  |
|           | Max | 0.213       | 0.270 | 0.168    | 0.207 | 195      | 286 | 325     | 522 | 16       | 45  |
|           | Min | 0.151       | 0.154 | 0.018    | 0.029 | 88       | 100 | 111     | 204 | 5        | 8   |
| % Loading |     | 45.0%       |       |          |       |          |     | 32%     | 46% |          |     |
| 2016      | Jan | 0.160       | 0.165 | 0.153    | 0.202 | 106      | 185 | 141     | 255 | 5        | 11  |
|           | Feb | 0.166       | 0.176 | 0.170    | 0.202 | 185      | 138 | 256     | 203 | 10       | 16  |
|           | Mar | 0.192       | 0.208 | 0.164    | 0.166 | 106      | 228 | 170     | 396 | 12       | 22  |
|           | Apr | 0.194       | 0.243 | 0.135    | 0.209 | 132      | 203 | 214     | 411 | 12       | 7   |
|           | May | 0.207       | 0.221 | 0.114    | 0.122 | 93       | 150 | 161     | 276 | 11       | 24  |
|           | Jun | 0.184       | 0.195 | 0.036    | 0.079 | 117      | 75  | 180     | 122 | 20       | 18  |
|           | Jul | 0.154       | 0.187 | 0.000    | 0.000 | 243      | 188 | 312     | 293 | 0        | 0   |
|           | Aug | 0.147       | 0.156 | 0.000    | 0.000 | 160      | 159 | 196     | 207 | 0        | 0   |
|           | Sep | 0.159       | 0.174 | 0.000    | 0.000 | 179      | 151 | 237     | 219 | 0        | 0   |
|           | Oct | 0.168       | 0.197 | 0.000    | 0.080 | 185      | 141 | 259     | 232 | 10       | 16  |
|           | Nov | 0.159       | 0.165 | 0.094    | 0.105 | 231      | 149 | 306     | 205 | 7        | 10  |
|           | Dec | 0.146       | 0.155 | 0.111    | 0.124 | 212      | 150 | 258     | 194 | 16       | 20  |
|           | Avg | 0.170       | 0.187 | 0.081    | 0.107 | 162      | 160 | 224     | 251 | 9        | 12  |
|           | Max | 0.207       | 0.243 | 0.170    | 0.209 | 243      | 228 | 312     | 411 | 20       | 24  |
|           | Min | 0.146       | 0.155 | 0.000    | 0.000 | 93       | 75  | 141     | 122 | 0        | 0   |
| % Loading |     | 43.3%       |       |          |       |          |     | 34%     | 38% |          |     |
|           |     |             |       |          |       |          |     | 48%     | 63% |          |     |



# Lake Point Improvement District

|                  | Flows (mgd) |            |            |            | Influent   |            |            |            | Effluent   |            |
|------------------|-------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
|                  | Influent    |            | Effluent   |            | mg/l       |            | Lbs/day    |            | mg/l       |            |
|                  | <u>Avg</u>  | <u>Max</u> | <u>Avg</u> | <u>Max</u> | <u>BOD</u> | <u>TSS</u> | <u>BOD</u> | <u>TSS</u> | <u>BOD</u> | <u>TSS</u> |
| 2017 Jan         | 0.158       | 0.167      | 0.130      | 0.144      | 193        | 160        | 254        | 223        | 15         | 38         |
| Feb              | 0.165       | 0.170      | 0.131      | 0.137      | 171        | 144        | 235        | 204        | 17         | 36         |
| Mar              | 0.193       | 0.211      | 0.081      | 0.130      | 172        | 167        | 277        | 294        | 21         | 29         |
| Apr              | 0.256       | 0.266      | 0.182      | 0.216      | 100        | 74         | 214        | 164        | 26         | 42         |
| May              | 0.235       | 0.256      | 0.158      | 0.205      | 242        | 257        | 474        | 549        | 31         | 30         |
| Jun              | 0.209       | 0.243      | 0.066      | 0.109      | 145        | 179        | 253        | 363        | 19         | 18         |
| Jul              | 0.163       | 0.183      | 0.013      | 0.036      | 171        | 194        | 232        | 296        | 15         | 91         |
| Aug              | 0.157       | 0.160      | 0.000      | 0.000      | 290        | 332        | 380        | 443        | 0          | 0          |
| Sep              | 0.159       | 0.175      | 0.031      | 0.088      | 236        | 204        | 313        | 298        | 11         | 11         |
| Oct              | 0.178       | 0.178      | 0.038      | 0.046      | 186        | 180        | 276        | 267        | 15         | 45         |
| Nov              | 0.147       | 0.154      | 0.106      | 0.130      | 193        | 202        | 237        | 259        | 16         | 20         |
| Dec              | 0.180       | 0.277      | 0.125      | 0.130      | 125        | 90         | 188        | 208        | 15         | 16         |
| <b>Avg</b>       | 0.183       | 0.203      | 0.088      | 0.114      | 185        | 182        | 278        | 297        | 17         | 31         |
| <b>Max</b>       | 0.256       | 0.277      | 0.182      | 0.216      | 290        | 332        | 474        | 549        | 31         | 91         |
| <b>Min</b>       | 0.147       | 0.154      | 0.000      | 0.000      | 100        | 74         | 188        | 164        | 0          | 0          |
| <b>% Loading</b> | 46.8%       |            |            |            |            |            | 42%        | 45%        |            |            |
|                  |             |            |            |            |            |            | 73%        | 84%        |            |            |
| 2018 Jan         | 0.161       | 0.164      | 0.143      | 0.158      | 146        | 161        | 196        | 216        | 17         | 14         |
| Feb              | 0.156       | 0.163      | 0.140      | 0.158      | 212        | 225        | 276        | 293        | 45         | 60         |
| Mar              | 0.190       | 0.213      | 0.139      | 0.151      | 255        | 220        | 404        | 349        | 33         | 24         |
| Apr              | 0.216       | 0.257      | 0.153      | 0.187      | 162        | 157        | 292        | 283        | 7          | 5          |
| May              | 0.216       | 0.230      | 0.144      | 0.151      | 312        | 339        | 562        | 611        | 10         | 14         |
| Jun              | 0.232       | 0.257      | 0.064      | 0.090      | 162        | 180        | 313        | 348        | 12         | 9          |
| Jul              | 0.216       | 0.236      | 0.038      | 0.047      | 193        | 191        | 348        | 344        | 9          | 4          |
| Aug              | 0.170       | 0.176      | 0.023      | 0.030      | 178        | 277        | 252        | 393        | 20         | 62         |
| Sep              | 0.154       | 0.174      | 0.019      | 0.022      | 198        | 205        | 254        | 263        | 27         | 44         |
| Oct              | 0.157       | 0.162      | 0.095      | 0.101      | 331        | 586        | 433        | 767        | 28         | 24         |
| Nov              | 0.155       | 0.158      | 0.107      | 0.129      | 180        | 153        | 233        | 198        | 12         | 23         |
| Dec              | 0.181       | 0.182      | 0.131      | 0.144      | 104        | 127        | 157        | 192        | 12         | 14         |
| <b>Avg</b>       | 0.184       | 0.198      | 0.100      | 0.114      | 203        | 235        | 310        | 355        | 19         | 25         |
| <b>Max</b>       | 0.232       | 0.257      | 0.153      | 0.187      | 331        | 586        | 562        | 767        | 45         | 62         |
| <b>Min</b>       | 0.154       | 0.158      | 0.019      | 0.022      | 104        | 127        | 157        | 192        | 7          | 4          |
| <b>% Loading</b> | 46.9%       |            |            |            |            |            | 47%        | 54%        |            |            |
|                  |             |            |            |            |            |            | 86%        | 117%       |            |            |
| 2019 Jan         | 0.156       | 0.170      | 0.194      | 0.202      | 227        | 290        | 295        | 377        | 21         | 14         |
| Feb              | 0.214       | 0.217      | 0.206      | 0.230      | 156        | 202        | 278        | 361        | 14         | 32         |
| Mar              | 0.235       | 0.318      | 0.220      | 0.230      | 126        | 218        | 247        | 427        | 25         | 11         |
| Apr              | 0.400       | 0.431      | 0.429      | 0.432      | 96         | 98         | 320        | 327        | 14         | 16         |
| May              | 0.395       | 0.434      | 0.256      | 0.259      | 82         | 119        | 270        | 392        | 10         | 9          |
| Jun              | 0.334       | 0.386      | 0.228      | 0.252      | 78         | 94         | 217        | 262        | 15         | 29         |
| Jul              | 0.279       | 0.293      | 0.101      | 0.113      | 144        | 238        | 335        | 554        | 17         | 61         |
| Aug              | 0.225       | 0.245      | 0.074      | 0.076      | 162        | 168        | 304        | 315        | 11         | 4          |
| Sep              | 0.214       | 0.226      | 0.074      | 0.108      | 131        | 118        | 234        | 211        | 27         | 32         |
| Oct              | 0.244       | 0.249      | 0.091      | 0.128      | 114        | 136        | 232        | 277        | 24         | 61         |
| Nov              | 0.245       | 0.260      | 0.180      | 0.198      | 119        | 131        | 243        | 268        | 29         | 43         |
| Dec              | 0.293       | 0.298      | 0.202      | 0.205      | 463        | 639        | 1131       | 1561       | 148        | 30         |
| <b>Avg</b>       | 0.270       | 0.294      | 0.188      | 0.203      | 158        | 204        | 342        | 444        | 30         | 29         |
| <b>Max</b>       | 0.400       | 0.434      | 0.429      | 0.432      | 463        | 639        | 1131       | 1561       | 148        | 61         |
| <b>Min</b>       | 0.156       | 0.170      | 0.074      | 0.076      | 78         | 94         | 217        | 211        | 10         | 4          |
| <b>% Loading</b> | 68.8%       |            |            |            |            |            | 52%        | 68%        |            |            |
|                  |             |            |            |            |            |            | 173%       | 239%       |            |            |

### Lake Point Improvement District

|               |  | Flows (mgd) |       |          |       | Influent |     |         |      | Effluent |     |
|---------------|--|-------------|-------|----------|-------|----------|-----|---------|------|----------|-----|
|               |  | Influent    |       | Effluent |       | mg/l     |     | Lbs/day |      | mg/l     |     |
|               |  | Avg         | Max   | Avg      | Max   | BOD      | TSS | BOD     | TSS  | BOD      | TSS |
| 2020 Jan      |  | 0.309       | 0.317 | 0.202    | 0.216 | 191      | 284 | 492     | 732  | 17       | 27  |
| Feb           |  | 0.337       | 0.422 | 0.23     | 0.24  | 171      | 142 | 481     | 399  | 17       | 39  |
| Mar           |  | 0.335       | 0.338 | 0.249    | 0.251 | 217      | 172 | 606     | 481  | 18       | 22  |
| Apr           |  | 0.356       | 0.375 | 0.243    | 0.245 | 168      | 205 | 499     | 609  | 29       | 67  |
| May           |  | 0.308       | 0.315 | 0.226    | 0.245 | 187      | 191 | 480     | 491  | 20       | 22  |
| Jun           |  | 0.304       | 0.346 | 0.179    | 0.18  | 133      | 199 | 337     | 505  | 34       | 43  |
| Jul           |  | 0.263       | 0.308 | 0.182    | 0.223 | 99       | 139 | 217     | 305  | 22       | 21  |
| Aug           |  | 0.257       | 0.278 | 0.099    | 0.108 | 200      | 100 | 429     | 214  | 20       | 30  |
| Sep           |  | 0.223       | 0.333 | 0.135    | 0.144 | 210      | 175 | 391     | 325  | 10       | 12  |
| Oct           |  | 0.303       | 0.352 | 0.188    | 0.22  | 233      | 160 | 589     | 404  | 12       | 16  |
| Nov           |  | 0.231       | 0.232 | 0.202    | 0.32  | 117      | 190 | 225     | 366  | 33       | 56  |
| Dec           |  | 0.230       | 0.232 | 0.251    | 0.259 | 287      | 309 | 551     | 593  | 27       | 32  |
| Avg           |  | 0.288       | 0.321 | 0.199    | 0.221 | 184      | 189 | 441     | 452  | 22       | 32  |
| Max           |  | 0.356       | 0.422 | 0.251    | 0.320 | 287      | 309 | 606     | 732  | 34       | 67  |
| Min           |  | 0.223       | 0.232 | 0.099    | 0.108 | 99       | 100 | 217     | 214  | 10       | 12  |
| YTD % Loading |  | 73.5%       |       |          |       |          |     | 67%     | 69%  |          |     |
|               |  |             |       |          |       |          |     | 93%     | 112% |          |     |

### Lake Point Improvement District

|               |  | Flows (mgd) |       |          |         | Influent |     |         |     | Effluent |     |
|---------------|--|-------------|-------|----------|---------|----------|-----|---------|-----|----------|-----|
|               |  | Influent    |       | Effluent |         | mg/l     |     | Lbs/day |     | mg/l     |     |
|               |  | Avg         | Max   | Avg      | Max     | BOD      | TSS | BOD     | TSS | BOD      | TSS |
| 2021 Jan      |  | 0.230       | 0.247 | 0.357    | 500     | 162      | 211 | 311     | 405 | 20       | 39  |
| Feb           |  | 0.240       | 0.264 | 0.374    | 0.41    | 213      | 248 | 426     | 496 | 23       | 86  |
| Mar           |  | 0.247       | 0.260 | 0.324    | 0.357   | 180      | 182 | 371     | 375 | 21       | 47  |
| Apr           |  | 0.249       | 0.259 | 0.357    | 0.403   | 217      | 181 | 451     | 376 | 19       | 38  |
| May           |  | 0.265       | 0.303 | 0.212    | 0.368   | 148      | 179 | 327     | 396 | 17       | 20  |
| Jun           |  | 0.213       | 0.248 | 0.119    | 0.190   | 231      | 205 | 410     | 364 | 35       | 31  |
| Jul           |  | 0.303       | 0.328 | 0.158    | 0.288   | 200      | 189 | 505     | 478 | 29       | 42  |
| Aug           |  | 0.310       | 0.314 | 0.217    | 0.230   | 131      | 180 | 339     | 465 | 29       | 93  |
| Sep           |  | 0.301       | 0.306 | 0.230    | 0.207   | 122      | 177 | 306     | 444 | 15       | 34  |
| Oct           |  | 0.301       | 0.335 | 0.274    | 0.302   | 180      | 186 | 452     | 467 | 33       | 20  |
| Nov           |  | 0.303       | 0.314 | 0.289    | 0.295   | 221      | 215 | 558     | 543 | 35       | 40  |
| Dec           |  |             |       |          |         |          |     |         |     |          |     |
| Avg           |  | 0.269       | 0.289 | 0.265    | 45.732  | 182      | 196 | 405     | 437 | 25       | 45  |
| Max           |  | 0.310       | 0.335 | 0.374    | 500.000 | 231      | 248 | 558     | 543 | 35       | 93  |
| Min           |  | 0.213       | 0.247 | 0.119    | 0.19    | 122      | 177 | 306     | 364 | 15       | 20  |
| YTD % Loading |  | 68.7%       |       |          |         |          |     | 62%     | 67% |          |     |
|               |  |             |       |          |         |          |     | 85%     | 83% |          |     |

### Lake Point Improvement District

|               |  | Flows (mgd) |       |          |       | Influent |     |         |      | Effluent |     |
|---------------|--|-------------|-------|----------|-------|----------|-----|---------|------|----------|-----|
|               |  | Influent    |       | Effluent |       | mg/l     |     | Lbs/day |      | mg/l     |     |
|               |  | Avg         | Max   | Avg      | Max   | BOD      | TSS | BOD     | TSS  | BOD      | TSS |
| 2022 Jan      |  | 0.308       | 0.339 | 0.324    | 0.36  | 107      | 202 | 275     | 519  | 13       | 27  |
| Feb           |  | 0.332       | 0.416 | 0.308    | 0.396 | 183      | 150 | 507     | 415  | 44       | 40  |
| Mar           |  | 0.403       | 0.655 | 0.368    | 0.382 | 129      | 187 | 434     | 629  | 31       | 41  |
| Apr           |  | 0.347       | 0.406 | 0.350    | 0.382 | 84       | 128 | 243     | 370  | 28       | 36  |
| May           |  | 0.339       | 0.416 | 0.321    | 0.346 | 171      | 223 | 483     | 630  | 21       | 51  |
| Jun           |  | 0.189       | 0.255 | 0.259    | 0.321 | 174      | 144 | 274     | 227  | 17       | 21  |
| Jul           |  | 0.297       | 0.401 | 0.147    | 0.179 | 227      | 229 | 562     | 567  | 5        | 31  |
| Aug           |  | 0.290       | 0.334 | 0.170    | 0.245 | 167      | 298 | 404     | 721  | 21       | 25  |
| Sep           |  | 0.277       | 0.294 | 0.183    | 0.208 | 154      | 196 | 356     | 453  | 22       | 32  |
| Oct           |  | 0.254       | 0.576 | 0.312    | 0.423 | 147      | 222 | 311     | 470  | 19       | 26  |
| Nov           |  | 0.298       | 0.460 | 0.121    | 0.134 | 165      | 176 | 410     | 437  | 25       | 18  |
| Dec           |  | 0.315       | 0.329 | 0.260    | 0.267 | 150      | 95  | 394     | 250  | 25       | 50  |
| Avg           |  | 0.304       | 0.407 | 0.260    | 0.304 | 155      | 188 | 388     | 474  | 23       | 33  |
| Max           |  | 0.403       | 0.655 | 0.368    | 0.423 | 227      | 298 | 562     | 721  | 44       | 51  |
| Min           |  | 0.189       | 0.255 | 0.147    | 0.179 | 84       | 128 | 243     | 227  | 5        | 21  |
| YTD % Loading |  | 77.6%       |       |          |       |          |     | 59%     | 72%  |          |     |
|               |  |             |       |          |       |          |     | 86%     | 110% |          |     |

### Lake Point Improvement District

|               |       | Flows (mgd) |            |            |            | Influent                                                              |            |            |            | Effluent   |            |
|---------------|-------|-------------|------------|------------|------------|-----------------------------------------------------------------------|------------|------------|------------|------------|------------|
|               |       | Influent    |            | Effluent   |            | mg/l                                                                  |            | Lbs/day    |            | mg/l       |            |
|               |       | <u>Avg</u>  | <u>Max</u> | <u>Avg</u> | <u>Max</u> | <u>BOD</u>                                                            | <u>TSS</u> | <u>BOD</u> | <u>TSS</u> | <u>BOD</u> | <u>TSS</u> |
| 2023          | Jan   | 0.440       | 0.456      | 0.299      | 0.0331     | 100                                                                   | 105        | 366.96     | 385.31     | 37         | 40         |
|               | Feb   | 0.389       | 0.409      | 0.342      | 0.0357     | 172                                                                   | 142        | 558.01     | 460.68     | 40         | 35         |
|               | Mar   | 0.546       | 0.564      | 0.383      | 0.418      | 124                                                                   | 122        | 564.65     | 555.54     | 27         | 6          |
|               | Apr   |             |            |            |            | 78                                                                    | 277        | 0.00       | 0.00       | 16         | 44         |
|               | May   | 0.409       | 0.644      | 0.124      | 0.311      | 101                                                                   | 109        | 344.52     | 371.81     | 16         | 11         |
|               | Jun   | 0.358       | 0.040      | 0.218      | 0.258      | 185                                                                   | 167        | 552.36     | 498.62     | 22         | 19         |
|               | Jul   | 0.357       | 0.395      | 0.161      | 0.172      | 197                                                                   | 241        | 586.54     | 717.55     | 35         | 64         |
|               | Aug   | 0.249       | 0.292      | 0.177      | 0.18       | 314                                                                   | 317        | 652.07     | 658.30     | 27         | 44         |
|               | Sep   | 0.224       | 0.309      | 0.169      | 0.18       | 259                                                                   | 216        | 483.85     | 403.52     | 23         | 44         |
|               | Oct   | 0.265       | 0.313      | 0.182      | 0.202      | 308                                                                   | 258        | 680.71     | 570.21     | 35         | 45         |
|               | Nov   | 0.271       | 0.397      | 0.223      | 0.245      | 157                                                                   | 250        | 354.84     | 565.04     | 11         | 30         |
|               | Dec   | 0.271       | 0.282      | 0.243      | 0.252      | 164                                                                   | 145        | 370.66     | 327.72     | 28         | 32         |
|               | Avg   | 0.344       | 0.373      | 0.229      | 0.208      | 180                                                                   | 196        | 459.60     | 459.52     | 26         | 35         |
| Max           | 0.546 | 0.644       | 0.383      | 0.418      | 314        | 317                                                                   | 680.71     | 717.55     | 40         | 64         |            |
| Min           | 0.224 | 0.040       | 0.124      | 0.033      | 78         | 105                                                                   | 0.00       | 0.00       | 11         | 6          |            |
| YTD % Loading |       | 87.6%       |            |            |            | <div><div>70%</div><div>70%</div><div>104%</div><div>110%</div></div> |            |            |            |            |            |
|               |       | 0.367       |            | 0.245      |            |                                                                       |            |            |            |            |            |
|               |       | 0.625       | 0.560      | 0.612      | 0.648      |                                                                       |            |            |            |            |            |

### Lake Point Improvement District

|               |     | Flows (mgd) |       |          |       | Influent |     | Lbs/day |         | Effluent |      |
|---------------|-----|-------------|-------|----------|-------|----------|-----|---------|---------|----------|------|
|               |     | Influent    |       | Effluent |       | mg/l     |     |         |         | mg/l     |      |
|               |     | Avg         | Max   | Avg      | Max   | BOD      | TSS | BOD     | TSS     | BOD      | TSS  |
| 2024          | Jan | 0.312       | 0.360 | 0.256    | 0.266 | 193      | 170 | 502.20  | 442.35  | 20       | 28   |
|               | Feb | 0.329       | 0.375 | 0.288    | 0.316 | 196      | 184 | 537.80  | 504.87  | 11       | 34   |
|               | Mar | 0.404       | 0.450 | 0.318    | 0.334 | 69       | 127 | 232.49  | 427.91  | 23       | 71   |
|               | Apr | 0.517       | 0.732 | 0.754    | 2.750 | 141      | 201 | 607.96  | 866.67  | 43       | 78   |
|               | May | 0.643       | 0.789 | 0.558    | 0.693 | 207      | 169 | 1110.06 | 906.28  | 27       | 31   |
|               | Jun | 0.511       | 0.634 | 0.251    | 0.317 | 113      | 338 | 481.58  | 1440.47 | 26       | 46   |
|               | Jul | 0.352       | 0.383 | 0.245    | 0.274 | 170      | 201 | 499.07  | 590.07  | 36       | 50   |
|               | Aug | 0.314       | 0.345 | 0.232    | 0.252 | 142      | 118 | 371.86  | 309.01  | 19       | 39   |
|               | Sep | 0.301       | 0.306 | 0.203    | 0.207 | 122      | 17  | 306.26  | 42.68   | 15       | 34   |
|               | Oct | 0.358       | 0.367 | 0.263    | 0.270 | 205      | 248 | 612.07  | 740.46  | 18       | 27   |
|               | Nov | 0.370       | 0.407 | 0.292    | 0.302 | 205      | 213 | 632.59  | 657.28  | 19       | 30   |
|               | Dec | 0.353       | 0.370 | 0.312    | 0.327 | 378      | 177 | 1112.84 | 521.09  | 21       | 44   |
|               | Avg | 0.397       | 0.460 | 0.331    | 0.526 | 178      | 180 | 590.73  | 596.80  | 23       | 43   |
|               | Max | 0.643       | 0.789 | 0.754    | 2.750 | 378      | 338 | 1112.84 | 1440.47 | 43       | 78   |
|               | Min | 0.301       | 0.306 | 0.203    | 0.207 | 69       | 17  | 232.49  | 42.68   | 11       | 27   |
| YTD % Loading |     | 101.3%      |       |          |       |          |     | 90%     | 91%     | 23.7     | 44.0 |
|               |     |             |       |          |       |          |     | 170%    | 220%    |          |      |

### Lake Point Improvement District

|               |     | Flows (mgd) |        |          |       | Influent |     | Lbs/day |        | Effluent |      |
|---------------|-----|-------------|--------|----------|-------|----------|-----|---------|--------|----------|------|
|               |     | Influent    |        | Effluent |       | mg/l     |     |         |        | mg/l     |      |
|               |     | Avg         | Max    | Avg      | Max   | BOD      | TSS | BOD     | TSS    | BOD      | TSS  |
| 2025          | Jan | 0.381       | 0.397  | 0.328    | 0.357 | 84       | 172 | 266.91  | 546.54 | 20       | 20   |
|               | Feb | 0.373       | 0.0392 | 0.316    | 0.364 | 147      | 141 | 457.29  | 438.63 | 26       | 26   |
|               | Mar | 0.434       | 0.437  | 0.329    | 0.346 | 147      | 98  | 532.08  | 354.72 | 36       | 36   |
|               | Apr | 0.500       | 0.553  | 0.318    | 0.353 | 204      | 218 | 850.68  | 909.06 | 38       | 38   |
|               | May | 0.490       | 0.522  | 0.334    | 0.353 | 143      | 126 | 584.38  | 514.91 | 27       | 27   |
|               | Jun | 0.401       | 0.416  | 0.251    | 0.309 | 128      | 134 | 428.08  | 448.14 | 40       | 40   |
|               | Jul | 0.389       | 0.463  | 0.184    | 0.192 | 154      | 154 | 499.62  | 499.62 | 45       | 45   |
|               | Aug | 0.311       | 0.326  | 0.181    | 0.187 | 174      | 273 | 451.31  | 708.09 | 26       | 26   |
|               | Sep | 0.211       | 0.202  | 0        | 0     | 309      | 158 | 543.76  | 278.04 | 44       | 44   |
|               | Oct | 0.305       | 0.369  | 0.316    | 0.033 | 292      | 227 | 742.76  | 577.42 | 19       | 19   |
|               | Nov | 0.327       | 0.349  | 0.284    | 0.292 | 154      | 250 | 419.99  | 681.80 | 20       | 20   |
|               | Dec | 0.309       | 0.337  | 0.589    | 0.302 | 188      | 133 | 484.49  | 342.75 | 23       | 23   |
|               | Avg | 0.369       | 0.368  | 0.286    | 0.257 | 177      | 174 | 545.08  | 534.81 | 30       | 30   |
|               | Max | 0.500       | 0.553  | 0.589    | 0.364 | 309      | 273 | 850.68  | 909.06 | 45       | 45   |
|               | Min | 0.211       | 0.039  | 0.000    | 0.000 | 84       | 98  | 266.91  | 278.04 | 19       | 19   |
| YTD % Loading |     | 94.2%       |        |          |       |          |     | 83%     | 82%    | 30.6     | 30.6 |
|               |     |             |        |          |       |          |     | 130%    | 139%   |          |      |

| Year | Month        | BOD | TSS | pH  | Flow Avg | Flow Max\ | Influent | BOD | TSS | E Coll | pH  | Cl2 Max | O&G | Flow Avg | Flow Max\ | Effluent | Lake Point Improvement District |
|------|--------------|-----|-----|-----|----------|-----------|----------|-----|-----|--------|-----|---------|-----|----------|-----------|----------|---------------------------------|
| 2026 | January      | 262 | 180 | 7.8 | 0.329    | 0.371     | 0.371    | 15  | 23  | 36     | 8.8 | 0.36    | N/D | 0.261    | 0.281     | <1       |                                 |
|      | February     | 285 | 180 | 7.7 | 0.340    | 0.342     | 0.342    | 23  | 36  | 7      | 8.8 | 0.34    | N/D | 0.275    | 0.288     | 7        |                                 |
|      | March        | 176 | 135 | 7.7 | 0.366    | 0.386     | 0.386    | 24  | 32  | 100    | 8.9 | 0.32    | N/D | 0.260    | 0.290     | 100      |                                 |
|      | Avg          | 244 | 192 | 7.7 | 0.345    | 0.366     | 0.366    | 21  | 31  | 54     | 9   | 0.340   | N/D | 0.265    | 0.286     | 54       |                                 |
|      | Min          | 176 | 135 | 7.7 | 0.329    | 0.342     | 0.342    | 15  | 26  | 7      | 8.8 | 0.32    | N/D | 0.26     | 0.281     | 7        |                                 |
|      | Max          | 285 | 262 | 7.8 | 0.366    | 0.386     | 0.386    | 24  | 36  | 100    | 8.9 | 0.36    | N/D | 0.275    | 0.290     | 100      |                                 |
|      | 2025 January | 184 | 172 | 7.7 | 0.381    | 0.0397    | 0.0397   | 14  | 20  | 20     | 8.8 | 0.24    | N/D | 0.328    | 0.358     | <1       |                                 |
|      | February     | 149 | 141 | 7.7 | 0.373    | 0.392     | 0.392    | 20  | 26  | 26     | 8.7 | 0.39    | N/D | 0.316    | 0.364     | <1       |                                 |
|      | March        | 148 | 98  | 7.7 | 0.434    | 0.437     | 0.437    | 27  | 36  | 36     | 8.8 | 0.34    | N/D | 0.329    | 0.346     | <1       |                                 |
|      | April        | 204 | 218 | 7.8 | 0.500    | 0.553     | 0.553    | 26  | 38  | 38     | 8.8 | 0.29    | N/D | 0.318    | 0.353     | 1        |                                 |
|      | May          | 143 | 126 | 7.7 | 0.490    | 0.522     | 0.522    | 28  | 27  | 27     | 8.7 | 0.22    | N/D | 0.334    | 0.353     | <1       |                                 |
|      | June         | 128 | 134 | 7.8 | 0.401    | 0.413     | 0.413    | 18  | 70  | 70     | 8.6 | 0.38    | N/D | 0.251    | 0.309     | <1       |                                 |
| 2025 | July         | 154 | 154 | 7.7 | 0.389    | 0.463     | 0.463    | 10  | 45  | 45     | 8.8 | 0.42    | N/D | 0.184    | 0.192     | <1       |                                 |
|      | August       | 174 | 273 | 7.7 | 0.311    | 0.325     | 0.325    | 13  | 26  | 26     | 8.8 | 0.31    | N/D | 0.181    | 0.187     | <1       |                                 |
|      | September    | 309 | 158 | 7.8 | 0.211    | 0.212     | 0.212    | 17  | 44  | 44     | 8.6 | 0.27    | N/D | 0.067    | 0.069     | <1       |                                 |
|      | October      | 292 | 227 | 7.7 | 0.305    | 0.369     | 0.369    | 6   | 19  | 19     | 8.7 | 0.19    | N/D | 0.316    | 0.353     | 12       |                                 |
|      | November     | 154 | 250 | 7.7 | 0.317    | 0.349     | 0.349    | 8   | 20  | 20     | 8.7 | 0.27    | N/D | 0.284    | 0.292     | <1       |                                 |
|      | December     | 188 | 133 | 7.7 | 0.309    | 0.337     | 0.337    | 14  | 23  | 23     | 8.7 | 0.24    | N/D | 0.289    | 0.302     | 1        |                                 |
|      | Avg          | 186 | 174 | 7.7 | 0.368    | 0.368     | 0.368    | 17  | 33  | 33     | 9   | 0.30    | N/D | 0.266    | 0.290     | 9        |                                 |
|      | Min          | 128 | 98  | 7.7 | 0.211    | 0.0397    | 0.0397   | 6   | 19  | 19     | 8.6 | 0.19    | N/D | 0.067    | 0.069     | 1        |                                 |
|      | Max          | 309 | 273 | 7.8 | 0.500    | 0.553     | 0.553    | 28  | 70  | 70     | 8.8 | 0.42    | N/D | 0.334    | 0.364     | 12       |                                 |

|      |           |     |     |       |       |       |    |    |    |     |      |     |       |       |
|------|-----------|-----|-----|-------|-------|-------|----|----|----|-----|------|-----|-------|-------|
| 2024 | January   | 107 | 202 | 7.7   | 0.303 | 0.339 | 13 | 27 | <1 | 8.8 | 0.19 | N/D | 0.324 | 0.36  |
|      | February  | 183 | 150 | 7.7   | 0.332 | 0.416 | 44 | 40 | <1 | 8.9 | 0.25 | N/D | 0.038 | 0.396 |
|      | March     | 129 | 187 | 7.7   | 0.403 | 0.655 | 31 | 41 | <1 | 8.7 | 0.49 | N/D | 0.368 | 0.382 |
|      | April     | 84  | 128 | 7.7   | 0.347 | 0.406 | 28 | 36 | <1 | 8.9 | 0.38 | N/D | 0.350 | 0.382 |
|      | May       | 171 | 223 | 7.7   | 0.339 | 0.416 | 21 | 51 | <1 | 8.9 | 0.34 | N/D | 0.321 | 0.321 |
|      | June      | 174 | 144 | 7.07  | 0.189 | 0.255 | 17 | 21 | <1 | 8.8 | 0.25 | N/D | 0.259 | 0.321 |
|      | July      | 227 | 229 | 7.7   | 0.297 | 0.401 | 5  | 31 | <1 | 8.7 | 0.36 | N/D | 0.147 | 0.179 |
|      | August    | 167 | 298 | 7.8   | 0.29  | 0.334 | 21 | 25 | <1 | 8.7 | 0.35 | N/D | 0.170 | 0.245 |
|      | September | 154 | 196 | 7.07  | 0.277 | 0.294 | 22 | 32 | <1 | 8.8 | 0.21 | N/D | 0.183 | 0.208 |
|      | October   | 147 | 222 | 7.08  | 0.254 | 0.576 | 19 | 26 | <1 | 8.9 | 0.42 | N/D | 0.312 | 0.423 |
|      | November  | 165 | 176 | 7.08  | 0.298 | 0.600 | 25 | 18 | <1 | 8.9 | 0.45 | N/D | 0.121 | 0.134 |
|      | December  | 150 | 95  | 7.8   | 0.315 | 0.327 | 25 | 50 | <1 | 8.9 | 0.24 | N/D | 0.260 | 0.267 |
|      | Avg       | 155 | 188 | 241.0 | 0.304 | 0.418 | 23 | 33 | <1 | 9   | 0.33 | N/D | 0.238 | 0.302 |
|      | Min       | 84  | 95  | 7.7   | 0.189 | 0.255 | 5  | 18 | <1 | 8.7 | 0.19 | N/D | 0.038 | 0.134 |
|      | Max       | 227 | 298 | 7.08  | 0.403 | 0.655 | 44 | 51 | <1 | 8.9 | 0.49 | N/D | 0.368 | 0.423 |
| 2023 | January   | 100 | 108 | 7.7   | 0.440 | 0.453 | 37 | 40 | <1 | 8.9 | 0.38 | N/D | 0.299 | 0.331 |
|      | February  | 172 | 142 | 7.6   | 0.389 | 0.409 | 40 | 35 | <1 | 8.8 | 0.44 | N/D | 0.342 | 0.367 |
|      | March     | 124 | 122 | 7.7   | 0.546 | 0.564 | 27 | 6  | 2  | 8.8 | 0.27 | N/D | 0.380 | 0.418 |
|      | April     | 78  | 277 | 7.7   | 0.650 | 0.644 | 16 | 44 | <1 | 8.6 | 0.19 | N/D | 0.612 | 0.648 |
|      | May       | 101 | 109 | 7.8   | 0.409 | 0.400 | 16 | 11 | <1 | 8.7 | 0.61 | N/D | 0.124 | 0.311 |
|      | June      | 185 | 167 | 7.8   | 0.356 | 0.400 | 22 | 19 | <1 | 8.7 | 0.24 | N/D | 0.218 | 0.258 |
|      | July      | 197 | 241 | 7.8   | 0.357 | 0.395 | 35 | 24 | <1 | 8.8 | 0.31 | N/D | 0.161 | 0.172 |
|      | August    | 314 | 317 | 7.7   | 0.249 | 0.292 | 27 | 44 | 17 | 8.8 | 0.29 | N/D | 0.177 | 0.180 |
|      | September | 259 | 216 | 7.7   | 0.224 | 0.309 | 23 | 44 | 1  | 8.7 | 0.59 | N/D | 0.167 | 0.180 |
|      | October   | 308 | 258 | 7.8   | 0.265 | 0.313 | 35 | 45 | <1 | 8.8 | 0.16 | N/D | 0.182 | 0.202 |
|      | November  | 157 | 250 | 7.8   | 0.276 | 0.307 | 11 | 30 | <1 | 8.8 | 0.21 | N/D | 0.223 | 0.245 |
|      | December  | 164 | 145 | 7.8   | 0.271 | 0.292 | 28 | 32 | <1 | 8.8 | 0.19 | N/D | 0.243 | 0.252 |
|      | Avg       | 180 | 196 | 7.7   | 0.367 | 0.419 | 26 | 31 | <1 | 8.8 | 0.32 | N/D | 0.261 | 0.297 |
|      | Min       | 78  | 108 | 7.6   | 0.224 | 0.292 | 11 | 6  | <1 | 8.6 | 0.16 | N/D | 0.124 | 0.172 |
|      | Max       | 314 | 317 | 7.8   | 0.625 | 0.65  | 40 | 45 | <1 | 8.9 | 0.61 | N/D | 0.612 | 0.648 |



**Lake Point Improvement District**

|        | <b>Influent</b> |                  | <b>Effluent</b> |                |                |                  |            |                  |
|--------|-----------------|------------------|-----------------|----------------|----------------|------------------|------------|------------------|
|        | <u>TLN</u>      | <u>Total PO4</u> | <u>Ammonia</u>  | <u>Nitrate</u> | <u>Nitrite</u> | <u>Ortho PO4</u> | <u>TKN</u> | <u>Total PO4</u> |
| 25-Jan | 45.1            | 5.0              | ND              | 0.98           | 0.4            | 0.92             | 10.0       | 1.5              |
| 25-Mar | 33.3            | 3.8              | 14.00           | 0.76           | 0.2            | 1.80             | 17.8       | 2.7              |
| 25-Jun | 70.3            | 8.1              | 13.70           | 0.50           | 0.1            | 1.50             | 19.5       | 2.8              |
| 25-Sep | 45.5            | 6.1              | 2.89            | N / D          | 0.1            | 0.71             | 10.9       | 3.3              |
| 24-Jan | 42.0            | 4.7              | 8.25            | 0.41           | 0.4            | 1.40             | 12.1       | 2.4              |
| 24-Mar | 65.0            | 5.5              | 5.42            | 0.52           | 0.4            | 1.50             | 23.4       | 2.6              |
| 24-Sep | 89.2            | 11.0             | 3.72            | ND             | 0.4            | 2.00             | 33.9       | 3.1              |
| 24-Dec | 79.6            | 4.7              | 8.25            | 0.41           | 0.4            | 1.40             | 12.1       | 2.4              |
| 23-Feb | 121             | 16.4             | 22.60           | ND             | ND             | 2.9              | 27.1       | 4.4              |
| 23-Jun | 84.5            | 12.3             | 8.49            | ND             | ND             | 2.0              | 12.2       | 3.1              |
| 23-Aug | 70.2            | 9.9              | 2.37            | 0.43           | ND             | 1.3              | 5.8        | 2.0              |
| 23-Dec | 88.2            | 17.9             | 8.43            | 0.27           | 0.2            | 2.3              | 13.2       | 2.9              |
| 22-Jan | 70.4            | 6.6              | 6.40            | 1.2            | 0.3            | 2.5              | 4.1        | 17.7             |
| 22-Mar | 86.3            | 12.2             | 1.70            | 2.6            | 0.4            | 0.9              | 50.5       | 4.4              |
| 22-Aug | 106             | 11.9             | 10.00           | ND             | 0.2            | 2.5              | 20.1       | 4.7              |
| 22-Dec | 66.5            | 7.5              | 9.16            | 0.61           | 0.3            | 1.9              | 12.8       | 2.5              |

Lake Point Improvement District

| <u>Year</u> | <u>Cyanide</u> | <u>Aluminum</u> | <u>Arsenic</u> | <u>Barium</u> | <u>Cadmium</u> | <u>Chromium</u> | <u>Copper</u> | <u>Lead</u> | <u>Mercury</u> | <u>Nickel</u> | <u>Selenium</u> | <u>Silver</u> | <u>Zinc</u> |
|-------------|----------------|-----------------|----------------|---------------|----------------|-----------------|---------------|-------------|----------------|---------------|-----------------|---------------|-------------|
| Jun-25      | ND             | N/D             | N/D            | 0.067         | N/D            | N/D             | 0.026         | N/D         | N/D            | N/D           | N/D             | N/D           | 0.02        |
| Dec-25      | ND             | 0.8             | 0.116          | 0.098         | 0.003          | 0.0043          | 0.0504        | 0.0075      | ND             | 0.006         | 0.00608         | ND            | 0.55        |
| 24-Jul      | ND             | 0.4             | 0.0078         | 113           | 0.0011         | 0.0033          | 0.176         | 0.0028      | IND            | 0.0047        | 95              | ND            | 0.24        |
| 23-Oct      | ND             | 0.3             | ND             | 0.078         | ND             | ND              | 0.059         | ND          | ND             | ND            | ND              | ND            | 0.23        |