

Official Draft Public Notice Version **July 1, 2026**

The findings, determinations, and assertions contained in this document are not final and subject to change following the public comment period.

**FACT SHEET
MOUNTAIN GREEN SEWER IMPROVEMENT DISTRICT
PERMIT MODIFICATION
UPDES PERMIT NUMBER: UT0024732
UPDES BIOSOLIDS PERMIT NUMBER: UTL-024732
MAJOR MUNICIPAL**

FACILITY CONTACTS

Operator Name:	Mountain Green Sewer Improvement District
Contact:	Jared Andersen
Position:	Plant Manager
Phone Number:	(801) 829-8238
Permittee Name:	Mountain Green Sewer Improvement District
Facility Name:	Mountain Green Sewer Improvement District Wastewater Treatment Plant
Mailing and Facility Address:	5455 West Old Highway Road Mountain Green, Utah 84050
Telephone:	(801) 876-3416
Actual Address:	5455 West Old Highway Road

DESCRIPTION OF FACILITY

This modification is in response to a letter from Mountain Green Sewer Improvement District (Permittee) (DWQ-2026-001056 and DWQ-2026-001057), received on February 5 and 27, 2026, requesting the incorporation of a Compliance Schedule for plant upgrade construction, whole effluent toxicity (WET) testing, and total phosphorus in Utah Pollutant Discharge Elimination System (UPDES) Permit No. UT0024732. The Division of Water Quality (DWQ) approves this request. On January 27, 2021, DWQ notified the Permittee that the yearly phosphorus loading cap agreed upon under Utah Administrative Code (UAC) R317-1-3.3 had been exceeded (see DWQ-2021-000879), and the Permittee was given until the beginning of 2026 to meet the yearly phosphorus loading cap. This Phosphorus Compliance Schedule has extended the date until 2027. Upon completion of the Compliance Schedule, the Permittee will be required to meet the 1.0 milligram per liter (mg/L) Technology-Based Phosphorus Effluent Limit Rule. The Compliance Schedules below have been incorporated into the UPDES Permit.

Plant Upgrade Construction Compliance Schedule:

Date	Milestone
September 1, 2026	Construction Completed
December 1, 2026	Plant Testing and Optimization Complete
January 1, 2027	Final Limitations in Effect

WET Compliance Schedule:

WET	
Date	Daily Maximum
Permit Issue – December 31, 2026	Monitor Only

January 1, 2027	IC ₅₀ > 100% effluent
-----------------	----------------------------------

Phosphorus Compliance Schedule:

Phosphorus	
Date	Annual Average
Permit Issue – December 31, 2026	Report Only
January 1, 2027	1.0 mg/L

* Phosphorus annual average for 2026 shall be reported in both loading (pounds per year) and concentration (mg/L).

PERMIT DURATION

It is recommended that this Permit modification be effective through the current Permit expiration date, July 31, 2030.

Drafted by
Lindsay Cowles, Environmental Scientist

PUBLIC NOTICE

Began:
Ended:

Comments will be received at: 195 North 1950 West
PO Box 144870
Salt Lake City, UT 84114-4870

During the public comment period provided under R317-8-6.5, any interested person may submit written comments on the draft Permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in R317-8-6.12.

ADDENDUM TO FSSOB

During finalization of the Permit certain dates, spelling edits and minor language corrections were completed. Due to the nature of these changes they were not considered Major and the permit is not required to be re Public Noticed.

Responsiveness Summary