



**GRANTSVILLE CITY
ORDINANCE NO. 2026-26**

**AN ORDINANCE OF GRANTSVILLE CITY APPROVING AMENDMENTS TO
CHAPTER 7-3 OF THE GRANTSVILLE CITY CODE REGARDING DEFINITIONS
AND REGULATIONS FOR CROSS CONNECTIONS AND DUAL SOURCE
CONNECTIONS**

Be it enacted and ordained by the City Council of Grantsville City, Utah as follows:

WHEREAS, Grantsville City Council has adopted regulations governing the City water system and cross connection control requirements within Chapter 7-3 of the Grantsville City Code; and

WHEREAS, the City desires to amend Section 7-3-6 Definitions to clarify the definition of “Cross Connection,” add a definition for “Dual Source Connection,” and remove the blank subsection labeled “A.”; and

WHEREAS, the City further desires to amend Section 7-3-7 Regulations to add additional protections and requirements relating to dual source connections; and

WHEREAS, the Grantsville City Council finds that these amendments are necessary to protect the public water system and promote the health, safety, and welfare of the residents of Grantsville City;

NOW THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF GRANTSVILLE CITY, STATE OF UTAH, AS FOLLOWS:

Section 1. Amendment to Section 7-3-6 Definitions: Section 7-3-6 of the Grantsville City Code is hereby amended as follows:

1. The blank subsection labeled “A.” is hereby removed.
2. The definition of “Cross Connection” is hereby repealed and replaced with the following:

“Cross Connection: Any actual or potential connection between the public water system or the consumer’s water system and any other source or auxiliary supply through which it is possible to introduce anything else. This would include temporary conditions, such as dual source connections, swing connections, removable sections, four way plug valves, spools, dummy sections of pipe, swivel or change-over devices, sliding multiport tubes, or other plumbing arrangements.”

3. The following definition is hereby added to Section 7-3-6:



“Dual Source Connection: A pipe that is installed so that either the nonpotable (i.e. secondary) irrigation water or the potable water is connected to a pressurized irrigation system one at a time, but not both at the same time; or a pipe that is installed so that either the potable water or private well water is connected to a residence at one time, but not the same time.”

Section 2. Amendment to Section 7-3-7 Regulations: Section 7-3-7 of the Grantsville City Code is hereby amended to add the following subsection as subsection (8):


“(8) Dual source connections shall be protected by a Reduced Pressure Principle Assembly. Any dual source connection found in violation of this ordinance shall be removed.”

Section 3. Effective Date: This Ordinance shall take effect immediately upon its passage and approval as provided by law.


Section 4. Severability clause: If any part or provision of this Ordinance is held invalid or unenforceable, such invalidity or unenforceability shall not affect any other portion of this Ordinance and all provisions, clauses and words of this Ordinance shall be severable.

ADOPTED AND PASSED BY THE CITY COUNCIL OF GRANTSVILLE CITY, THIS 15th DAY OF JULY, 2026.

BY THE ORDER OF THE GRANTSVILLE CITY COUNCIL:


By Mayor Heidi Hammond

ATTEST


Alicia Fairbourne, City Recorder

