
Where are the engineering documents

Gil [REDACTED]

Wed, Sep 16, 2026 at 3:39 PM

To: "araddatz@springdale.utah.gov" <araddatz@springdale.utah.gov>

April, please send this information to the Planning Commission members.

Attached are two photos taken earlier today of the parking lot at 50 Zion Park Blvd..

The first picture shows a boulder type retaining wall that is on the right side of the parking lot. The height of the left side of the wall is over 4 feet in height and grows to just under 6 feet in height at the right back side of the wall. This wall appears to have been constructed to allow an additional parking space in this area.

I measured both of these walls from the ground to the top of the wall. The total height of the wall is actually higher than I measured as the total height must include the part of the wall that is buried.

The second picture shows the boulder wall at the rear of the parking lot. The height of this wall in this area is 5 feet.

There are no engineering documents in the file for these two walls that exceed 4 feet in height. Per Town, County and State regulations, any retaining wall exceeding 4 feet in height must be engineered.

2 attachments



IMG_0505.jpeg
185K



IMG_0507.jpeg
199K