State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Tim Davis
Commissioner

DIVISION OF WATER QUALITY
Candice A. Hasenyager, P.E.
Director

October 29, 2026

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF INTENT TO RENEW A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the Director of the Division of Water Quality's intention to renew a Utah Pollutant Discharge Elimination System (UPDES) Permit under the authority of the Utah Water Quality Act, Utah Code § 19-5-106(2)(g). The draft Permit and the Fact Sheet (collectively, the draft Permit documents) are available for review and comment.

PERMIT INFORMATION

PERMITTEE NAME:	Manti City Corporation
FACILITY NAME:	Manti City Wastewater Treatment Facility
MAILING ADDRESS:	50 South Main Street, Suite 1, Manti, Utah 84642
TELEPHONE NUMBER:	(435) 851-1011
FACILITY LOCATION:	1500 North 100 East
UPDES PERMIT NO.:	UT0026026
PERMITTED OUTFALLS:	001
OUTFALL LOCATION:	Latitude 111° 37' 43" and longitude 39° 17' 24"
RECEIVING WATER:	San Pitch River

BACKGROUND

The Manti City Wastewater Treatment Facility (Facility) is located at 1500 N 100 E, Manti, Sanpete County, Utah, and serves the City of Manti. The Facility design capacity is 0.33 million gallons per day (MGD), with a maximum design capacity of 0.97 MGD, an average five-year flow of 0.219 MGD, and a population equivalent of approximately 3,800 with 25 miles of sewer collection pipes. The Facility consists of an influent pump station, 8-inch Parshall Flume, flow meter, grinder, bar screen, and three facultative lagoon cells totaling 41.5 acres. Cell #1 is 14.1 acres, cell #2 is 13.6 acres, cell #3 is 13.7 acres with chlorination for disinfection on the effluent. The Facility UPDES Permit allows for discharge to the San Pitch River between October 1 and February 28 each calendar year. Please refer to the draft permit documents for more information.

PUBLIC COMMENTS

Pursuant to Utah Admin. Code R317-8-6(6.6), any interested person may submit written comments on the draft permit documents and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in Utah Admin. Code R317-8-6(6.12).

Commenters have an affirmative obligation to raise all reasonably ascertainable issues and submit all reasonably available arguments and factual grounds supporting their position, including all supporting

material. Supporting material must be included in full and may not be incorporated by reference, unless the material is already part of the administrative record.

Public comments are invited any time prior to the deadline of the close of business on **November 30th, 2026**. Written public comments can be submitted to: Lindsay Cowles, UPDES Individual Permits Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: lcowles@utah.gov.

After considering public comments, the Director of the Division of Water Quality will issue a final Permit decision. The draft Permit documents are available for public review under "Public Participation" at www.waterquality.utah.gov/. Additionally, if internet access is not available, a copy may be obtained by calling Lindsay Cowles at (385) 414-0311.

DWQ-2026-006357