

AGENDA

UNIFORM BUILDING CODE COMMISSION  
ELECTRICAL ADVISORY COMMITTEE

May 29, 2015 1:30  
Room 475  
160 E 300 S Salt Lake City, UT

*This agenda is subject to change up to 24 hours prior to the meeting.*

1. Approve minutes from April 9, 2015 meeting
2. Review electrical portion of 2015 IRC
3. Make a recommendation for the 2014 NEC and electrical portion of the 2015 IRC

Next Scheduled Meeting: as needed

Please call Sharon at 801-530-6163 or email [ssmalley@utah.gov](mailto:ssmalley@utah.gov) if you do not plan on attending this meeting.



In compliance with the Americans with Disabilities Act, individuals needing special accommodations (including auxiliary communicative aids and services) during this meeting should notify Dave Taylor, ADA Coordinator, at least three working days prior to the meeting. Division of Occupational and Professional Licensing, 160 East 300 South, Salt Lake City UT 84115, Phone 530-6628 or toll-free in Utah only 866-275-3675.

UNIFORM BUILDING CODE COMMISSION

ELECTRICAL ADVISORY COMMITTEE  
MEETING

April 9, 2015 1:30  
Room 464 Heber M Wells Bldg  
160 E 300 S Salt Lake City, UT

MINUTES

STAFF

Dan S Jones, Bureau Manager  
Sharon Smalley, Board Secretary

ELECTRICAL ADVISORY COMMITTEE MEMBERS

Christopher Jensen	David Wesemann (absent)
Mike Thomas (excused)	Gary Beckstrand
Chris Joyal, Liaison	Rhett Butler
David Winger	

VISITORS

MINUTES

A motion was made by Chris Joyal to approve the minutes from the March 12, 2015 meeting as written. The motion was seconded by David Winger and passed unanimously.

REVIEW ELECTRICAL PORTION OF  
2015 IRC

Chris Jensen gave a report on the significant changes to the electrical portion of the 2015 residential code. Each item was reviewed and a cost estimate was developed.

During the review of Section E3902.16 it was pointed out that there is currently an amendment for this section. A recommendation for this section was tabled until the next meeting since there was no one there from the home owners to give their opinion. This will be an agenda item for the next meeting.

During the review of Section E3901.9 a recommendation was made to add an exception that would state, "Receptacles or other outlets adjacent to the exterior walls of the garage or outlets in storage rooms with entry from the garage

shall be permitted to be connected to the garage branch circuit." Following the discussion, a motion was made by Dave Winger to add the amendment. The motion was seconded by Rhett Butler and passed unanimously.

The meeting adjourned at 3:07.

*Note: These minutes are not intended to be a verbatim transcript but are intended to record the significant features of the business conducted in this meeting. Discussed items are not necessarily shown in the chronological order they occurred.*