

reduced pressure backflow assembly and high hazard air gap, showing the serial number, date tested, and by whom. The technician's license number must also be on this tag. In the case of a consumer requiring an assembly to be tested, any certified technician is authorized to make the test and report the results of that test to the consumer, and the Water Superintendent. The installation, replacement, or repair of assemblies must be made by a tester having appropriate licensure from the Department of Commerce, Division of Professional Licensing, except when the backflow technician is an agent of the assembly owner.

10.8.19 Water Pollution Prohibited

It shall be unlawful for any person to maintain or erect any building, pens, or stalls for any horses, cattle, sheep, swine, or other animals or to permit any of such animals to be corralled, bedded, or to run at large within three hundred (300) feet of any stream from which water for the city culinary water system shall be taken at any point within fifteen (15) miles above the point where the water of the stream is taken into the city culinary water system.

It shall likewise be unlawful for any person to construct or maintain within three hundred (300) feet of any such stream at any point within fifteen (15) miles above the point where the water of such system is taken into the city culinary water system, any closet, privy, or outhouse without providing an effective septic tank or other germ destroying appliance. Such tanks or appliances, prior to being placed in use, are subject to inspection and approval of the City.

10.8.20 Private Systems and Private Wells

As specified in Chapter 19.6 of Title 19, Zoning Ordinance, private drinking water wells may be allowed in the A-5-H, Annexation Holding Zone and the Mountain and Hillside Zones, as outlined in the respective ordinance. Only one single-family dwelling shall be connected per well.

Wells must satisfy the requirements of the Utah Division of Environmental Quality; the Utah County Health Department; and any other agency having authority to regulate on-site utility systems. Written documentation certifying the proposed on-site system conforms to the pertinent state and county health regulations shall be provided. A building permit shall not be issued until the required approvals have been granted.

Private water systems and the use of private wells to provide municipal water services are not allowed except

at the discretion of the City Council, in the following instances:

1. It is virtually impossible to expand the current municipal water system, connect to the current city culinary water system, or create facilities capable of linking to the city culinary water system.
2. Allowance of the private system or private well is more compatible with the land use development goals of the City (i.e. environmental preservation, construction of a necessary public facility significantly removed from the current water system, limitation of the number of dwellings units in a given area where connection to the city culinary water system could result in more dwellings units than are desired by the City.

The City Council is under no obligation to approve the use of a private system or private well and no precedent will be established by a previous City Council decision.

10.9 Open Ditch Irrigation

- 10.9.1 Irrigation Secretary to List Property and Prepare Schedule
- 10.9.2 Appeal of Apportionment
- 10.9.3 Entitlement to Use of Water
- 10.9.4 Permission to Make Change in Street
- 10.9.5 Surplus Water
- 10.9.6 Users to Control Water
- 10.9.7 Changes in irrigation Water System
- 10.9.8 Head gates

10.9.1 Irrigation Secretary to List Property and Prepare Schedule

On or before the fifteenth of January each year the irrigation secretary shall ascertain the number of city lots and the number of acres of land irrigated by open ditch irrigation, and the name of all persons, corporations, companies and firms owning, being in possession, charge or control thereof, and make a schedule of the same and return it to the Water Superintendent previous to the first of February of the same year. The City shall keep an account with the amount of assessment and the amount paid.

10.9.2 Appeal of Apportionment

Any person aggrieved at the proportion of water may, on written complaint, be heard by the City Council. All complaints must be presented within twenty (20) days from the origin of the act. If any person is aggrieved at the decision of the City Council, they may appeal the