

**NOTICE AND AGENDA
MIDWAY WATER ADVISORY BOARD
MONDAY, February 1, 2021**

Notice is hereby given that the Midway Water Advisory Board will hold their regular meeting Monday, February 1, 2021 at 6:00 p.m. in the Midway City Office Building at 75 North 100 West Midway, Utah. Notice of the meeting and agenda was posted in the Midway City Office Building, Main Street Station and 7-Eleven, a copy was sent to each of the Trustees and a copy posted on the Utah Meeting Notice Web Site.

The agenda shall be as follows:

1. **General Consent Calendar**
 - a. **Approve Agenda February 1, 2021**
 - b. **Approve Meeting Minutes January 4, 2021**
2. **Salazar Spring Road - Robert and Julie Salazar – 583 East Salazar Spring Road**
 - a. **Discussion on Project**
 - b. **Possible Recommendation to City Council**
3. **New/Old Business - No motions or recommendations given**
4. **Adjourn**



General Consent Calendar



MIDWAY WATER ADVISORY BOARD
MONDAY January 4, 2021
MEETING MINUTES

Minutes of the Midway Water Advisory Board meeting held January 4, 2021 at 6:00 p.m. in the Midway City Office Building, 75 North 100 West, Midway, UT.

Roll Call

Irrigation Members: Irrigation President/Chairman Steve Farrell, Grant Kohler, Brent Kelly; Midway City: City Councilman Steven Dougherty, City Councilman Jeff Drury, Wes Johnson, City Engineer, Michael Henke, City Planner and Jennifer Sweat, Treasurer/Water Advisory Board Secretary.

General Consent Calendar

Chairman/Mayor Celeste Johnson asked for approval of the General Consent Calendar which consisted of:

- a. Approval of the Agenda for January 4, 2021
- b. Approval of the minutes for November 16, 2020
- c. Approve 2021 Meeting Schedule

Motion: Midway Irrigation Member Grant Kohler made a motion to approve the General Consent Calendar, Co-Chairman/Midway Irrigation President Steve Farrell 2nd the motion.

Chairman Steve Farrell asked if there were further questions regarding this item? There was not.

Motion was carried unanimously.

Mountain Spa – Change Application

Michael Henke, City Planner stated the following information regarding the subdivision:

- . 52.45 acres
- R-1-22 zone
- 5 lots
- Access from River Road and Burgi Lane
- Utilities
 - Connect to culinary water.
 - Lots 1, 2 & 5 to connect to sewer.
 - Lots 2 & 3 to install septic.
 - Secondary – to be determined.

January 4, 2021

The board reviewed the change application and reviewed the property via google maps, and the properties on the plat map for the Mountain Spa.

Michael Henke, City Planner reminded the board what the approved water requirement would be for Mountain Spa.

- 52.45-acre parcel
 - Area of parcel – 2,284,722 sq. ft.
 - Impervious area of lots – 40,000 sq. ft. (5x8,000) (0.92 acres)
 - Irrigated acreage – $22.1 \times 3 = 66.3$ -acre feet
- 5 culinary connections
 - 4-acre feet
- 70.3-acre feet requirement

Mountain Spa Rural Preservation Subdivision Water Right Estimate

September 17, 2020

The Hot Pot Conservation Area will not be irrigated and not water rights have been calculated for this area.
The farm parcel along Burgi Lane has not been historically irrigated. This area will continue to be used for grazing with irrigation.
The farm parcel along River Road is proposed to be irrigated (14.10 acres).

Water Right Estimate for Mountain Spa Concept Plan

Use	Water Right per Unit (acre-feet)	Unit	Unit Quantity	Required Water Rights (acre-feet)
Preservation Lots				
Homes	0.80	per home	5	4.00
Total Estimated Water Rights for Inside Use				4

Lot 1 Irrigated Area	3.00	acre	1.87	5.61	Lot size less sensitive lands and 8,000 sf for home and driveway per city code.
Lot 2 Irrigated Area	3.00	acre	0.82	2.46	Lot size less 8,000 sf for home and driveway per city code.
Lot 3 Irrigated Area	3.00	acre	1.52	4.56	Lot size less sensitive lands and 8,000 sf for home and driveway per city code.
Lot 4 Irrigated Area for Home	3.00	acre	1.60	4.80	Parcel for home less 8,000 sf for home and driveway per city code.
Lot 4 Farm Parcel	3.00	acre	0.00	0.00	This area has not be historically irrigated. To be used for grazing.
Lot 5 Irrigated Area for Home	3.00	acre	2.19	6.57	Parcel for home less sensitive lands and 8,000 sf for home and driveway per city code.
Lot 5 Farm Parcel	3.00	acre	14.10	42.30	Historically irrigated area.
Total Estimated Water Rights for Irrigation				66.30	
Total Estimated Water Rights Needed for Development				70.30	

January 4, 2021

Explanatory for Permanent Change Application on Water Right 55-13093

Applicants Midway City Corporation, Midway Irrigation Company, Silver Rim Water Holdings LLC, New Washington Irrigation Company, and Charles Vaughn Heath jointly file this application to change the point of diversion, place of use and nature of use of 100 Class B shares and 30 Class D shares in the New Washington Irrigation Company, represented by Certificate numbers 424, 425, 426, and 427. True and correct copies of the certificates are attached hereto. The heretofore points of diversion are located on the Provo River near Woodland, Summit County, State of Utah, and the proposed hereafter points of diversion and place of use are also located in the Provo River Drainage, thereby maintaining the continuity of return flows. This Change Application contemplates Municipal use within the service area of Midway City and 15 existing surface water and groundwater sources are identified as the hereafter points of diversion. Two new underground wells are proposed in the region of the Mountain Spa development of Midway City.

The depletion quantity of the prior use of the shares is estimated from the report titled "*Consumptive Use of Irrigation Crops in Utah, Research Report 145, Kamas Station, Utah Agricultural Experiment Station, Utah State University, Logan, Utah, October 1994*" (Hill, 1994).

<u>Prior Use</u>	<u>Diversion</u>	<u>Rate of Depletion</u>	<u>Depletion</u>
Irrigation: 33.3333 acres	100 ac-ft	53.58%	53.58 ac-ft

To avoid water right enlargement Midway City and Midway Irrigation Company will track water use and will not exceed both the historic 100 ac-ft diversion limit and 53.58 ac-ft depletion limit of the shares.

The Shareholder has entered into an agreement with the New Washington Irrigation Company to ensure that the shares remain in good standing and water either remains in the Provo River or is released back into the Provo River at the end of the company's distribution system to prevent water right enlargement. Furthermore, the applicants will make 30 Class D shares (3:1 ratio of B:D) available to maintain canal carry water and evaporative losses in the canal.

New Washington Irrigation Company shares are supported by Provo River Decree fifth-class and seventeenth class water rights and include storage rights that allow extended seasonal irrigation. Because storage water can be released to mitigate potential impacts to downstream water users, a change to year-round Municipal water use can be made.

The board discussed the letter from Clyde Snow, and reviewed the documents given for an explanation for the change application (see above and supplemental file).

The board discussed the concerns the irrigation company had in bringing in foreign water, and the need for the applicant to be aware of the foreign water policy. It was decided that further information and discussion was needed, and the board suggested that the irrigation company, city and Steve Clyde and Van King meet with them prior to the next City Council meeting when this item would go before them. The applicants agreed on this, and understood the concerns being presented from the irrigation company.

Motion: Midway Irrigation Member Grant Kohler made the motion to approve the application, with the condition that the Irrigation Company and the City sit down with Steve Clyde and Van King to go over the 1. change application and 2. foreign water policy, that all parties are comfortable with how the water will go into the system and how it will be administered so there are no questions, and that any fees that are involved they understand those fees on the front end and understand what they are getting into. The goal is to have that meeting and discussion by January 13, 2021, so that the Mountain Spa can go before the City Council on January 19th, 2021. City Councilman Steve Dougherty 2nd the motion.

January 4, 2021

Chairman Steve Farrell asked if there were further questions regarding this item? There was not.

Motion was carried unanimously.

Homestead Resort -700 North Homestead Drive New/Old Business

Michael Henke, City Planner presented the following information regarding the project:

- 72.01 acres
- Resort Zone
- 2 Phases (1 plat)
- Sensitive lands on the property include The Crater and wetlands

The board reviewed the previous calculations from July 2020 and October 2020, and reviewed maps from Paul Berg, Engineer for the project as requested by the board at the November 2020 meeting. (See supplemental file for maps).

The Homestead Resort Master Plan Additional Water Right Calculations

July 6, 2020

Prepared by: Paul Berg, P.E., Berg Engineering

Project Information

Tables 1-3 provide the water right requirements and additional water uses for new The Homestead Resort Master Plan.

Resolution 2008-09 A Master Plan Development Agreement for The Homestead Resort states in Section 3.1(b)(4) - Water
"On May 5, 2008 the Midway Advisory Board determined that the Developer owns or leases enough water to provide an additional 107 acre-feet of water which is necessary to serve the improvements (including the golf course) identified on the project"

Existing uses at The Homestead that will be replaced with similar facilities are not considered in the analysis. New or expanded uses must dedicate additional water rights. These new or expanded uses are calculated below. Credits for existing uses that will be removed are also shown. Existing uses that will be replaced within the resort include the golf clubhouse, restaurants, conference rooms and existing restrooms.

The water right calculations below are based on the master plan dated July 2, 2020.

Table 1 - Water Use Requirements

Use	Water Requirement		Source of Requirement	Return Flow Requirement	Total Required	
	Quantity	Unit			Quantity	Unit
Irrigated / landscaped area	3.00	acre-feet/acre	Midway Water Board	0.00	3.00	acre-feet/acre
Hotel resort unit	150	gpd/unit	Table 1, Utah Code R309-510	1.77	0.30	acre-feet/unit
Restaurant	35	gpd/seat	Table 2, Utah Code R309-510	1.77	0.07	acre-feet/seat
Swimming pools	10	gpd/person	Table 2, Utah Code R309-510	1.77	0.02	acre-feet/person
Retail / commercial / amenities	500	gpd/toilet	Table 2, Utah Code R309-510	1.77	0.99	acre-feet/toilet
Visitors (conference) center	5	gpd/person	Table 2, Utah Code R309-510	1.77	0.01	acre-feet/person

Table 2 - Change in Water Uses at The Homestead

Use	Quantity	Unit
Irrigated area removed for development	-2.16	acres
Irrigated area removed for ponds	-0.15	acres
Ponds being removed	-0.72	acres
Irrigated area added to resort	11.15	acres
Pond area added to resort	0.79	acres
Existing units to be removed	-12	units
New hotel units	75	units
New restaurants	400	seats
Swimming pools	441	person
Retail / commercial / amenities / spa	16	toilet
Conference Center and Wedding Barn	650	person

Comments

Only 12 existing units to be removed, 125 of the existing 137 units will remain.

See note 1.

Additional mens and womens toilet stalls in commercial and amenity areas
Proposed additional conference center capacity at The Homestead

Table 3 - Additional Water Needs for The Homestead Resort

Use	Project Quantity	Unit	Water Requirement with Return Flow	Unit	Total (acre-feet)
Credit for removed irrigated area	2.16	acres	-3.00	acre-feet/acre	-8.48
Credit for removed ponds	0.15	acres	-3.00	acre-feet/acre	-0.45
Pond area being removed	0.72	acres	-3.00	acre-feet/acre	-2.16
Credit for removed hotel units	12	units	-0.30	acre-feet/unit	-3.60
Irrigated area added to resort	11.15	acres	3.00	acre-feet/acre	33.45
Pond area added to resort	0.79	acres	3.00	acre-feet/acre	2.37
New hotel units	75	units	0.30	acre-feet/unit	22.50
New restaurant spaces	400	seats	0.07	acre-feet/person	28.00
Swimming Pools	441	person	0.02	acre-feet/person	8.82
Retail / commercial / amenities / spa	16	toilet	0.99	acre-feet/toilet	15.84
Conference Center and Wedding Barn	650	person	0.01	acre-feet/person	6.50

104.79 acre-feet of add

Notes:

1. The existing swimming pools, hot tub and fitness center has an existing capacity of 194 people. The new swimming pools have a proposed capacity of 635 people for a net difference of 441.
2. 1 acre-foot per year = 892 gallons per day
3. The Midway Water Board policy was recently changed from 1.0 acre-feet per home to 0.80 acre-feet per home. This change represents a 1.77x return flow. The previous policy was 2x.

January 4, 2021

The Homestead Resort Preliminary Plan Additional Water Right Calculations

October 19, 2020

Prepared by: Paul Berg, P.E., Berg Engineering

Project Information

Tables 1-3 provide the water right requirements and additional water uses for new The Homestead Resort Master Plan.

Resolution 2008-09 A Master Plan Development Agreement for The Homestead Resort states in Section 3.1(b)(4) - Water
"On May 5, 2008 the Midway Advisory Board determined that the Developer owns or leases enough water to provide an additional 107 acre-feet of water which is necessary to serve the improvements (including the golf course) identified on the project."

Existing uses at The Homestead that will be replaced with similar facilities are not considered in the analysis. New or expanded uses must dedicate additional water rights. These new or expanded uses are calculated below. Credits for existing uses that will be removed are also shown. Existing uses that will be replaced within the resort include the golf clubhouse, restaurants, conference rooms, house keeping and existing restrooms.

The water right calculations below are based on the preliminary plan dated October 13, 2020.

Table 1 - Water Use Requirements

Use	Water Requirement		Source of Requirement	Return Flow Requirement	Total Required	
	Quantity	Unit			Quantity	Unit
Irrigated / landscaped area	3.00	acre-feet/acre	Midway Water Board	0.00	3.00	acre-feet/acre
Hotel resort unit	150	gpd/unit	Table 1, Utah Code R309-510	1.77	0.30	acre-feet/unit
Restaurant	35	gpd/seat	Table 2, Utah Code R309-510	1.77	0.07	acre-feet/seat
Swimming pools	10	gpd/person	Table 2, Utah Code R309-510	1.77	0.02	acre-feet/person
Retail and commercial	500	gpd/toilet	Table 2, Utah Code R309-510	1.77	0.99	acre-feet/toilet
Visitors (conference) center	5	gpd/person	Table 2, Utah Code R309-510	1.77	0.01	acre-feet/person
Spa and activity center	25	gpd/person	Table 2, Utah Code R309-510	1.77	0.05	acre-feet/person

Table 2 - Change in Water Uses at The Homestead

Use	Quantity	Unit	
Irrigated area removed for development	-2.16	acres	
Irrigated area removed for ponds	-0.15	acres	
Ponds being removed	-0.72	acres	
Irrigated area added to resort	11.15	acres	
Pond area added to resort	0.79	acres	ERUs
Existing units to be removed	-12	units	-12.00
Residential homes	5	homes	5.00
A New hotel units	49	units	18.38
B Additional restaurants seating	130	seats	11.38
C Additional swimming pool capacity	206	person	5.15
D Retail and commercial	2	toilet	2.50
E Conference Center and Wedding Barn	864	person	10.80
F Spa	50	person	3.13
G Activity Center	40	person	2.50

Comments

8.91

Only 12 existing units to be removed, 125 of the existing 137 units will remain.

42 units in 6-plex buildings, 4 in Virginia House and 3 in Center House

See note 4.

See note 1.

Additional mens and womens toilet stalls in commercial and amenity areas

Proposed additional conference center capacity at The Homestead

Based on gym participant in the state code.

Based on gym participant in the state code.

48.83

January 4, 2021

Table 3 - Additional Water Needs for The Homestead Resort

Use	Project Quantity	Unit	Water Requirement with Return Flow	Unit	Total (acre-feet)
Credit for removed irrigated area	2.16	acres	-3.00	acre-feet/acre	-6.48
Credit for removed ponds	0.15	acres	-3.00	acre-feet/acre	-0.45
Pond area being removed	0.72	acres	-3.00	acre-feet/acre	-2.16
Credit for removed hotel units	12	units	-0.30	acre-feet/unit	-3.60
Irrigated area added to resort	11.15	acres	3.00	acre-feet/acre	33.45
Pond area added to resort	0.79	acres	3.00	acre-feet/acre	2.37
Residential homes	5	homes	0.80	acre-feet/home	4.00
New hotel units	49	units	0.30	acre-feet/unit	14.70
New restaurant spaces	130	seats	0.07	acre-feet/person	9.10
Swimming Pools	206	person	0.02	acre-feet/person	4.12
Retail and commercial	2	toilet	0.99	acre-feet/toilet	1.98
Conference Center and Wedding Barn	864	person	0.01	acre-feet/person	8.64
Spa	50	person	0.05	acre-feet/person	2.50
Activity Center	40	person	0.05	acre-feet/person	2.00

70.17 acre-feet of additional water rights for master plan

Notes:

1. The existing swimming pools, hot tub and fitness center has an existing capacity of 194 people. The new swimming pools have a proposed capacity of 400 people for a net difference of 206.
2. 1 acre-feet per year = 892 gallons per day
3. The Midway Water Board policy was recently changed from 1.0 acre-feet per home to 0.80 acre-feet per home. This change represents a 1.77x return flow. The previous policy was 2x.
4. The existing restaurants have a 172 seating capacity (Simons 96 and Fanny's 76). The new restaurants, bars and lounges have a capacity of 302 for an increase in restaurant capacity of 130 seats.

- A 49 X 150 / 400 (49 X 150 gpd / 400 gal per ERU)
 B 302 X 35 / 400 (302 seats, 35 gpd per seat, 400 gpd per ERU)
 C 206 x 10 / 400 (206 people, 10 gpd per person, 400 gpd per ERU)
 D 2 X 500 / 400 (2 toilets, 500 gpd per toilet, 400 gpd per ERU)
 E 864 X 5 / 400 (864 people, 5 gpd, 400 gpd per ERU)
 F 50 X 25 / 400 (50 people, 50 gpd, 400 gpd per ERU)
 G 40 X 25 / 400 (50 people, 50 gpd, 400 gpd per ERU)

Michael Henke, City Planner presented the following possible recommendation for water.

- Golf Course Irrigated
 - $29.36 \times 3 = 88.08$ -acre feet
- Resort Core
 - 70.17-acre feet
- Total for master plan
 - 158.25

Additional information and water calculations from Berg Engineering:

January 4, 2021

Table 1 - Water Use Requirements

Use	Water Requirement		Source of Requirement	Return Flow Requirement	Total Required	
	Quantity	Unit			Quantity	Unit
Irrigated / landscaped area	3.00	acre-feet/acre	Midway Water Board	0.00	3.00	acre-feet/acre
Hotel resort unit	150	gpd/unit	Table 1, Utah Code R309-510	1.77	0.30	acre-feet/unit
Restaurant	35	gpd/seat	Table 2, Utah Code R309-510	1.77	0.07	acre-feet/seat
Swimming pools	10	gpd/person	Table 2, Utah Code R309-510	1.77	0.02	acre-feet/person
Retail and commercial	500	gpd/toilet	Table 2, Utah Code R309-510	1.77	0.99	acre-feet/toilet
Visitors (conference) center	5	gpd/person	Table 2, Utah Code R309-510	1.77	0.01	acre-feet/person
Spa and activity center	25	gpd/person	Table 2, Utah Code R309-510	1.77	0.05	acre-feet/person

Table 2 - Change in Water Uses at The Homestead

Use	Quantity	Unit
Existing units to be removed	-12	units
Irrigated area added to resort	4.61	acres
Pond area added to resort	0.07	acres
Residential homes	5	homes
New hotel units	49	units
Additional restaurants seating	130	seats
Additional swimming pool capacity	206	person
Retail and commercial	2	toilet
Conference Center and Wedding Barn	864	person
Spa	50	person
Activity Center	40	person

Comments

Only 12 existing units to be removed, 125 of the existing 137 units will remain.

42 units in 6-plex buildings, 4 in Virginia House and 3 in Center House

See note 4.

See note 1.

Additional mens and womens toilet stalls in commercial and amenity areas

Proposed additional conference center capacity at The Homestead

Based on gym participant in the state code.

Based on gym participant in the state code.

Table 3 - Additional Water Needs for The Homestead Resort

Use	Project Quantity	Unit	Water Requirement with Return Flow	Unit	Total (acre-feet)
Credit for removed hotel units	12	units	-0.30	acre-feet/unit	-3.60
Irrigated area added to resort	4.61	acres	3.00	acre-feet/acre	13.83
Pond area added to resort	0.07	acres	3.00	acre-feet/acre	0.21
Residential homes	5	homes	0.80	acre-feet/home	4.00
New hotel units	49	units	0.30	acre-feet/unit	14.70
New restaurant spaces	130	seats	0.07	acre-feet/person	9.10
Swimming Pools	206	person	0.02	acre-feet/person	4.12
Retail and commercial	2	toilet	0.99	acre-feet/toilet	1.98
Conference Center and Wedding Barn	864	person	0.01	acre-feet/person	8.64
Spa	50	person	0.05	acre-feet/person	2.50
Activity Center	40	person	0.05	acre-feet/person	2.00

57.48 acre-feet of addit

The board reviewed the letter written to them from Berg Engineering regarding the project and the questions they had regarding the project that the board had requested from previous meetings. The maps and calculations were reviewed by the board (see supplemental files)

Motion: Midway Irrigation Member Brent Kelly made the motion to recommend approval to the city council that new uses in the master plan for the Homestead is 145.56-acre feet be required, and an additional water rights for the new resort plan and that 29.36 acre of irrigated golf course area is represented in that number and that the Homestead always owns, or leases rights to cover 104 total acres for the golf course. Midway Irrigation Member Grant Kohler 2nd the motion.

City Councilman Jeff Drury discussed the laundry and Paul Berg stated that it would be moved, but it would be the same use, and nothing would change. The board only reviewed the new uses, not existing uses.

The motion stands and was 2nd by Grand Kohler as stated above.

Chairman Steve Farrell asked if there were further questions regarding this item? There was not.

New Old/Business

Chairman/Mayor Celeste Johnson asked if there was any New or Old Business? There was not.

Midway Irrigation Member Grant Kohler moved to adjourn. City Councilman Steve Dougherty 2nd the motion. It was carried unanimously. Meeting adjourned at 7:42 p.m.

DRAFT

January 4, 2021

Salazar Spring Road-Robert and Julie Salazar



MIDWAY CITY

Planning Office

75 North 100 West
Midway, Utah 84049

Phone: 435-654-3223 x105
Fax: 435-654-2830
mhenke@midwaycityut.org

Midway Water Advisory Application

Applicant or Authorized Representative:

Name: ROBERT & JULIE SALAZAR Phone: 801-361-5065 Fax: _____

Mailing Address: PO BOX 318 City: MIDWAY CITY State: UT Zip: 84049

E-mail Address: julie.salazar17@gmail.com

Project Name: SALAZAR SPRING RD

Location: 583 E SALAZAR SPRING RD (600 NORTH)

Total Acreage: 2.73 Number of Units: 3 Historically Irrigated Area: 2.5 AC

Existing Water Connections: 3 METERS / 3 IRRIG BOXES

Comments:

WATER METERS AND IRRIG. BOXES ARE EXISTING - INSTALLED
WITH CONSTRUCTION OF WHITAKER FARM

Please submit with application Site Plans, Plat Maps, Drawings or any information that pertains to water calculations.

Please read and sign before application submittal

I declare under penalty of perjury that I am the owner or authorized agent of the property subject to this request and the foregoing statements, answers and attached documents are true and correct. As the applicant for this proposal, I understand that my application is not deemed complete until the Planning Office has reviewed the application. I further understand I will be notified when my application has been deemed complete. At that time, I expect that my application will be processed within a reasonable time.

Signature of Owner or Agent: [Signature] Date: 01/07/2021

FOR OFFICE USE ONLY



STAFF:

Date Received: _____
Received By: _____
Fee Paid: _____

Application Number: _____
Zone: _____
Tax ID Number: _____


PLANNER:

Complete / Incomplete
Date: _____ Reviewed by: _____



SALAZAR
ENTRY NO. 437410
ID 0021-2773

SALAZAR
ENTRY NO. 467075
ID 0021-2717
POS # 3026



55 WEST CENTER
P.O. BOX 176
HEBER CITY, UT 84032

P: 435.654.9229
F: 435.054.0231

Summit Engineering Group
Structural • Civil • Surveying

SALAZAR SPRING SUBDIVISION



Summit Engineering Group Inc.

Summit Engineering Group, Inc
55 West Center St.
PO Box 176
Heber City, UT 84032
435-654-9229

Water Rights Calculation Sheet

SALAZAR SPRING SUBDIVISION - 3 LOTS

TOTAL ACREAGE =	2.73	acres	Non-Irrig 8000 sqft/house =	0.55	acres
TOTAL NEW HOMES =	3	homes			
TOTAL IRRIGATION =	2.179	acres	Midway Irrigation Shares =	3.00	ac-ft per share

Required Water

Culinary Use	0.80	AF/home	Total Municipal Indoor =	2.400	AF
Outdoor Irrigation	3.00	AF/acre	Total PI Outdoor =	6.537	AF

Total Water =	8.94	AF
---------------	------	----

Total Water Required =	8.94	AF
Midway Irrigation Shares Req'd =	2.98	SH

New/Old Business



Adjourn

