

MINUTES

UNIFORM BUILDING CODE COMMISSION  
PLUMBING /HEALTH ADVISORY COMMITTEE  
MEETING

November 4, 2021 9:00

Meeting

CONVENED: 9:02

ADJOURNED: 10:53

STAFF:

Steve Duncombe, Bureau Manager  
Sharon Smalley, Secretary

COMMITTEE MEMBERS:

Nathan Lunstad  
Andrea Gamble  
Travis Hales (absent)  
Jeff Brown  
Dean Johnson

Linda Ebert  
Jeremy Haslam  
Don Simons  
Rob Allen (excused)

VISITORS:

Jessie Sharp, Logan City Water & Utah Cross Connection Commission  
Gary Rager, Division of Drinking Water & Utah Cross Connection Commission  
Chris Bowles,

MINUTES

A motion was made by Jeremy Haslam to approve the minutes from the October 7, 2021 meeting as written. The motion was seconded by Dean Johnson and passed unanimously.

REVIEW PROPOSED  
AMENDMENT FOR  
15A-3-205(10) FOR  
SECTION 2910.5

The committee reviewed a possible new amendment for IPC Section 1301.5.1 and a definition for swing connection. Following the discussion, the following wording was developed: "A system that utilizes nonpotable water (i.e., pressurized irrigation) and installs a connection to the potable water system for backup must install a Reduced Pressure Principle Assembly (RP) directly downstream of the potable water connection (Stop and Waste) and install a "swing connection" directly downstream from the (RP) installed so that either the potable water system or the nonpotable water is connected

at any time to prevent a direct Cross Connection and to protect the potable water from any potential hazard from the nonpotable water system. (see Utah Code: Title19-4-112) Note: RP must be tested within 10 days of installation and annually whether the drinking water is used or not.”

Linda Ebert will work on a definition for the word “Swing Connection” for the committee to review at the December meeting.

A motion was made by Linda Ebert to approve the wording for a new amendment for IPC Section 1301.5.1. The motion was seconded by Dean Johnson and passed unanimously.

A motion was made by Linda Ebert to add the verbiage from the new amendment for IPC Section 1301.5.1 as a new amendment for IRC Section P2910.5. The motion was seconded by Dean Johnson and passed unanimously.

CONTINUE WITH THE REVIEW  
OF THE PLUMBING PORTION OF  
THE 2021 IRC AND CURRENT  
AMENDMENTS

The committee reviewed the current amendment for Section P312.10.2. The words “or within 10 days of being placed into service” will be added. A motion was made by Dean Johnson to add that wording to the current amendment. The motion was seconded by Jeremy Haslam and passed unanimously.

The committee reviewed the current amendment for IPC Section 608.17.7. Nathan Lunstad and Linda Ebert will do further review of this amendment and have a recommendation for the December meeting.

The meeting adjourned at 10:53.

*Note: These minutes are not intended to be a verbatim transcript but are intended to record the significant features of the business conducted in this meeting. Discussed items are not necessarily shown in the chronological order they occurred.*

UNIFORM BUILDING CODE COMMISSION  
PLUMBING/HEALTH ADVISORY COMMITTEE

*Nathan Lundstad*  
Nathan Lundstad (Dec 2, 2021 10:58 MST)

---

Nathan Lundstad, Chairman

12/02/2021

---

Date

*Stephen Duncombe*

---

Steven Duncombe, Bureau Manager

12/02/2021

---

Date