

MINUTES

UNIFORM BUILDING CODE COMMISSION
PLUMBING /HEALTH ADVISORY COMMITTEE
MEETING

December 2, 2021 9:00

Meeting

CONVENED: 9:08

ADJOURNED: 10:53

STAFF:

Steve Duncombe, Bureau Manager
Sharon Smalley, Secretary

COMMITTEE MEMBERS:

Nathan Lunstad
Andrea Gamble (absent)
Travis Hales (absent)
Jeff Brown (absent)
Dean Johnson

Linda Ebert
Jeremy Haslam
Don Simons
Rob Allen

VISITORS:

Jessie Sharp, Logan City Water & Utah Cross Connection Commission
Greg Hand

MINUTES

A motion was made by Jeremy Haslam to approve the minutes from the November 4, 2021 meeting as written. The motion was seconded by Linda Ebert and passed unanimously.

REVIEW THE DEFINITION FOR
"SWING CONNECTION"

Linda Ebert drafted a possible definition for the word "swing connection". The committee reviewed the draft and agreed that the word "swing connection" should be changed to "dual source connection". Following the discussion, a motion was made by Rob Allen to approve the definition as modified. The motion was seconded by Jeremy Haslam and passed unanimously.

It was noted that the word "swing connection" as used in Section 1301.5.1 also needs to be changed to "dual source connection". A motion was made by Rob Allen to utilize same wording. The motion was seconded by Linda Ebert and passed unani-

REVIEW CURRENT AMENDMENT
FOR IPC SECTION 608.17.7

mously.

Those present reviewed the wording in the current amendment. The recommendation was to add the words “not downstream of an atmospheric vacuum breaker” and delete the words “a sink faucet”. A motion was made by Linda Ebert to accept the change and adopt the wording. The motion was seconded by Dean Johnson and passed unanimously.

The committee reviewed the current amendment for Section 608.17.4.1 and agreed that the words “or double check valve detector assembly” should be added after the word “assembly”. Rob Allen made a motion to approve the wording as edited. The motion was seconded by Linda Ebert and passed unanimously.

No other changes were recommended for amendments to the 2021 plumbing codes. The committee will meet again in April for one final review.

The next meeting will be April 7th at 9:00.

The meeting adjourned at 10:01.

Note: These minutes are not intended to be a verbatim transcript but are intended to record the significant features of the business conducted in this meeting. Discussed items are not necessarily shown in the chronological order they occurred.

UNIFORM BUILDING CODE COMMISSION
PLUMBING/HEALTH ADVISORY COMMITTEE

Nathan Lundstad
[Nathan Lundstad \(May 5, 2022 12:16 MDT\)](#)
Nathan Lundstad, Chairman

05/05/2022

Date

Stephen Duncombe
Steven Duncombe, Bureau Manager

05/05/2022

Date