

AGENDA

UNIFORM BUILDING CODE COMMISSION
ELECTRICAL ADVISORY COMMITTEE

March 13, 2014 1:00
Room 402
160 E 300 S Salt Lake City, UT

This agenda is subject to change up to 24 hours prior to the meeting.

1. Swear in new members
2. Approve minutes from the February 13, 2014 meeting
3. Review 2014 NEC

Please call Sharon at 801-530-6163 or email ssmalley@utah.gov if you do not plan on attending this meeting.



In compliance with the Americans with Disabilities Act, individuals needing special accommodations (including auxiliary communicative aids and services) during this meeting should notify Dave Taylor, ADA Coordinator, at least three working days prior to the meeting. Division of Occupational and Professional Licensing, 160 East 300 South, Salt Lake City UT 84115, Phone 530-6628 or toll-free in Utah only 866-275-3675.

UNIFORM BUILDING CODE COMMISSION

ELECTRICAL ADVISORY COMMITTEE
MEETING

February 13, 2014 9:00
Room 341 Sandy City Hall
10000 Centennial Pkwy Sandy, UT

MINUTES

STAFF

Dan S Jones, Bureau Manager
Sharon Smalley, Board Secretary

ELECTRICAL ADVISORY COMMITTEE MEMBERS

Christopher Jensen	David Wesemann (absent)
Mike Thomas	Gary Beckstrand
Chris Joyal, Liaison	Rhett Butler (excused)
Kevin Phillips	

VISITORS

Tim McClintock, NFPA

MINUTES

A motion was made by Mike Thomas to approve the minutes from the January 9, 2014 meeting as written. The motion was seconded by Chris Jensen and passed unanimously.

REVIEW AND TRAINING ON 2014
NEC

Gary Beckstrand introduced Tim McClintock who will be conducting the training for the 2014 NEC. The procedure that will be followed for the code review was discussed.

The meeting was turned over to Mr. McClintock for the training.

During the training and discussion on the significant changes, the following Articles were determined to be items that need further review by the committee:

- 110.26 (C)(3) Personnel doors
- 210.12 Arc-fault circuit interrupter protection
- 210.64 Electrical Service Areas
- 240.87 Arc Energy Reduction
- 590.4(J) Support

625 Electric Vehicle Charging Systems
680.21(C) GFCI Protection
680.25(A)(1) Exception
700.8 Surge Protection
700.28 & 701.27 Selective Coordination

The meeting adjourned at 4:57.

Note: These minutes are not intended to be a verbatim transcript but are intended to record the significant features of the business conducted in this meeting. Discussed items are not necessarily shown in the chronological order they occurred.